



Control Systems

Pole Mounted Plant (PMP) Control Boards

Business Case

25 January 2024

CONTENTS

1	Summary	3
2	Purpose and scope	4
3	Background	4
3.1	Asset Population	4
3.2	Asset Management Overview	4
3.3	Asset Performance.....	5
3.4	Consequence of Failure (CoF).....	6
3.5	Likelihood of Consequence (LoC).....	7
4	Identified Need.....	7
4.1	Problem Statement	7
4.2	Compliance	8
5	Asset Limitation Forecast Summary.....	8
5.1	Problematic Control Board	8
6	Recommendation.....	8

List of Tables

Table 1 : Forecasted Replacement Volume	8
---	---

List of Figures

Figure 1 : Age Profile	4
Figure 2 : Unassisted Control Systems Failures	5
Figure 3 : Control Systems Defects.....	6

DOCUMENT VERSION

Version Number	Change Detail	Date	Updated by
Draft v0.1	Draft	13/03/2023	Engineer Asset Strategy
Draft v0.2	AER Document Initial Release	31/05/2023	Engineer Asset Strategy
Draft v0.3	Final draft - Formatted	09/11/2023	Manager Asset Strategy
V1.0	Finalised	23/11/2023	Manager Asset Strategy

RELATED DOCUMENTS

Document Date	Document Name	Document Type
JAN 2024	Asset Management Plan – Control Systems	PDF
1/03/2023	Electrical Safety Act 2002 (Qld)	PDF
17/06/2022	Electrical Safety Regulation 2013 (QLD)	PDF
OCT 2023	Lines Defect Classification Manual	PDF
V3	Substation Defect Classification Manual	PDF
NOV 2023	Energex 2022-23 - Category Analysis - RIN Response - Consolidated - 24 November 2023 – PUBLIC (16063386.1)	Excel
FEB 2021	Electrical Safety Code of Practice 2020 - Works	PDF

1 SUMMARY

Title	EGX Control Systems Business Case AER 2025-30								
DNSP	Energy Queensland (EQL) – Energex Ltd								
Expenditure category	<input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Augmentation <input type="checkbox"/> Connections <input type="checkbox"/> Tools and Equipment <input type="checkbox"/> ICT <input type="checkbox"/> Property <input type="checkbox"/> Fleet								
Identified need	<input checked="" type="checkbox"/> Legislation <input type="checkbox"/> Regulatory compliance <input checked="" type="checkbox"/> Reliability <input type="checkbox"/> CECV <input checked="" type="checkbox"/> Safety <input type="checkbox"/> Environment <input type="checkbox"/> Financial <input type="checkbox"/> Other <p>The objective of this business case is to outline the limitation forecast associated with control boards in accordance with the lifecycle management strategies detailed in the Asset Management Plan. Additionally, this Business Case provides the summary of proposed interventions, both in terms of volume and financial allocations during the regulatory period 2025-30.</p> <p>Energex has an ongoing program of work for the replacement of high-risk and ageing problematic control boards within its network. To meet the challenges of Energex retiring its problematic and ageing control board population; control board replacements will be an ongoing endeavour. With strategic spares quickly depleting, the growing cost of unplanned replacements after failure will be significant and prolong Energex’s exposure to network safety, reliability, and financial risks.</p>								
Expenditure		Year	2025-26	2026-27	2027-28	2028-29	2029-30	2025-30	
		\$m direct 2022-23	3	3	3	3	3	15	
		Replacement	20	20	20	20	20	100	
Optimal timing and NPV analysis	<p>Within the framework of the Network Planning Process, an assessment is conducted for the limitations associated with each control system module. Subsequently, individual projects are initiated, and an assessment undertaken to determine the optimal timing for their replacement. This procedure involves performing Net Present Value (NPV) analysis, risk assessment, and consolidating activities with other network assets in suboptimal condition at a designated timing. This ensures prudence and efficiency, ultimately curbing the financial impact on our customers and the broader community.</p> <p>Attachment 5.2.01 SCS Capex model – January 2024 outlines our overall investments for the 2025-2030 period, which will include control systems with other investments. Business cases for those investments are available on request.</p>								

2 PURPOSE AND SCOPE

The purpose of this document is to outline the forecast volumes of replacement and expenditure associated with pole mounted plant (PMP) for problematic control board boards in accordance with the lifecycle management strategies detailed in the Control Systems Asset Management Plan.

This business case should be read in conjunction with the Asset Management Plan - Control Systems. All dollar values in this document are based upon 2022-23 dollars and exclude overheads.

3 BACKGROUND

Pole mounted plant (PMP) recloser control boards play a crucial role in enabling SCADA to operate field-based switch equipment, ensuring safe operation and control of the network. These control boards facilitate the necessary functions of field-based switch equipment, such as network protection, network switching and minimizing customer outages in the event of a fault. These control boards have an expected life of 25 years.

3.1 Asset Population

There are approximately 2,600 recloser control boards across the Energex network as per Figure 1.




Figure 1 : Age Profile

3.2 Asset Management Overview

Energex adopts several strategies in managing the asset. These include:

- **Preventative maintenance:** which is performed in accordance with the inspection and Maintenance Standard Tasks with maintenance intervals outlined in the Maintenance Activity Frequency.

- **Corrective Maintenance:** undertaken when inspection and condition monitoring classify defects as outlined in the Lines Defect Classification Manual and Substation Defect Classification Manuals.
- **Proactive Replacement:** is the management strategy used in conjunction asset performance monitor and trending to replace problematic assets.

Energex manages our critical spares by proactively reviewing and adjusting stock levels held in stores and manage spares recovered from projects for 'like for like' applications. Where possible, replacement of defective or failed control boards with 'like for like spares is the preferred option.

3.3 Asset Performance

A control board is deemed to have failed if it can no longer perform its basic function of detecting and tripping to isolate power system faults or operation on demand. Failures spiked in 2021-22 year due to the intensification of storm activities and replacement of the failed recloser controller boards and sub-components as per Figure 2. However, the number of failures for 2022-23 reduced to be more in line with historical failures.




Figure 2 : Unassisted Control Systems Failures

A control board is classified as defective if one or more components are not performing as expected but the control board can still perform its basic function of detecting and tripping to isolate power system faults or operation on demand. Defect quantities have gradually increased in the last three years. This is most likely due to recent intensification of storm activities as per Figure 3.




Figure 3 : Control Systems Defects

3.4 Consequence of Failure (CoF)

Consequences of an in-service failure has been assessed across four value streams and are relevant to this business case:

- **Reliability:** Represents the unserved energy cost to customers of network outages and is based on an assessment of the amount of Load at Risk in circumstances where the recloser control board fails and the recloser function is inhibited. This may result in loss of supply until crews are able to temporary bridge the recloser until the failed control board has been replaced or repaired.
- **Financial:** The financial cost is derived from an assessment of the likely replacement costs incurred by the failure of the asset. This cost can substantially increase for emergency replacements.
- **Safety:** There is a risk of multiple serious injuries or fatality following a failure of a recloser control board. Additionally, a recloser control board failure could lead to widespread asset damage inside/outside of the substations causing significant public safety issues
- **Environmental:** It is unlikely for a failure of a recloser control board to result in environmental impact/contamination

3.5 Likelihood of Consequence (LoC)

The likelihood of consequence refers to the probability of a particular outcome or result occurring because of a given event or action. To estimate the likelihood of consequence, Energex has utilised a combination of historical performances and researched results.

Energex has analysed past events, incidents, and data to identify patterns and trends that can provide insights into the likelihood of similar outcomes occurring in the future. Additionally, Energex also has conducted extensive research to gather relevant information and data related to the respective risk criteria.

4 IDENTIFIED NEED

4.1 Problem Statement

Energex has a substantial number of recloser control boards that pose significant issues. Problematic control boards constitute 65% of the overall control board population and have been experiencing a rising number of failures, malfunctions, and unavailability for procurement. The major challenge lies in replacing these problematic control boards with current contract control boards which differ in make and model.

This necessitates the implementation of a new SCADA build for a non-like-for-like replacement, a process that can extend up to a duration of 12 months. Therefore, opting for replacement using strategic spares is the preferred course of action.

The observed increase in failures across the Energex region during storm seasons underscores the urgent need for strategic spares to swiftly restore assets and normalise network configurations. Prompt action is required to address any potential depletion of spares, given the critical role of these devices in reducing customer outages during fault scenarios. Failure to do so could jeopardise Energex's ability to meet guaranteed service levels and minimum standards, particularly if outage rate increase.

The unavailability of spares exposes Energex to the following risks:

- Abnormal network configurations, such as bypassing the PMP, which can lead to operational challenges.
- Inability to provide high-speed protection, jeopardizing the safety of staff, the public, and primary assets.
- Potential for larger customer outages resulting from abnormal network configurations during faults.
- Significant financial impacts due to unplanned and urgent corrective maintenance, potentially requiring the replacement of entire PMPs

It is essential for Energex to prioritize the availability of spare parts to mitigate these risks, ensure operational efficiency, and uphold their commitment to customer service and safety.

4.2 Compliance

This business case is guided by the following legislation, regulations, rules and codes:

- Electricity Act 2002 (Qld)
- National Electricity Rules (NER)
- Electrical Safety Act 2002 (Qld)
- Electrical Safety Regulation 2013 (Qld)
- Queensland Electrical Safety Code of Practice 2020 – Works (ESCOP)
- Work Health & Safety Act 2011 (Qld)
- Work Health & Safety Regulation 2011 (Qld)

5 ASSET LIMITATION FORECAST SUMMARY

5.1 Problematic Control Board

Table 1 identifies the forecasted replacement volumes for the high-risk problematic control boards. This forecast is an estimate of the likely level of replacements included with other projects in our program of work.

Year	2025-26	2026-27	2027-28	2028-29	2029-30	2025-30
\$m direct 2022-23	3	3	3	3	3	15
Volume	20	20	20	20	20	100

Table 1 : Forecasted Replacement Volume

6 RECOMMENDATION

The proposed volume provides the best balance of benefits and risks for the organisation.