



Underground Cable Replacements Business Case

19 January 2024



Part of Energy Queensland

CONTENTS

1	Summary	4
2	Purpose and scope	6
3	Background	6
3.1	Asset Population	6
3.2	Asset Management Overview	7
3.3	Asset Performance.....	8
3.4	Risk Evaluation.....	10
4	Identified Need.....	12
4.1	Problem and/or Opportunity	12
4.2	Compliance	12
5	Asset Limitation Forecast Summary.....	13
5.1	Asset Condition Limitations – Health Index (HI) Summary.....	13
6	Optimal timing and NPV Risk Analysis.....	15
6.1	Asset Replacement Limitation Forecast	15
7	Recommendation.....	15

List of Tables

Table 1: UG Cables Population Volume Summary	7
Table 2: UG Cables Replacement Volumes.....	15
Table 3: UG Cables Replacement Volumes Summary – RIN Forecast.....	15

List of Figures

Figure 1: Age Profile UG Cables	7
Figure 2: Unassisted UG Cables Failures	9
Figure 3: UG Cables Defects.....	9
Figure 4: Monetised Risk Calculations	10
Figure 5: Total Risk Cost calculations	10
Figure 6: Health Index and Condition Relationship	13
Figure 7: HI Summary Current 2023-24 – Underground Cables.....	14
Figure 8: Future Forecast HI Summary 2029-30 – Underground Cables	14

DOCUMENT VERSION

Version Number	Change Detail	Date	Updated by
Draft v0.1	Draft	16/09/2023	Snr Asset Engineer
Draft v0.2	Initial Release	31/10/2023	Snr Engineer Asset Strategy
V1.0	Approved	16/11/2023	Manager Asset Strategy

RELATED DOCUMENTS

Document Date	Document Name	Document Type
JAN 2024	Asset Management Plan – Underground Cables	PDF
NOV 2023	Underground Cable CBRM/CNAIM Model	Excel
JUN	RIN 2.2 Compare 2021-22 (Rosetta)	Excel
NOV 2023	Ergon 2022-23 - Category Analysis - RIN Response - Consolidated - 23 November 2023 – PUBLIC (16058117.2)	Excel
AUG 2023	Maintenance Activity Frequency (MAF) – Release 2	PDF
JUN 2023	Maintenance Acceptance Criteria (MAC) – Release 11	PDF
OCT 2023	Lines Defect Classification Manual	PDF
JUL 2023	Substation Defect Classification Manual	PDF

1 SUMMARY

Title	Underground Cable Replacements
DNSP	Ergon Energy
Expenditure category	<input type="checkbox"/> Replacement <input type="checkbox"/> Augmentation <input type="checkbox"/> Connections <input type="checkbox"/> Tools and Equipment <input type="checkbox"/> ICT <input type="checkbox"/> Property <input type="checkbox"/> Fleet
Identified need	<input type="checkbox"/> Legislation <input checked="" type="checkbox"/> Regulatory compliance <input checked="" type="checkbox"/> Reliability <input type="checkbox"/> CECV <input checked="" type="checkbox"/> Safety <input checked="" type="checkbox"/> Environment <input checked="" type="checkbox"/> Financial <input type="checkbox"/> Other <p>The objective of this Business Case report is to outline the projected limitations pertaining to underground cable assets in alignment with the lifecycle management approaches specified in the Asset Management Plan. Additionally, this Business Case provides the necessity for interventions, both in terms of volume and financial allocations during the regulatory period 2025-30, as informed by the results of CNAIM/CBRM modelling for cables $\geq 22\text{kV}$ and asset performance trend for less than 22kV.</p> <p>UG cables are critical to the network due to the large energy transfer requirements without visibility of assets above the ground providing improved public safety and supply reliability - through reduced failures due to significantly less exposure to external interventions including environment and humans, in comparison to overhead network assets. However, UG construction adds much more challenges during fault location and remedial works following a failure partially negating some of the gains in reliability performance. These assets feature prominently in Safety Net contingency plans required by Ergon Energy's Distribution Licences. Ergon Energy employs all reasonable measures to ensure it does not exceed minimum reliability service standards, assessed as:</p> <ul style="list-style-type: none"> • System Average Interruption Duration Index (SAIDI) • System Average Interruption Frequency Index (SAIFI) <p>Ergon Energy have a moderate quantity of older UG cables, both HV and LV assets. This is likely due to the typically lower loads that the assets have been required to supply, and the resultant extension on their useful life. While life extension of the asset is desirable, the proportion of assets that have exceeded the expected life presents a risk that needs to be monitored and managed in order to meet asset management objectives.</p> <p>Investment in the replacement of Underground (UG) cable is required to manage legislative and regulatory compliance, and reliability, financial, safety, and environmental risks and consequences that may arise due to their failure.</p> <p>Through trending of defect and fault data, specific types of UG cable are being targeted for replacement.</p>

Expenditure & Volume	Year	2025/26	2026/27	2027/28	2028/29	2029/30	Total
	Defect UG Cable Replacement (Capex Model Input project "Underground Cable Replacements Business Case")	6.5	6.8	6.8	7.1	7.1	34.2
UG Cable Replacement Projects*	0.8	0.5	0.6	0.8	1.4	4.1	
Business Case Total	7.2	7.2	7.4	7.9	8.5	38.2	

* UG Cable replacement projects included in sub-transmission and cable pit replacement projects

Optimal timing and NPV analysis	<p>For UG cable rated $\geq 22\text{kV}$, within the framework of the Network Planning Process, an assessment is conducted for the limitations associated with each UG feeder. Subsequently, an individual project is initiated to ascertain the optimal timing for their replacement. This procedure involves performing Net Present Value (NPV) analysis, risk assessment, and consolidating activities with other network assets in suboptimal condition at a designated timing. Our goal is to ensure utmost prudence and efficiency, ultimately curbing the financial impact on our valued customers and the broader community.</p> <p>Attachment 5.2.01 SCS Capex model – January 2024 outlines our overall investments for the 2025-2030 period, which will include protection relays. Business cases for those investments are available on request.</p> <p>For underground cables rated below 22kV, including low-voltage cables, the replacement forecast relies on historical instances of failures, defects, and known issues. Predictive modelling is not an effective approach for this asset category due to the limited availability of condition data resulting from inspection challenges and the expensive cost of diagnostic testing. Instead, a strategy based on "Safety First, As Far As is Reasonably Practicable" (SFAIRP) has been deemed the most suitable approach for managing these cables in alignment with industry best practices among Distribution Network Service Providers (DNSPs). This approach has been successfully implemented by Ergon Energy for several years, as detailed in the Asset Management Plan.</p>
---------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

2 PURPOSE AND SCOPE

The objective of this business case document is to define the projected limitations related to Underground cable for the regulatory period 2025-30, as informed by the results of CNAIM/CBRM modelling for $\geq 22\text{kV}$ and asset performance analysis for $< 22\text{kV}$. It is essential to read this document in conjunction with the Asset Management Plan Underground Cables.

3 BACKGROUND

Underground cable systems are designed and constructed to provide the physical connection and electrical continuity to allow for the safe and reliable transmission and distribution of electrical power. Failure of underground cable assets to perform their function results in negative impacts to Ergon Energy business objectives related to safety, reliability, and regulatory compliance.

Ergon has identified a number of current and emerging issues that are driving targeted replacement programs to remove high risk / condition driven high voltage UG cable from the network.

Underground cables due to their very nature are inherently challenging to access for maintenance or inspection. As such, verification of the data to ensure reliable asset population counts, age profiling and asset condition is difficult to accurately determine in situ. Ergon Energy is working to improve its data quality and actively investigating and pursuing advancements in underground cable condition assessment, cable diagnostics and insulation rejuvenation techniques that will further assist in the management of this asset class.

3.1 Asset Population

Ergon Energy owns and maintains approximately 9,425 kms of UG cable throughout Queensland at distribution, sub-transmission, and transmission voltages. Also, UG assets include cable accessories and UG link boxes, Pits and Pillars required for joints and terminations of these cables.

Ergon Energy maintains a diverse population of underground cable types and sizes due to legacy organisation standards, changes in period contracts and advancement in cable technology.

Cables population summary had been provided in Table 1 and Figure 1. We have approximately 40km that will be above 60 years old by 2029-30, and 87km over 50 years. There are several known issues and problems with this asset class that require replacement at the modest rate that we have forecast in this business case.

Asset type	Volume (km)
< = 1 kV	6,742
> 1 kV & < = 11 kV	1,865
> 11 kV & < = 22 kV	725
> 22 kV & < = 33 kV	58
> 33 kV & < = 66 kV	19
> 66 kV & < = 132 kV	15
> 132 kV	0
Total	9,425

Table 1: UG Cables Population Volume Summary




Figure 1: Age Profile UG Cables

3.2 Asset Management Overview

This asset class is managed, consistent with our corporate asset management policy, to achieve all legislated obligations and any specifically defined corporate key performance indicators, and to support all associated key result areas as reported in the Statement of Corporate Intent (SCI).

Underground cables operating at 22kV or above are managed with predictive modelling in line with Condition Based Risk Management (CBRM) and Common Network Asset Indices Methodology (CNAIM) principles. Both observed external deterioration and measured condition data is regularly collected to be incorporated into the determination of condition scoring and Health Index for all UG cables to calculate the future probability of failure. Replacements are undertaken based on overall risk evaluation and failure consequences analysed for each UG cable to optimise the cost/benefits for community.

However, assets operating below 22kV are managed by population trends, historical failures, defects and known issues, inspected/assessed regularly where possible/practicable, and allowed to operate as close as practical to end of life before replacement. End of asset life is determined by reference to the benchmark standards defined in the Defect Classification Manuals and or Maintenance Acceptability Criteria. Replacement work practices are optimised to achieve bulk replacement to minimise overall replacement cost and customer impact.

Life extension techniques are applied where practical, consistent with overall legislative, risk, reliability, and financial expectations. Problematic assets such as very high maintenance or high safety risk assets in the population are considered for early retirement.

3.3 Asset Performance

Two main failure modes have been considered in this business case as per the following descriptions:

- **Unassisted Failures:** Functional failure of an UG cable asset or component under normal operating circumstances and not caused by any external intervention such as abnormal weather or human.
- **Defects:** UG cable asset or component deemed defective based on prescribed classifications and if not rectified in a prescribed time scale (P0/P1/P2) could result in an unassisted failure.

Unassisted asset failures occur where the programs in place to manage the assets do not identify and rectify an issue prior to the asset failing to perform its design function. Failures that are the result of circumstances beyond the reasonable control of any practical management system are deemed Assisted Failures. Ergon Energy has developed a suite of maintenance programs to identify, prioritise and remediate underground cable asset defects where visual inspection is achievable. Defects identified via inspection programs are classified and prioritised according to the Ergon Energy Lines Defect Classification manual (LDCM).

Identified defects are scheduled for repair according to a risk-based priority scheme (P0/P1/P2). The P0, P1 and P2 defect categories relate to priority of repair, which effectively dictates whether normal planning processes are employed (P2), or more urgent repair works are initiated (P1 and P0).

Historical failure and defect data has been summarised in Figure 2 and Figure 3. The data indicates consistent failure and defect rates over the last five years, indicating effectiveness of the current management approach for this asset class.

Furthermore, unassisted failures in Ergon Energy show dominant failure modes of cable and terminations. Terminations and joints have traditionally shown to have higher failure rates than cables across the voltage ranges due to human factors during installation.




Figure 2: Unassisted UG Cables Failures




Figure 3: UG Cables Defects

3.4 Risk Evaluation

The risk is calculated as per equation in Figure 4.




Figure 4: Monetised Risk Calculations

Each consequence category follows the same calculations in Figure 4 to obtain the total monetised risk is as per Figure 5. Ergon Energy broadly considers five value streams for investment justifications regarding replacement of widespread assets. In Figure 5, only four of the value streams are considered; the 'Export' is not material to UG cables.




Figure 5: Total Risk Cost calculations

3.4.1 Probability of Failure (PoF)

In order to determine the assets condition realistically, several contributing factors have been considered including appropriate probabilistic impact scales in line with Condition Based Risk Management (CBRM) and Common Network Asset Indices Methodology (CNAIM) principles. Both observed external deterioration and measured condition data has been incorporated into the determination of Health Index for all UG cables operating above 22kV to calculate the future probability of failure.

Observed condition data mainly involves visible deteriorations of support structure and external damages to cables/terminations including rust, corrosion and leaks on metallic and fluid filled cables/terminations. The measured condition data incorporates electrical testing results (IR, VLF and PD testing), sheath testing and thermos-scanning results.

The PoF is calculated based on a well-established equation set out in CBRM/CNAIM modelling after analysing worldwide data about the relationship between health index and PoF for different assets. The equation involves two specific constant factors to be applied aligning the PoF with a specific type of asset and historical failure data experienced by the DNSP operating in different operating conditions. Please refer to the CBRM/CNAIM document for full details about these constants and PoF/HI relationship equation.

Considering the overall low failure rate and reliability consequences of failures, the condition data (observed and measured) process is considered uneconomical for UG cables assets ≤ 22 kV and therefore a different management approach as mentioned in Section 3.2 Asset Management Overview is adopted for this asset group.

3.4.2 Consequence of Failure (CoF)

Consequences of an in-service failure has been assessed across four value streams are relevant to this business case:

- **Reliability:** There will be unserved energy following the in-service failure of an UG cable. The network performance is also monitored through SAIDI and SAIFI performance of the distribution network – a key performance indicator for the business and community.
- **Financial:** There will be a financial cost associated with responding to a failed UG cable, as well as replacing the cable under emergency. The unplanned cost could vary significantly from couple of thousands to hundreds of thousands depending on length of the cable, location of the cable, type of the fault and the damage occurred to the cable or associated components such as termination/termination box, cable support structures, cable joint etc.
- **Safety:** There is a risk of multiple serious injuries or fatality following a failure of an UG cable, specifically old assets with metallic termination housings (potheads, link boxes etc), dependent on the failure mode and proximity of the employee/contractor or public during the event. Considering that these termination boxes are installed in public area a public member could be involved specifically near school or high pedestrian areas.
- **Environmental:** There is a moderate risk of environmental impact/contamination under right conditions in case of failure of an UG cable specifically fluid filled cables/boxes/terminations

3.4.3 Likelihood of Consequence (LoC)

Likelihood of consequence refers to the probability of a particular outcome or result occurring because of a given event or action. To estimate the likelihood of consequence, Ergon Energy has utilised a combination of historical performances and researched results. Ergon Energy has analysed past events, incidents, and data to identify patterns and trends that can provide insights into the likelihood of similar outcomes occurring in the future. Additionally, Ergon Energy also has conducted extensive research to gather relevant information and data related to the respective risk criteria.

4 IDENTIFIED NEED

4.1 Problem and/or Opportunity

The identified need for this investment is driven by a positive cost/benefit analysis based on Value of Customer Reliability, Financial, Safety and Environmental benefits.

Key current issues associated with this asset class and driving replacement programs are:

- Cast iron potheads.
- Low voltage Concentric Neutral Solid Aluminium Conductor (CONSAC) cable
- Hochstadter Screened Separately Lead Sheathed (HSL) cable.

Key emerging issues associated with this asset class and driving replacement programs are:

- Water treeing in XLPE cable
- Ageing cable and associated obsolescence issues
- Cable jointing skill and capability
- Submarine cables
- Cable joint and termination failure rates
- Recovery of redundant cable
- LV Pillar defect and failure rates
- Distribution Cable Cit Lids not designed for explosive failures.
- Distribution Cable Pits with structural defects requiring pit rebuilds.
- Distribution Cable Pits with various defects requiring rectification work.
- Unreliable distribution cable and supply configurations feeding future critical Olympic venues.

Our Asset Management Plan – Underground Cables outlines each of these issues and their impact on future replacement programs.

4.2 Compliance

The Electrical Safety Act 2002 (Qld) s29 imposes a specific duty of care upon Ergon Energy, which are prescribed Electrical Entities:

- 1) An electricity entity has a duty to ensure that its works—
 - a) are electrically safe; and
 - b) are operated in a way that is electrically safe.
- 2) Without limiting subsection (1), the duty includes the requirement that the electricity entity inspect, test and maintain the works.

Ergon Energy, under the Electricity Safety Regulations 2013 (Qld), is required to notify the Electrical Safety Office in the occurrence of any Serious Electrical Incident (SEI) or Dangerous Electrical Event (DEE).

Under the Electricity Regulation 2006 (Qld) an electricity entity must, in accordance with recognised practice in the electricity industry, periodically inspect and maintain its works to ensure the works remain in good working order and condition.

The Queensland Coastal Protection and Management Act controls infrastructure on and across tidal lands, waterways, and harbours. The Transport Infrastructure Act 1994 (Qld) (specifically Division 3) covers assets within carriage way boundary of all state roads.

The Marine Parks Act 1982 (Cth) (Moreton Bay areas) covers infrastructure such as cables to Russell Island and Bribie Island.

The Commonwealth Great Barrier Reef Marine Park Act 1975 establishes a framework for protection and management of the reef and its environs. The park includes coastline slightly north of Bundaberg through to Cape York, covering much of the coastal area containing Ergon Energy infrastructure. The Great Barrier Reef Marine Park Regulations 2019 establishes a Permit System for operating, maintaining and renewing facilities in the Park, and Ergon Energy has a specific permit to operate submarine cables between the mainland and Magnetic Island, Dunk Island, and Hayman Island which embodies specific environmental conditions upon the operations.

5 ASSET LIMITATION FORECAST SUMMARY

5.1 Asset Condition Limitations – Health Index (HI) Summary

Ergon Energy uses CBRM/CNAIM to predict the end of life of HV UG cables at >22kV voltages. CBRM uses age, location, and condition to predict the health of the asset as an index (Health Index – HI) that has a range of 0 – 10. A higher HI value represents a more degraded asset as illustrated in Figure 6.




Figure 6: Health Index and Condition Relationship

Ergon considers assets for replacement when HI reaches 7.5. The asset management plan documents the basis of the condition analysis and derivation of health index. The Ergon risk framework is applied to prioritise asset replacement at a program level within financial and resource constraints. Please note that the UG cables 22kV and below are maintained and replaced based on failures, defects and known problematic issues.

The oldest UG cables in the population that have exceeded their technical life are also considered as potential candidates for replacement. Replacement of potential candidate assets is subsequently considered based on network requirements and in alignment with other network drivers such as augmentation and customer requested works to ensure the final option to address the identified limitation is the most cost effective from a whole-of-network perspective. The Ergon Energy risk framework is applied to prioritise asset replacement at an individual project level within financial and resource constraints.

The latest HI information of UG Cables has been provided in Figure 6. A HI of 7.5 indicates poor condition of the UG cable with intervention required in a specified time frame. The seven-year HI profile forecast indicates only a few km of the UG cables over a condition score of 7.5 by the end of the regulatory period in 2030.

Note that this CBRM data is applicable only for HV cables operating above 22kV voltage level. The remaining UG cable asset fleet operating at 22kV and below including all LV cables, which constitutes more than 96% of our total cable volumes. Replacements of this cable would be in addition to our sub-transmission cable replacements. The proposed replacement volumes for this lower voltage cable category are based on historical failures rates, number of defects and known issues. A total of 15km per year of UG cables replacements are proposed during the regulatory period of 2025-30.




Figure 7: HI Summary Current 2023-24 – Underground Cables




Figure 8: Future Forecast HI Summary 2029-30 – Underground Cables

6 OPTIMAL TIMING AND NPV RISK ANALYSIS

This business case presents asset limitations in terms of asset condition, health index and associated monetised risk values based on CNAIM/CBRM modelling outcomes incorporating the historical data so far, as per descriptions in Section 5. This BC also forecast intervention requirements for this asset class during the regulatory period 2025-30.

However, the optimal timing of replacement of an asset, NPV analysis, risk evaluation and bundling of works with other poor condition network assets at a specific time shall be carried out in case-by-case basis under each individual projects based on overall prudence and efficiency to minimise the cost impact on customers/community.

6.1 Asset Replacement Limitation Forecast

Based on CNAIM/CBRM model and historical performance, the required replacement volume for 2025-30 is 15km per annum for $\geq 22\text{kV}$ and 20km for $< 22\text{kV}$ as per Table 2.

Year	2025/26	2026/27	2027/28	2028/29	2029/30	Total
$\geq 22\text{kV}$	20	20	20	20	20	100
$< 22\text{kV}$	15	15	15	15	15	75
Total Volume	35	35	35	35	35	175

Table 2: UG Cables Replacement Volumes

After conducting the risk evaluation, optimal timing and NPV analysis for individual project to optimise the cost/benefits for community the proposed modified volume summary and expenditures have been provided in Table 3.

Year	2025/26	2026/27	2027/28	2028/29	2029/30	Total
UG Cable \$m, direct 2022-23	6.5	6.8	6.8	7.1	7.1	34.2
Sub Transmission projects & Cable Pit replacement \$m, direct 2022-23	0.8	0.5	0.6	0.8	1.4	4.1
Quantity (km)	20	26	21	22	25	114

Table 3: UG Cables Replacement Volumes Summary – RIN Forecast

7 RECOMMENDATION

The proposed volume provides the best balance of benefits and risks for the organization. As such, the decision has been made to continue with counterfactual UG cable replacement strategy, with a focus on optimizing existing processes and enhancing efficiencies where possible.