



# Clearance to Ground & Structure Program

Business Case

19 November 2024

## CONTENTS

1	Summary.....	4
2	Purpose and scope .....	5
3	Revised regulatory proposal.....	5
	3.1 Changes from Regulatory Proposal.....	5
	3.2 Minor / Major Works Assessment .....	5
	3.3 Acceptance of Actual and Forecast Volumes .....	6
	3.4 Clarification of Unit Rates .....	6
	3.5 Compliance Obligations .....	6
	3.6 Identification of Defects.....	7
	3.7 Prioritisation of Defects .....	10
4	Identified Need .....	11
	4.1 Requirement for compliance .....	11
5	Options Analysis .....	12
	5.1 Option 1.....	12
	5.2 Cost Summary .....	12
	5.3 Risk discussion .....	12
6	Recommendation .....	13
	Appendix 1: Alignment with the National Electricity Rules.....	14
	Appendix 2: Reconciliation Table .....	16
	Appendix 3: Strategic Alignment .....	17
<b>List of Tables</b>		
	Table 1: Asset Function and Strategic Alignment .....	6
	Table 2: Defects Remediated by Regulatory Control Period.....	9
	Table 3: Cost Overview for Option 1 .....	12
	Table 4: Cost summary for 2025-30 period.....	12
	Table 5: Recommended Option's Alignment with the National Electricity Rules .....	14
	Table 6: Reconciliation .....	16

Table 7: Alignment to 'Enable' Building Blocks .....	17
Table 8: Alignment to Regulatory/Compliance Obligations .....	17
<b>List of Figures</b>	
Figure 1: LiDAR Program Delivery Timeline.....	8

## DOCUMENT VERSION

Version Number	Change Detail	Date	Updated by
1	Approved	18/11/2024	General Manager Asset Standards

## RELATED DOCUMENTS

- Energex – 5.5.02 – Business Case Clearance to Ground & Structure Program
- Attachment 5 – Capital expenditure | Draft decision - Energex distribution determination 2025–30
- Electrical Safety Regulation 2013,  
<https://www.legislation.qld.gov.au/view/pdf/inforce/current/sl-2013-0213>

## 1 SUMMARY

Title	Clearance to Ground and Structure Program														
DNSP	Energex														
Expenditure category	<input type="checkbox"/> Replacement <input checked="" type="checkbox"/> Augmentation <input type="checkbox"/> Connections <input type="checkbox"/> Tools and Equipment <input type="checkbox"/> ICT <input type="checkbox"/> Property <input type="checkbox"/> Fleet														
Identified need <i>(select all applicable)</i>	<input checked="" type="checkbox"/> Legislation <input checked="" type="checkbox"/> Regulatory compliance <input type="checkbox"/> Reliability <input type="checkbox"/> CECV <input checked="" type="checkbox"/> Safety <input type="checkbox"/> Environment <input type="checkbox"/> Financial <input type="checkbox"/> Other  Energex has a legislative obligation to maintain minimum electrical clearances of its overhead conductors to ground (CTG) and to structure (CTS) to ensure public safety. This business case sets out the options to meet the obligations and evaluates the costs and risks.														
Summary of preferred option	The preferred option is to remediate 3,995 defects across the Energex network over the 2025-2030 regulatory control period.														
Expenditure	A total of 3,155 CTG and 840 CTS defects are forecast to be remediated over the 2025-2030 regulatory control period at a unit rate of \$5,511 and \$27,884 respectively. Total cost of \$40.8 million in direct 2022-23 \$ is required over the 5 years. <table border="1" data-bbox="446 1187 1292 1332"> <thead> <tr> <th>Year</th> <th>2025-26</th> <th>2026-27</th> <th>2027-28</th> <th>2028-29</th> <th>2029-30</th> <th>2025-30</th> </tr> </thead> <tbody> <tr> <td>\$m, direct 2022-23</td> <td>8.16</td> <td>8.16</td> <td>8.16</td> <td>8.16</td> <td>8.16</td> <td>40.82</td> </tr> </tbody> </table>	Year	2025-26	2026-27	2027-28	2028-29	2029-30	2025-30	\$m, direct 2022-23	8.16	8.16	8.16	8.16	8.16	40.82
Year	2025-26	2026-27	2027-28	2028-29	2029-30	2025-30									
\$m, direct 2022-23	8.16	8.16	8.16	8.16	8.16	40.82									
Benefits	Benefits – implementation of the preferred option will ensure that Energex can meet its compliance obligations and in so doing, keep customers and the community safe.														

## 2 PURPOSE AND SCOPE

This document sets out the capital investment required for remediating clearance to ground (CTG) and clearance to structure (CTS) issues for overhead conductors. It compares the benefits of options to remediate the known defects, with the risks associated with unmitigated clearance problems identified through the aerial Light Detection and Ranging (LiDAR) program.

This business case has been developed for the purpose of justifying the investment required for clearance programs to be included in the Energex Network 2025-30 Regulatory Proposal to Australian Energy Regulator (AER). This investment is a key public safety component of operating a safe distribution network in Southeast Queensland.

The terms to be used in this document in order of timeline are:

- Energex Network 2025-30 Regulatory Proposal (Regulatory Proposal)
- Draft Decision – Energex Distribution Determination 2025-30 (Draft Decision)
- Energex Network 2025-30 Revised Regulatory Proposal (Revised Proposal)

## 3 REVISED REGULATORY PROPOSAL

### 3.1 Changes from Regulatory Proposal

This Revised Proposal details changes to the unit rates for the regulatory control period 2025-2030. This change in unit rates for both CTG and CTS result in a reduction in cost from \$50.8 million to \$40.8 million in 2022-23 \$. The volumes to be remediated remain unchanged.

The unit rates now reflect feedback from the Draft Decision where a combination of re-tensioning and actual unit rates from FY 2023-24 are used.

### 3.2 Minor / Major Works Assessment

When a clearance defect is scoped and triaged, several options may be suitable for remediation. In the range of solutions, the most prudent option is selected as the preferred remediation approach starting with minor works such as re-tensioning. Other minor works activities include use of raiser brackets and offset crossarms. Major works are considered when the minor rectifications are deemed unsuitable. Major works themselves have an increasing level of prudence starting with an interpole arrangement through to use of taller poles and network reconfiguration such as undergrounding.

Where minor works are deemed suitable, the defects is sent 'straight to field' for rectification. The most common minor works action is re-tensioning and the development of the unit rate for CTG recognises the feedback in the Ergon Energy Draft Decision. A re-tensioning rate of 10% of CTG defects is used for Energex minor works rectification at an average cost of \$7,969. The historical re-tensioning rate for Energex is just under 3% so use of 10% for minor works is a conservative value. By comparison, the equivalent Ergon Energy re-tensioning rate is just under 8%.

Traffic control in the urban settings of Energex can contribute to a significant portion of the minor works cost. When traffic control is considered with on-site risk assessments, switching required for access and performing the re-tension activity, the average cost of \$7,969 is reasonable.

Contributing factors as to why conductors (particularly aged conductors) can't simply be reinstated by re-tensioning can be due to the following factors:

- Stay movement and pole lean caused by soil expansion and contraction throughout the wet/dry seasons.
- Crossarm strength limitations and degradation.
- Pole strength degradation over time.
- Conductor degradation over time.

Where re-tensioning and other minor works is not deemed suitable by desktop assessment, the defect is sent to design for assessment. The design triage stage then assesses the defect for remediation options with the most prudent option selected.

### 3.3 Acceptance of Actual and Forecast Volumes

Energy Queensland notes AER’s acceptance of actual and proposed defect volumes in the Regulatory Proposal for the Clearance to Ground and Structure Program. A total of 3,155 CTG and 840 CTS are forecast to be delivered over the regulatory control period 2025-2030. Given this acceptance, justification for the volumes will not be discussed but are shown in Table 2 for clarity.

### 3.4 Clarification of Unit Rates

Unit rates were a key area of focus in the Draft Decision. The Revised Proposal uses the actual 2023-24 unit rates delivered at the start of the 2024-25 financial year. There was an error in the unit rate calculation however, with double counting of some defects leading to the stated 2023-24 unit rate for CTG calculated artificially high. The CTG defects completed was incorrectly counted at 1,421 for 2023-24 at a total cost of \$8M. The correct volume was 547 defects completed for the same \$8M cost. The actual unit rate therefore should have been \$14,987 not \$5,650. This error in unit rate wasn’t discovered prior to the AER presentations and formed the basis of the presentation summary. This unit rate of \$5,650 is being carried forward in this business case with the inclusion of minor re-tension rectification taking the CTG unit rate to \$5,511 in direct 2022-23 \$.

The CTS unit rate of \$27,884 is based on actual cost and volumes delivered for the 2023-24 year and is not subject to the same error. A common rectification for CTS is replacing LV open wire with LVABC because re-tensioning LV open wire is largely ineffective for horizontal triggered CTS defects. The clearance program is generally bespoke, and this is more so with CTS rectification.

### 3.5 Compliance Obligations

Table 1 shows the relevant compliance obligations for this proposal. Defect rectification timelines are documented in the EQL Standard for Conductor Clearance Prioritisation and Remediation. The Prioritisation Matrix is underpinned by EQL’s Network Risk Assessment criteria and prioritisation based on clearance measurements at time of flight. These measurements, along with location are used to determine the priority for remediation.

**Table 1: Asset Function and Strategic Alignment**

Legislative Instruments	Obligations	Relevance to this investment
<b>QLD Electrical Safety Act 2002</b>  <b>QLD Electrical Safety Regulation 2013</b>	EQL has a duty of care, ensuring so far as is reasonably practicable, the health and safety of staff and other parties as follows:  Pursuant to the Electrical Safety Act 2002:	This proposal is a key component in the management of safety for electricity customers. Inadequate clearances to structures or ground are in breach of the

Legislative Instruments	Obligations	Relevance to this investment
<b>(Schedule 4)</b>	(a) as a person in control of a business or undertaking (PCBU), EQL has an obligation to ensure that its undertaking is electrically safe <sup>1</sup> . This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work (b) as an electricity entity, Energex has a duty to ensure that its works: (i) are electrically safe; (c) are operated in a way that is electrically safe <sup>2</sup> : (ii) This duty includes ensuring that CTG and CTS clearance requirements are complied with Pursuant to the QLD Electrical Safety Regulation 2013 which prescribe CTG and CTS clearance requirements	Queensland Electrical Safety Regulation 2013, Schedule 4.
<b>Distribution Authority for Ergon Energy or Energex issued under section 195 of Electricity Act 1994 (Queensland)</b>	Under its Distribution Authority: The distribution entity must plan and develop its supply network in accordance with good electricity industry practice, having regard to the value that end users of electricity place on the quality and reliability of electricity services. The distribution entity will ensure, to the extent reasonably practicable, that it achieves its safety net targets as specified. The distribution entity must use all reasonable endeavours to ensure that it does not exceed in a financial year the Minimum Service Standards (MSS)	Fundamentally, this proposal aims to ensure that clearances are adequate and in accordance with standards. This aligns with good electricity industry practice. proposal.

This program focuses on remediating clearances in accordance with Queensland Electrical Safety Regulation 2013, Schedule 4. Emergency defect notification has become a key part of the program whereby critical clearance breaches due to asset failure can be actioned as soon as possible.

Ergon Energy and Energex also report quarterly to the Queensland Electrical Safety Office on the status of clearance defect remediation.

### 3.6 Identification of Defects

Energy Queensland Limited (EQL) has engaged LiDAR provider Fugro, to survey the entire Queensland distribution network.

ROAMES was developed within Ergon Energy and operated on the timeline shown in Figure 1 below. The Energex network was first flown in 2018 parallel with Ergon Energy's Cycle 6. The naming convention adopted for Energex's first flight program was Cycle 1 then aligned to the Cycle 7 naming convention in 2020. Hence the first two Energex flight cycles will be referred to as Cycle 1 and Cycle 7 from this point forward.

<sup>1</sup> Section 30, *Electrical Safety Act 2002*

<sup>2</sup> Section 29, *Electrical Safety Act 2002*



Since the introduction of LiDAR into the Energex network, the volume of identified defects has increased significantly and the clearance risk matrix within the EQL Standard for Conductor Clearance Prioritisation and Remediation has been adopted to prioritise the volumes based on accessibility, high risk areas and magnitude of the breach.

A LiDAR flight cycle of 3 years across the Ergon Energy and Energex distribution networks allows the highest risks to be prioritised within the flight cycle and the lowest risks that have a treatment year longer than 3 years to be periodically reviewed. Cycle 8 is currently underway with the Energex network being flown first.

**Figure 1: LiDAR Program Delivery Timeline**



The cycles relevant to previous, current and next regulatory control periods (2015-20, 2020-25 and 2025-30) are described below:

- Energex Cycle 1 commenced in Feb 2018 where 26,000 clearance defects were raised. Cycle 7 then commenced in July 2020 where 8,130 defect were raised and the downward trend is expected to continue into Cycle 8. As defects are remediated, a baseline level of defects are expected from each 3-year LiDAR flight cycle. The baseline is expected to be achieved in Cycle 8 and plateau out to the same rate in Cycle 9.
- Cycle 7 raised 8,130 (6,657 CTG + 1,473 CTS) LiDAR clearance defect work orders which represents a 69% reduction in defect volumes from Cycle 1. This reduction is due to the first sweep of Cycle 1 capturing all long standing defects, then Cycle 7 capturing the changes. The works required to remediate the 8,130 defects will span the 2020-2025 and 2025-2030 regulatory periods. Further, 1,311 defects from Cycle 7 have compliance dates that fall into the 2025-2030 regulatory control period while another 2,065 are low priority defects will be monitored and remediated opportunistically with other works. These 2,065 defects are not included in the 2025-2030 regulatory proposal.
- Cycle 8 flights for Energex commenced in 2024 which means that Cycle 8 remediation activities will span the 2020-2025 and 2025-2030 regulatory periods.

Table 2 below shows the defects completed, in progress and forecast over the regulatory control periods.

**Table 2: Defects Remediated by Regulatory Control Period**

<b>Cycle No</b>	<b>No of defects</b>	<b>2020-25</b>	<b>2025-30</b>	<b>2030-35</b>	<b>Monitor and complete with other works</b>
<b>Cycle 1</b>	26,005*	5	0	0	0
<b>Cycle 7</b>	8,130	4,765	1,311	0	2,065
<b>Cycle 8 (forecast)</b>	2,425	224	2,201	0	0
<b>Cycle 9 (forecast)</b>	2,425	0	483	1,942	0

\* From the 26,005 clearance defects identified in Cycle 1, 9,239 defects were assessed as 'No Defect Found.' This was prior to temperature compensation being introduced.

Given the overlapping flight, remediation and regulatory timeframes, the volumes are also forecast to reduce in Cycle 8 as defects are remediated and the benefits from the temperature correction algorithm are realised.

Temperature correction calculates additional sag of the line by comparing the ambient BOM temperature at time of flight to a standard temperature of 35°C. This actively identifies conductors that are calculated to breach legislative clearances on the hottest of days. While not a defect at the time of flight, these temperature corrected defects are treated as genuine defects and actioned accordingly as part of the overall clearance program.

This reduction will primarily be realised in the second half of the 2025-2030 regulatory control period where the volumes are predominantly Level 3-5 defects.

### 3.7 Prioritisation of Defects

Defects are categorised in the EQL Standard for Conductor Clearance Prioritisation and Remediation based on measured LiDAR conductor clearances to structures and ground while considering the severity of the regulatory breach, the location, and public accessibility to the defect. Standard rectification timeframes, defined in the Standard, are then assigned to each defects work orders. These defects levels and timeframes are as follows:

- **Emergency** – These defects are given the highest response priority and rectified as soon as practicable, normally the same day. EQL has processes in place with the LiDAR vendor whereby if during point cloud processing, an Emergency defect is suspected, normal quality assurance activities are bypassed and EQL is notified immediately. EQL then validates via desktop assessment and an 'Urgent Public Hazard' fault call is made to the relevant contact centre to dispatch a field crew for assessment and treatment. Low and high voltage conductors are categorised as an Emergency if they are equal to or below 3.5m. Clearance to structure defects receive an Emergency classification depending on their voltage and structure accessibility.
- **Level 1** - These defects are given a 9-month rectification timeframe. Accessible CTS defects that are less than 75% of the statutory clearance are assigned Level 1. For CTG defects, any defect below the statutory threshold and in a high-risk area such as schools, hospitals and agricultural areas are assigned Level 1. Level 1 defects also have a flag installed as a control measure and a customer safety advice is issued to nearby residents.
- **Level 2** – These defects are CTS defects only and receive an 18-month rectification timeframe. This level captures the remainder of the accessible structure defects and non-accessible defects that are within 66.7% of the statutory clearance requirement. Level 2 defects also have a flag installed as a control measure and a customer safety advice is issued to nearby residents.
- **Level 3** – These defects have a 3-year rectification timeframe. This level captures the remainder of the non-accessible CTS defects and sets a minimum CTG threshold of 5m for road crossing for low voltage conductors and 5.8m for high voltage conductors.
- **Level 4 & 5** – These defects have 4- and 5-year rectification timeframes respectively and capture the remainder of the CTG defects over areas other than roads, non-trafficable land and road clearances up to the statutory clearance.
- **Level 5 Monitor** – These are level 5 defects outside high-risk areas and do not cross a minor or major road. These defects are 200mm (up to 33kV) & 400mm (66kV -132kV) from being legislative compliant at locations other than roads.

## 4 IDENTIFIED NEED

### 4.1 Requirement for compliance

The design of power lines in Energy Queensland is based on AS/NZS 7000:2016. Energex has used LiDAR data, design information, modelling and environmental data to establish which overhead assets have encroached minimum legislative clearance requirements and require rectification as per Tables 3.5 to Table 3.7 of AS/NZS 7000:2016. A dedicated clearance program to manage identified clearance defects is required to address the inherent risk of legislative clearance breaches in a coordinated way.

Clearance defects using LiDAR are tested against Electrical Safety Act 2002 and the Electrical Safety Regulations 2013, where there is no alternative option other than to rectify the clearance breach.

## 5 OPTIONS ANALYSIS

There is a limited range of options to address known clearance issues. Once defects have been identified there is an obligation to remediate them in a timely manner. Only one option is presented using the compliance timeframes for each defect overlaid with the flight schedule. The option presented aligns with the National Electricity Rules as detailed in Appendix 1 and EQL's 'Enable Building Blocks' described in Appendix 3.

### 5.1 Option 1

This option remediates outstanding and forecast level 1-5 defects within compliance timeframes while monitoring and opportunistically rectifying the lowest priority defect 5 defects. The volume to be delivered is smoothed over the 2025-30 regulatory period.

Total cost is \$40.8 million to be delivered over the 5 years.

**Table 3: Cost Overview for Option 1**

Item	Description \$m, direct 2022-23	2025-26	2026-27	2027-28	2028-29	2029-30
CTG	CTG Defects	631	631	631	631	631
	Unit Cost	\$5,511	\$5,511	\$5,511	\$5,511	\$5,511
CTS	Defects	168	168	168	168	168
	Unit Costs	\$27,884	\$27,884	\$27,884	\$27,884	\$27,884
<b>Total</b>	<b>\$ million</b>	<b>8.16</b>	<b>8.16</b>	<b>8.16</b>	<b>8.16</b>	<b>8.16</b>

### 5.2 Cost Summary

**Table 4: Cost summary for 2025-30 period**

Option (\$ direct 2022-23)	2025-26	2026-27	2027-28	2028-29	2029-30	Total 2025-30
Option 1	8,163,000	8,163,000	8,163,000	8,163,000	8,163,000	<b>40,815,000</b>

### 5.3 Risk discussion

Given that the remediation of CTS/CTG defects is a compliance obligation under both the Electrical Safety Act 2002 and the Electrical Safety Regulations 2013, there is no alternative option other than to rectify the clearance breach. Failing to act creates a potential risk to public safety and would place Energex and potentially its officers at risk of breach of this legislation particularly in circumstances where there has been a failure to address a known risk. A breach of the safety

legislation could result in serious consequences (including jail terms for individuals) for the organisation.

While conductors breaching legislative clearances is unacceptable, to manage overall network risk, EQL will continue to review lower risk works to ensure the management of network investments in accordance with the So Far As Is Reasonably Practicable (SFAIRP) principle.

## **6 RECOMMENDATION**

Option 1 is the preferred option to manage legislative compliance from the LiDAR flight program.

A total of 3,155 CTG and 840 CTS defects are forecast to be remediated over the 2025-2030 regulatory control period at a unit rate of \$5,511 and \$27,884 respectively.

Total cost of \$40.8 million in direct 2022-23\$ is required over the 5 years.

## Appendix 1: Alignment with the National Electricity Rules

The table below details the alignment of this proposal with the NER capital expenditure requirements as set out in Clause 6.5.7 of the NER.

**Table 5: Recommended Option's Alignment with the National Electricity Rules**

NER capital expenditure objectives	Rationale
<p><b>A building block proposal must include the total forecast capital expenditure which the DNSP considers is required in order to achieve each of the following (the capital expenditure objectives):</b></p>	
<p><b>6.5.7 (a) (2)</b> <b>comply with all applicable regulatory obligations or requirements associated with the provision of standard control services;</b></p>	<p>Pursuant to the Electrical Safety Act 2002, as a person in control of a business or undertaking (PCBU), Energex has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe.<sup>3</sup> This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work.<sup>4</sup> This proposal addresses Energex' key obligation in relation to ensuring that it works are electrically safe.</p> <p>Clearances of electricity infrastructure to external structures and to ground are key factors in managing electrical safety risks and are compliance obligations related to Queensland Electrical Safety Regulation 2013, Schedule 4.</p>
<p><b>6.5.7 (a) (3)</b> <b>to the extent that there is no applicable regulatory obligation or requirement in relation to:</b></p> <p>(i) <b>the quality, reliability or security of supply of standard control services; or</b></p> <p>(ii) <b>the reliability or security of the distribution system through the supply of standard control services,</b></p> <p><b>to the relevant extent:</b></p> <p>(iii) <b>maintain the quality, reliability and security of supply of standard control services; and</b></p> <p>(iv) <b>maintain the reliability and security of the distribution system through the supply of standard control services</b></p>	<p>While the primary purpose of this program is the delivery of safe outcomes for customers, it does also address reliability issues associated with service failures.</p>
<p><b>6.5.7 (a) (4)</b> <b>maintain the safety of the distribution system through the supply of standard control services.</b></p>	<p>Pursuant to the Electrical Safety Act 2002, as a person in control of a business or undertaking (PCBU), Energex has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe.<sup>5</sup> This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work.<sup>6</sup> This proposal addresses Energex's key obligation in relation to ensuring</p>

<sup>3</sup> Section 29, *Electrical Safety Act 2002*

<sup>4</sup> Section 30 *Electrical Safety Act 2002*

<sup>5</sup> Section 29, *Electrical Safety Act 2002*

<sup>6</sup> Section 30 *Electrical Safety Act 2002*

NER capital expenditure objectives	Rationale
	<p>that it works are electrically safe.</p> <p>Clearances of electricity infrastructure to external structures and to ground are key factors in managing electrical safety risks and are compliance obligations related to Queensland Electrical Safety Regulation 2013, Schedule 4.</p>
NER capital expenditure criteria	Rationale
<p><b>The AER must be satisfied that the forecast capital expenditure reflects each of the following:</b></p>	
<p><b>6.5.7 (c) (1) (i)</b> <b>the efficient costs of achieving the capital expenditure objectives</b></p>	<p>The consistent use of the estimation system is essential in producing an efficient CAPEX forecast by enabling:</p> <ul style="list-style-type: none"> <li>• Option analysis to determine preferred solutions to network constraints</li> <li>• Strategic forecasting of material, labour and contract resources to ensure deliverability</li> <li>• Effective management of project costs throughout the program and project lifecycle, and</li> <li>• Effective performance monitoring to ensure the program of work is being delivered effectively.</li> </ul>
<p><b>6.5.7 (c) (1) (ii)</b> <b>the costs that a prudent operator would require to achieve the capital expenditure objectives</b></p>	<p>Attachment 5.2.10 – Cost Comparison of Energex RIN Unit Costs to the NEM outline the efficiency of the delivery of our work in comparison to other DNSPs.</p>



## Appendix 2: Reconciliation Table

**Table 6: Reconciliation**

Expenditure	DNSP	2025-26	2026-27	2027-28	2028-29	2029-30	2025-30
Expenditure in business case \$m, direct 2022-23 in AER capex model input page	Energex	8.16	8.16	8.16	8.16	8.16	40.82

## Appendix 3: Strategic Alignment

### Alignment to Energy Queensland's Strategic Framework

This investment aligns with the following Energy Queensland 'Enable' Building Blocks:

**Table 7: Alignment to 'Enable' Building Blocks**

'Enable' Building Blocks	How this investment contributes	Impact
<b>1. Safety</b> The safety of our people, customers and communities is our first priority	Clearances of electricity infrastructure to external structures and to ground are key factors in managing electrical safety risks for the public under Queensland Electrical Safety Regulation 2013, Schedule 4.	High
<b>2. Keep the lights on</b> We will design, build and maintain a safe and reliable electricity network	This program audits and outworks solutions to ensure the overhead network is maintained in a safe state.	Medium
<b>3. Financial sustainability</b> We will ensure funds spent are done so prudently and we will grow our revenue streams.	Legislative compliance is the primary driver for the Clearance program.	Low
<b>4. People &amp; Culture</b> Continue to build a capable & productive workforce to ensure we deliver EQL's electric life ambition.	Communicate requirements to rectify and manage defects through deployment of Standards.	Low

### Regulatory and Compliance Obligations

The proposed investment addresses the following regulatory and compliance obligations.

**Table 8: Alignment to Regulatory/Compliance Obligations**

Regulatory/ Compliance Obligation	How this investment contributes to compliance	Implication	Residual Risk Level
<b>Electrical Safety Act 2002</b>	<ul style="list-style-type: none"> <li>This Clearance program directly outworks compliance through adherence to electrical clearance in Electrical Safety Regulation 2013, Schedule 4.</li> </ul>	<ul style="list-style-type: none"> <li>Directly managing compliance with Electrical Safety Regulation 2013 Schedule 4 ensures the requirements of the Electrical Safety Act 2002 are met.</li> </ul>	Low