



The Electricity Supply Industry Planning Council

- The Planning Council is a statutory corporation formed under the *Electricity Act*
- Operates under the control of a Board of 5 members
 - ↳ three members represent industry sectors;
 - ↳ the chair and one member are independent
- The Electricity Act and our Charter set out our functions and obligations
- A small corporation of 9 employees



AER Public Forum

ElectraNet Revenue Proposal

24 July 2007

Electricity Supply Industry Planning Council

Role of the Planning Council

The Planning Council was established to:

- ↳ review the development plans of the private industry participants against the forecast needs of the State;
- ↳ provide independent, expert advice to the Government and the Essential Services Commission of South Australia (ESCOSA); and
- ↳ fulfil a number of South Australian representative roles in the National Electricity Market.

Regulated Electricity Services

The Planning Council encourages efficient outcomes in the regulated network services sector of the industry by:

- ↳ liaising with state and federal regulators to ensure that network regulation is effective for SA;
- ↳ working with network service providers on the efficient, long term development of the power system and of specific network solutions;
- ↳ collaborating with NEMMCO and interstate planning bodies seeking to ensure efficient development of the national network; and
- ↳ understanding the inter-relationship between the competitive and regulated market sectors.

- The Planning Council has reviewed the network augmentations in ElectraNet's submission as a core part of work on regulated network services
- all augmentation to the transmission network proposed within the revenue reset is solely driven by the need to comply with reliability standards in the South Australia Electricity Transmission Code (ETC)
- potential augmentations driven by market benefits (eg interconnector upgrades) are only included as contingent projects

The Planning Council:

- produces the Statewide demand and energy forecasts and reconciles those with connection point forecasts developed by ETSA Utilities
- has applied the forecast loads for year 2011/12 to the current network and identified areas where standards in the ETC are expected to be breached
- cross checked identified reliability constraints with ElectraNet's proposed projects
- undertaken a number of analysis in regions to ascertain whether the proposed projects are likely to represent close to optimal network development

Electricity Transmission Code

- ↳ ETC reliability relates to the **agreed maximum demand** at a connection point
- ↳ The agreed maximum demand is set between ETSA Utilities and ElectraNet based on ETSA's connection point forecasts
- ↳ ESIPC produces statewide forecasts annually and reconciles the 10% probability of exceedance forecast with these connection point forecasts
- ↳ The Planning Council applied a new technique for forecasting summer peak demand for the first time this year


Sales and Demand Forecasts

- ↳ Sales and Demand forecasts
- ↳ Economic assumptions
- ↳ Transmission connection point forecasts

- ✦ Sales have been growing strongly in the last two years
 - ↳ 5.3% growth in 06-07 and 9.1% over past two years
 - ↳ price response weakening; drought & pumping loads; weather effects on sales
- ✦ Lower growth expected in 07-08 – assumes return to average weather
- ✦ Average growth of 1.3% over next decade (base case economic outlook)
 - ↳ 0.9% for residential sector; 1.8% for business sales
 - ↳ forecasts assume carbon price signal from 12-13
- ✦ High case includes major expansion of Olympic Dam mining operation




Customer Sales



System Load Factor

- Following shows system load factor based on 50% PoE outcomes and including wind generation
- Load factor projected to remain stable at around 53 % through the revenue reset period
- Low by industry standards but some improvement if Olympic Dam expansion proceeds

System Load Factor




Summer Peak Demand

- Following focuses on '*Native Demand*' which includes:
 - peak scheduled demand;
 - market non-scheduled generation;
 - wind generation; and
 - notified demand side participation
- Actual 06-07 peak of 2,942 MW on 16 Jan 07 (estimated 52% PoE outcome)
 - higher peak reached in 05-06 (2,953 MW, 20 Jan 06; 30% PoE outcome)
 - however last summer experienced 5 days with demand over 2,800 and record non-work day peak of 2,866 MW on 17 Feb 07



Summer Peak Demand





50% PoE Summer Peak Demand

Base case:

- ↪ forecast 50% PoE level for 07-08 is 3,069 MW
- ↪ compares with 2,942 MW last summer
- ↪ up by 119 MW on backcast 06-07 50% level,
- ↪ forecast average growth of 2.2% over next 10 years
- ↪ forecast for 2012/13 is 3,408 MW

10% PoE Summer Peak Demand

Base case:

- ↪ forecast 10% PoE level for 07-08 is 3,363 MW
- ↪ up by 143 MW on backcast 06-07 10% PoE level,
- ↪ average growth of 2.3% over next ten yrs
- ↪ forecast for 2012/13 is 3,736 MW

Low case:

- ↪ forecast for 2012/13 is 3,534 MW

High Case:

- ↪ growth of 4.9% pa based on strong growth in the resources sector and the SA economy
- ↪ forecast for 2012/13 is 4,441 MW

10% PoE Summer Peak Demand

Base case:

- ↳ forecast 10% PoE level for 07-08 is 3,363 MW
- ↳ up by 143 MW on backcast 06-07 10% PoE level,
- ↳ average growth of 2.3% over next ten yrs
- ↳ forecast for 2012/13 is **3,736 MW**

Low case:

- ↳ forecast for 2012/13 is **3,534 MW**


High Case:

- ↳ growth of 4.9% pa based on strong growth in the resources sector and the SA economy
- ↳ Forecast for 2012/13 is **4,441 MW**


Economic assumptions

- ↳ Economic assumptions are those supplied by NIEIR for the 2007 Statement of Opportunities
- ↳ GSP
 - ↳ Base case assumes robust growth of 2.3% in 07-08 (up from 1.7% in 06-07)
 - ↳ slower growth in 08-09 & 09-10
 - ↳ medium term outlook assumes strong commodity prices and mining activity in Australia
- ↳ Population
 - ↳ Base case assumes average population growth around 0.5% annually
- ↳ Retail prices
 - ↳ Base case - \$15/t carbon price signal phased over 5 years from 12-13


Economic assumptions - GSP



Economic assumptions - Population



Retail price assumptions




Major mining loads

- ↳ Base & low case assumptions are the same
 - ↳ Prominent Hill operating from 2008 and some expansion at Roxby Downs
 - ↳ around 60 MW rise in peak demand and additional 360 GWh energy required
- ↳ High case assumes major expansion of operations at Olympic Dam
 - ↳ incremental increase of around 450 MW in peak and 3,000 GWh energy




Major mining loads



Diversity of connection point loads

- ↳ Load diversity examined over first 3 quarters of 2006-07
- ↳ Individual connection point loads aggregated into regional loads across SA
- ↳ Regional load at time of State-wide peak on 16 Feb 2007 compared with outright maximum for each region
- ↳ Analysis shows that some loads can be considerably greater than at the time of the system peak – average difference was around 10%

Diversity of connection point loads




Comparison with state-wide peak demand forecasts

- ↳ Connection point loads adjusted for 10% diversity factor, losses, generator loads and embedded generation then compared with State-wide 10% PoE demand forecasts
- ↳ High level of consistency in the near term, with connection point forecasts being up to 2% higher towards the end of the reset period
- ↳ Difference likely to reflect economic assumptions, particularly assumption of carbon price signal post 2012-13



Comparison with state-wide peak demand forecasts



Electricity Transmission Code

- Forward planning is required to identify when growth in the forecast maximum demand at a connection point or a group of connection points is unable to be delivered with the required reliability
- The NEM Rules require joint planning with ETSA Utilities and the application of the Regulatory Test to find the lowest total cost solution
- The ETC requires that ElectraNet must use its best endeavours to ensure that the capacity of the network meets the required reliability standard within 12 months.

ESIPC Network analysis

- ↳ The Planning Council undertook a series of loadflow analysis for 2011/12 to identify network limitations on both a system normal and n-1 basis
- ↳ Took a network model updated to include projects to be completed before commencement of reset period
- ↳ Applied connection point forecast loads for 2011/12
- ↳ Added estimated losses
- ↳ Estimated additional reactive power requirements

ESIPC Network analysis

- ↳ Balanced the system with sources of reactive and active power
- ↳ Active power was supplied by additional conventional generators located to minimise cost to the shared transmission network
 - ↳ APR and ElectraNet's Annual review provide information on options
 - ↳ market benefits case would have to be made to upgrade network to remove constraints on generator output
- ↳ Reactive power sources assumed as SVC's and capacity utilised checked against ElectraNet project proposals



Supply balance for 2011/12

Active Power (MW)

	2006/07	2011/12	Increase
Total Load	3492	4212	720
Losses	125	125	
Generation + Imports	3617	4337	720

Reactive Power (MVA_r)

	2006/07	2011/12	Increase
DEMAND (MVA_r)			
Total Load	1175	1408	470
Losses	1455	1692	
SUPPLY (MVA_r)			
Generators + SVC	1180	1640	
Capacitors	705	715	
Transmission Lines	785	786	
Imports	-40	-39	
Total MVA_r Requirement	2630	3100	470

Load flow study – System normal analysis

- ↳ Loaded the base case for 2011/12 into PSS/E – the industry standard loadflow analysis program
- ↳ Identified all cases where:
 - ↳ a transmission line was running over its rated capacity
 - ↳ a transformer was running over its rated capacity; or
 - ↳ a sub-station bus was running outside voltage limits

Load flow study – System normal analysis

Constrained Elements Identified

Bus Voltage ($1.05\text{pu} < V < 0.95\text{pu}$)				Transmission Line Over Load ($> 100\%$)					Transformer Over Load ($> 100\%$)					
Bus	kV	Vpu		From	To	kV	MVA	%	HV Bus	LV Bus	kV	Cct ID	MVA	%
56248 (WATL/2)	33	0.908		54025 (WHYL)	54028 (MIDL)	132	59	159	54250 (WATL)	56248 (WATL/2)	132/33	1	13	139
56249 (WATL/3)	33	0.907		54028 (MIDL)	54030 (YADN)	132	59	125	54250 (WATL)	56249 (WATL/3)	132/33	2	13	137
56351 (HUMM/2)	33	0.935		54030 (YADN)	54035 (PLIN)	132	33	140	54364 (KADE)	56364 (KADE)	132/33	1	28	107
56352 (HUMM/3)	33	0.935		54253 (TEMPLR/2)	54254 (DORN)	132	46	104						



Mid-North




Eyre Peninsula
&
Mid-North



Mid-North

Load flow study – n-1 Analysis



Load flow study – n-1 Analysis

Transmission Lines						
From	To	kV	Cct ID	MVA	% Load	No of times the line got O/L
53005 (DAVN)	53144 (BRNK)	275		171	131	3
53770 (CGDN)	53700 (MVE)	275		463	109	1
54015 (CULT/1)	54025 (WHYL)	132		137	106	1
54010 (PLAY)	54016 (CULT/2)	132	2	85	136	1
54010 (PLAY)	54025 (WHYL)	132	1	91	114	1
54016 (CULT/2)	54025 (WHYL)	132	2	85	136	1
54107 (ODMN)	54106 (ODMN/1)	132	2 / 1	138	161	1
54155 (ROBT)	54170 (NWB)	132		111	168	1
54155 (ROBT)	54162 (MWP3)	132		144	123	1
54162 (MWP3)	54164 (MWP2)	132		144	119	1
54164 (MWP2)	54166 (MWP1)	132		144	116	1
54166 (MWP1)	54170 (NWB)	132		144	114	1
54170 (NWB)	54205 (MNSH)	132		111	129	1
54350 (HUMM)	54364 (KADE)	132		33	102	1
54253 (TEMPLR/2)	54254 (DORN)	132		46	237	1
54252 (TEMP)	54254 (DORN)	132		46	173	4
54842 (MOBL)	54834 (MANN)	132		69	116	3
54834 (MANN)	54832 (MAP2)	132		47	106	3
54822 (MILT)	54826 (ANGC)	132		73	121	5
54826 (ANGC)	54830 (MAP3)	132		52	132	4
54860 (TAIL)	54840 (MOBL)	132		144	118	2
54914 (MGAM)	54916 (BLAN)	132		107	101	1
54350 ((HUMM)	54364 (KADE)	132		32	100	1

Load flow study – n-1 Analysis


Transformers						
HV Bus	LV Bus	kV	Cct ID	MVA	% Load	No of times the t/f got O/L
53015 (CULT)	54015 (CULT/1)	275/132		160	101	1
53275 (PARA)	54275 (PARA)	275/132	8	160	109	1
53770 (CGDN)	54770 (CGDN)	275/132		160	102	1
53107 (ODMW)	54107 (ODMW)	275/132	1 / 2	140	281	1
53155 (ROBT)	54155 (ROBT)	275/132	1 / 2	160	116	1
53275 (PARA)	55275 (PARA)	275/66	1 / 2	120	174	1
53300 (PGW)	55300 (PGW)	275/66		180	114	1
53550 (MAGL)	55550 (MAGL)	275/66	1 / 2	225	142	1
53640 (HAVL)	55640 (HAVL)	275/66	2 / 3 / 4	180	125	1
53700 (MVE)	55700 (MVE)	275/66	3 / 1 / 4	225	169	1
54010 (PLAY)	56010 (PLAY)	132/33	1 / 2	26.3	139	1
54106 (ODMN/1)	57106 (ODMN)	132/11	1/2/3/4/5	36/33	161	1
54107 (ODMW)	57107 (ODMW)	132/11	4 / 6	36	281	1
54160 (MWP4)	58160 (MWP4)	132/3.3	2	6	106	1
54162 (MWP3)	58162 (MWP3)	132/3.3	2	5	134	1
54350 (HUMM)	56352 (HUMM/3)	132/33	1 / 2	12.6	134	1
54356 (ARDW)	56356 (ARDW)	132/33	1 / 2	13.4	134	1
54780 (MTBR)	55780 (MTBR)	132/66	1 / 2	71	149	1
54830 (MAP3)	58830 (MAP3)	132/3.3	1 / 2	6	161	1
54832 (MAP2)	58832 (MAP2)	132/3.3	1 / 2	6	161	1
54834 (MANN)	56834 (MANN)	132/33	1 / 2	20	106	1
54836 (MAP1)	58836 (MAP1)	132/3.3	1 / 2	8	125	1
54880 (KEIT)	56880 (KEIT)	132/33	1	29	104	1
54908 (KINC)	56908 (KINC)	132/33	1 / 2	27/29	112	1
54914 (MGAM)	59914 (MGAM/D1)	132/33	1	30	136	1




Bus Voltage				
Bus	kV	Vpu	No of times it went out-of-limit	
			Vpu<0.95	Vpu>1.05
53050 (CANW)	275	1.054		1
54016 (CULT/2)	132	0.949	1	
54025 (WHYL)	132	0.934	1	
54028 (MIDL)	132	0.904	1	
54029 (IRON DUK)	132	0.897	1	
54030 (YADN)	132	0.922	1	
54032 (MT MILLR)	132	0.922	2	
54070 (WUDN)	132	0.904	1	
54106 (ODMN/1)	132	0.927	1	
54107 (ODMW)	132	0.934	1	
54135 (BUNG)	132	0.929	1	
54140 (BARO)	132	0.924	1	
54142 (PTRP)	132	0.925	1	
54150 (MINT)	132	1.059		1
54252 (TEMP)	132	0.926	6	
54253 (TEMPLR/2)	132	0.876	3	
54254 (DORN)	132	0.938	5	
54258 (ROSW)	132	0.843	2	
54275 (PARA)	132	0.904	1	
54350 (HUMM)	132	0.898	2	
54356 (ARDW)	132	0.947	6	
54358 (DALR)	132	0.935	11	
54360 (WATTLE)	132	0.935	12	
54364 (KADE)	132	0.947	6	
54700 (CGDN)	132	0.864	1	
54780 (MTBR)	132	0.861	2	
54822 (MILT)	132	0.909	2	
54824 (MILB)	132	0.909	2	
54826 (ANGC)	132	0.942	3	
54834 (MANN)	132	0.946	2	
54836 (MAP1)	132	0.946	1	
54840 (MOBL)	132	0.941	2	
54842 (MHP1)	132	0.940	2	
54844 (MHP2)	132	0.930	2	
54848 (KANM)	132	0.893	2	
54850 (MHP3)	132	0.893	2	
54914 (MGAM)	132	0.865	1	
54916 (BLAN)	132	0.880	1	
54920 (SNUJG)	132	0.949	1	
54925 (MAYURRA)	132	0.949	1	
58830 (MAP3)	3.3	0.922	4	
58832 (MAP2)	3.3	0.916	4	
58836 (MAP1)	3.3	0.941	4	

Reconciliation with reset projects

- The projects in ElectraNet's submission have been reconciled with ESIPC analysis (summarised in the following)
- Feedback between ESIPC and ElectraNet over the past 6 months have refined the actual projects proposed
- Not all identified constraints need to be remedied. In various cases an inability to carry loadflow following a contingency
 - may be acceptable because of the reliability standard at the point
 - may be a matter for the market benefits test
 - may be the responsibility of others not ElectraNet and the shared network





- ↳ Project 6 - CBD
 - ↳ Project is driven by new reliability standard
 - ↳ CBD is currently supported by transmission and sub-transmission not modelled in this work
- ↳ Project 7 - Southern suburbs
 - ↳ relieves Panorama sub-transmission overload (not modelled) in 66kV system supplying Southern suburbs
 - ↳ project leverages off new City west sub-station
- ↳ Project 19 - Coonalpyn West
 - ↳ relieves 33kV sub-transmission system overload
- ↳ Project 24 - RTU replacement
- ↳ Project 25 - weather stations

Contingent projects

- ↳ Planning Council supports the approach ElectraNet have taken with contingent projects
- ↳ Range of outcomes in probabilistic assessment is tighter and accountability better as a result
- ↳ Few potentially large contingent projects

Contingent projects

- ↳ Contingent Project 1 – Eyre peninsula
 - ↳ Major network upgrade contingent on major new loads on Eyre Peninsula – existing system is heavily loaded
- ↳ Contingent Project 2 – Riverland
 - ↳ support available from Murraylink is essential to Riverland reliability – complex question given constraints on Murraylink
- ↳ Contingent Project 17 – Northern transmission
 - ↳ contingent on BHP-Billiton and regulatory decisions
- ↳ Contingent Project 16 – Interconnector Upgrade
 - ↳ not justifiable at this time but market conditions could change quickly

Limitations of ESIPC analysis

- ↳ The Planning Council's analysis has been limited and focussed on network development
- ↳ Have not examined a number of important issues including:
 - ↳ estimated project costs
 - ↳ asset condition and refurbishment program and costs;
 - ↳ optimisation of contingent projects; or
 - ↳ other spending