

ElectraNet's TNSP Economic Benchmarking Data Templates

Estimate Information

5. Operational data worksheet

Variable_Code

Regulatory year

Variable

Table 5.1 Energy delivery

Energy Grouping by Downstream Connection type

Units

2006	2007	2008	2009	2010	2011	2012	2013
------	------	------	------	------	------	------	------

TOPED0101
TOPED0102
TOPED0103
TOPED01

To Other connected transmission networks

GWh

2,530	882	-24	187	580	519	1,071	1,356
-------	-----	-----	-----	-----	-----	-------	-------

To Distribution networks

GWh

11,889	11,689	11,781	11,791	11,974	11,705	11,276	11,135
--------	--------	--------	--------	--------	--------	--------	--------

To Directly connected end-users (please specify voltages)

GWh

1,182	1,418	1,324	1,536	1,292	1,657	1,246	1,293
-------	-------	-------	-------	-------	-------	-------	-------

Total energy transported

GWh

15,101	13,990	13,083	13,514	13,847	13,882	14,063	14,284
--------	--------	--------	--------	--------	--------	--------	--------

Table 5.2 Connection point numbers

Number of entry points at each transmission voltage level

TOPCP0101
TOPCP0102
TOPCP0103

275kV

2	2	2	8	10	10	10	10
---	---	---	---	----	----	----	----

132 kV

9	9	10	11	11	11	11	11
---	---	----	----	----	----	----	----

66 kV

3	3	3	3	3	3	3	3
---	---	---	---	---	---	---	---

Number of exit points at each transmission voltage level

TOPCP0201
TOPCP0202
TOPCP0203

275kV

11	11	11	11	11	12	14	14
----	----	----	----	----	----	----	----

132 kV

56	56	57	57	58	59	60	61
----	----	----	----	----	----	----	----

66 kV

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

Table 5.3 System demand

Table 5.3.1 Annual system maximum demand characteristics – MW measure

TOPSD0101

Transmission System coincident maximum demand

MW

2717	2707	2940	3178	3055	3169	2808	2914
------	------	------	------	------	------	------	------

TOPSD0102

Transmission System coincident weather adjusted maximum demand 10% POE

MW

--	--	--	--	--	--	--	--

TOPSD0103

Transmission System coincident weather adjusted maximum demand 50% POE

MW

--	--	--	--	--	--	--	--

TOPSD0104

Transmission System non-coincident summated maximum demand

MW

3648	3712	4001	4101	4077	4204	4042	4136
------	------	------	------	------	------	------	------

TOPSD0105

Transmission System non-coincident weather adjusted summated maximum demand 10% POE

MW

--	--	--	--	--	--	--	--

TOPSD0106

Transmission System non-coincident weather adjusted summated maximum demand 50% POE

MW

--	--	--	--	--	--	--	--

Table 5.3.2 Annual system maximum demand characteristics – MVA measure

TOPSD0201

Transmission System coincident maximum demand

MVA

2839	3097	3123	3346	3272	3282	2915	3235
------	------	------	------	------	------	------	------

TOPSD0202

Transmission System coincident weather adjusted maximum demand 10% POE

MVA

--	--	--	--	--	--	--	--

TOPSD0203

Transmission System coincident weather adjusted maximum demand 50% POE

MVA

--	--	--	--	--	--	--	--

TOPSD0204

Transmission System non-coincident summated maximum demand

MVA

3978	3976	4223	4265	4285	4376	4229	4403
------	------	------	------	------	------	------	------

TOPSD0205

Transmission System non-coincident weather adjusted summated maximum demand 10% POE

MVA

--	--	--	--	--	--	--	--

TOPSD0206

Transmission System non-coincident weather adjusted summated maximum demand 50% POE

MVA

--	--	--	--	--	--	--	--

Table 5.3.3 Power factor

Power factor conversion between MVA and MW

TOPSD0301

Average overall network power factor conversion between MVA and MW

Factor

0.9920 leading	0.9891 leading	0.9766 leading	0.9797 leading	0.9821 leading	0.9787 leading	0.9839 leading	0.9785 leading
----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------

TOPSD0302

Average power factor conversion for 500 kV lines

Factor

NA	NA	NA	NA	NA	NA	NA	NA
----	----	----	----	----	----	----	----

TOPSD0303

Average power factor conversion for 330 kV lines

Factor

NA	NA	NA	NA	NA	NA	NA	NA
----	----	----	----	----	----	----	----

TOPSD0304

Average power factor conversion for 275 kV lines

Factor

0.9850 lagging	0.9916 leading	0.9892 leading	0.9897 leading	0.9923 leading	0.9910 leading	0.9999 lagging	0.9886 leading
----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------

TOPSD0305

Average power factor conversion for 230 kV lines

Factor

NA	NA	NA	NA	NA	NA	NA	NA
----	----	----	----	----	----	----	----

TOPSD0306

Average power factor conversion for 132 kV lines

Factor

0.9762 leading	0.9836 leading	0.9627 leading	0.9718 leading	0.9749 leading	0.9675 leading	0.9710 leading	0.9680 leading
----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------

TOPSD0307

Average power factor conversion for 66 kV lines

Factor

0.9906 lagging	0.9693 lagging	0.9785 leading	0.9884 leading	0.9834 leading	0.9939 lagging	0.9872 leading	0.9866 lagging
----------------	----------------	----------------	----------------	----------------	----------------	----------------	----------------

TOPSD0308

Average power factor conversion for 33 kV lines

Factor

NA	NA	NA	NA	NA	NA	NA	NA
----	----	----	----	----	----	----	----

TOPSD0309

(Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code)

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

6. Physical assets worksheet

Regulatory year										
Variable_Code	Variable	Unit	2006	2007	2008	2009	2010	2011	2012	2013
Table 6.1 Transmission System Capacities Variables										
Table 6.1.1 Overhead network length of circuit at each voltage										
TPA0101	500 kV	km	0	0	0	0	0	0	0	0
TPA0102	330 kV	km	0	0	0	0	0	0	0	0
TPA0103	275 kV	km	2608	2608	2608	2608	2608	2608	2611	2611
TPA0104	220 kV	km	0	0	0	0	0	0	0	0
TPA0105	132 kV	km	2969	2886	2886	2871	2869	2872	2872	2873
TPA0106	66 kV	km	14.75	15.88	15.88	15.88	15.88	15.88	15.88	16.16
TPA0107	33 kV	km	0	0	0	0	0	0	0	0
TPA0108	[Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code]									
TPA01	Total overhead circuit kilometres	km	5592	5510	5510	5495	5493	5496	5499	5500
Table 6.1.2 Underground cable circuit length at each voltage										
TPA0201	500 kV	km	0	0	0	0	0	0	0	0
TPA0202	330 kV	km	0	0	0	0	0	0	0	0
TPA0203	275 kV	km	7.87	7.87	7.87	7.87	7.87	7.87	26.27	26.27
TPA0204	220 kV	km	0	0	0	0	0	0	0	0
TPA0205	132 kV	km	0	0	0	0	0	0	0	0
TPA0206	66 kV	km	0.919	0.919	0.919	0.919	0.919	0.919	0.919	0.919
TPA0207	33 kV	km	0	0	0	0	0	0	0	0
TPA0208	[Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code]									
TPA02	Total underground circuit kilometres	km	8.789	8.789	8.789	8.789	8.789	8.789	27.189	27.189
Table 6.1.3 Estimated overhead network weighted average MVA capacity by voltage class										
TPA0301	500 kV	SUMMER*	0	0	0	0	0	0	0	0
TPA0302	330 kV	MVA	0	0	0	0	0	0	0	0
TPA0303	275 kV	MVA	550.6	565.8	565.8	566.4	566.4	566.4	566.4	566.4
TPA0304	220 kV	MVA	0	0	0	0	0	0	0	0
TPA0305	132 kV	MVA	108.2	109.8	111.9	114.1	114.1	114.1	114.1	114.1
TPA0306	66 kV	MVA	105.9	105.9	105.9	105.9	105.9	105.9	105.9	105.9
TPA0307	33 kV	MVA	0	0	0	0	0	0	0	0
TPA0308	[Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code]									
Table 6.1.4 Estimated underground network weighted average MVA capacity by voltage class										
TPA0401	500 kV	MVA	0	0	0	0	0	0	0	0
TPA0402	330 kV	MVA	0	0	0	0	0	0	0	0
TPA0403	275 kV	MVA	450.0	450.0	450.0	450.0	450.0	450.0	597.0	597.0
TPA0404	220 kV	MVA	0	0	0	0	0	0	0	0
TPA0405	132 kV	MVA	0	0	0	0	0	0	0	0
TPA0406	66 kV	MVA	0	0	0	0	0	0	0	0
TPA0407	33 kV	MVA	0	0	0	0	0	0	0	0
TPA0408	[Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code]									
Table 6.1.5 Installed transmission system transformer capacity										
TPA0501	Transmission substations (eg 500 kV to 330 kV)	MVA	3300	3080	3240	3240	3240	3240	3400	3440
TPA0502	Terminal points to DNSP systems	MVA	5297	5230	5476	5798	5863	6263	6888	7363
TPA0503	Transformer capacity for directly connected end-users owned by the TNSP	MVA	601.0	746.0	871.0	871.0	871.0	871.0	891.0	891.0
TPA0504	Transformer capacity for directly connected end-users owned by the end-user	MVA	4934	4934	5039	5182	5182	5542	5542	5542
TPA0505	Interconnector capacity	MVA	680	680	680	680	680	680	680	680
TPA0506	[Add rows as required for other voltages here. For each additional row, specify the voltage level and add a variable code]									
Table 6.1.6 Cold spare capacity										
TPA06	Cold spare capacity included in table 6.1.5	MVA	268.6	40.0	222.6	492.6	462.6	462.6	462.6	717.6

FOR IDENTIFICATION ONLY
PWC
ADELAIDE

7. Quality of services worksheet

Variable_Code	Regulatory year Variable	Unit	2006	2007	2008	2009	2010	2011	2012	2013
Table 7.1 Service Component										
Table 7.1.1 Service Parameter 1 – Average Circuit outage rate										
TQS0101	Lines outage rate - fault	per cent	41.1	26.2	26.9	20.4	41.7	25.7	43.6	29.7
TQS0102	Number of Lines fault outages	number	44	28	29	22	45	28	48	33
TQS0103	Number of defined Lines	number	107	107	108	108	108	109	110	111
TQS0104	Transformers outage rate - fault	per cent	20	14.5	15.1	11.6	17.2	8.6	11.2	11.1
TQS0105	Number of Transformer fault outages	number	25	18	19	15	23	12	16	16
TQS0106	Number of defined Transformers	number	125	124	126	129	134	139	143	144
TQS0107	Reactive plant outage rate - fault	per cent	50	23.1	42.3	30.8	25.9	46.2	28.6	30.3
TQS0108	Number of Reactive plant fault outages	number	13	6	11	8	7	12	8	10
TQS0109	Number of defined Reactive plant	number	26	26	26	26	27	26	28	33
TQS0110	Lines outage rate – forced outage	per cent	14	14	15.7	13	25.9	20.2	9.1	14.4
TQS0111	Number of Lines forced outages	number	15	15	17	14	28	22	10	16
TQS0112	Transformer outage rate – forced outage	per cent	8	5.6	4	7.8	9.7	2.2	8.4	0.7
TQS0113	Number of Transformers forced outages	number	10	7	5	10	13	3	12	1
TQS0114	Reactive plant outage rate – forced outage	per cent	11.5	26.9	88.5	7.7	114.8	23.1	10.7	36.4
TQS0115	Number of Reactive plant forced outages	number	3	7	23	2	31	6	3	12
Table 7.1.2 Service Parameter 2 – Loss of supply event frequency – number in ranges specified										
TQS0116	Number of events greater than (0.2 for 2003-08 and 0.05 for 2008-13) system minutes per annum	number	4	1	4	4	12	7	7	5
TQS0117	Number of events greater than (1.0 for 2003-08 and 0.2 for 2008-13) system minutes per annum	number	0	0	1	2	6	1	5	4
Table 7.1.3 Service Parameter 3 – Average outage duration										
TQS0118	Average outage duration	minutes	88.46	269.94	200.2	161.27	126.85	242.28	124.76	154.17
Table 7.1.4 System Parameter 4 – Proper operation of equipment – number of failure events										
TQS0119	Failure of protection system	number	38	26	24	24	49	24	37	24
TQS0120	Material failure of Supervisory Control and Data Acquisition (SCADA) system	number	4	2	13	2	5	5	2	2
TQS0121	Incorrect operational isolation of primary or secondary equipment	number	0	3	7	4	7	4	2	2
Table 7.2 - Market Impact Component										
Market Impact Parameter										
TQS02	Market Impact Parameter	Number of dispatch intervals	28385	10935	5548	3719	2259	1772	5325	2927
7.3 System losses										
TQS03	System losses	per cent	2.21%	1.99%	1.73%	2.07%	2.19%	2.15%	2.16%	2.29%

8. Operating environment factors worksheets

Variable_Code	Regulatory year Variable	Unit	2006	2007	2008	2009	2010	2011	2012	2013
8.1 Terrain factors										
TEF01	Total number of vegetation maintenance spans	Number of spans								1494
TEF0101	Average vegetation maintenance span cycle	Years	1.367	1.367	1.367	1.367	1.367	1.367	1.367	1.367
TEF0103	Average number of trees per vegetation maintenance span	Trees								12
TEF0104	Average number of defects per vegetation maintenance span	Defects								7
TEF0105	Tropical proportion	Number of spans								0
TEF0106	Standard vehicle access	km								4196
TEF0107	Altitude	km								10
TEF0108	Bushfire risk	Number of spans								10918
8.2 Network characteristics										
TEF02	Route line length	km	4643	4555	4555	4540	4538	4542	4543	4543
TEF0201	Variability of dispatch	per cent	6	6	8	14	17	21	27	27
TEF0202	Concentrated load distance	km	0	0	0	0	0	0	0	0
TEF0204	Total number of spans	number	13638	13431	13428	13349	13342	13362	13367	13370

TEF03	8.3 Weather stations
TEF03001	ADELAIDE (BRIGHTON)
TEF03002	ADELAIDE (CLARENCE GARDENS BOWLING CLUB)
TEF03003	ADELAIDE (DRY CREEK SALTWORKS)
TEF03004	ADELAIDE (GLEN OSMOND)
TEF03005	ADELAIDE (GORGE WEIR)
TEF03006	ADELAIDE (HOPE VALLEY RESERVOIR)
TEF03007	ADELAIDE (KENT TOWN ALERT)
TEF03008	ADELAIDE (KENT TOWN)
TEF03009	ADELAIDE (KESWICK)
TEF03010	ADELAIDE (MAGILL)
TEF03011	ADELAIDE (MORPHETT VALE)
TEF03012	ADELAIDE (MORPHETTVILLE RACECOURSE)
TEF03013	ADELAIDE (POORAKA)
TEF03014	ADELAIDE (SALISBURY BOWLING CLUB)
TEF03015	ADELAIDE (SEATON)
TEF03016	ADELAIDE (SOMERTON PARK)
TEF03017	ADELAIDE (TEA TREE GULLY COUNCIL)
TEF03018	ADELAIDE (TORRENS ISLAND)
TEF03019	ADELAIDE AIRPORT
TEF03020	ADELAIDE AIRPORT (ANEMOMETER NORTHEAST)
TEF03021	ADELAIDE AIRPORT (ANEMOMETER NORTHWEST)
TEF03022	ADELAIDE AIRPORT (ANEMOMETER SOUTH WEST)
TEF03023	ADELAIDE AIRPORT ALERT
TEF03024	AGERY
TEF03025	ALAWOONA
TEF03026	ALAWOONA (SCHELLS WELL)
TEF03027	ALDGATE
TEF03028	AMATA AIRSTRIP
TEF03029	AMERICAN RIVER
TEF03030	AMERICAN RIVER (REDBANKS)
TEF03031	ANDAMOOKA
TEF03032	ANGASTON
TEF03033	ANNA CREEK
TEF03034	APOINGA (WILIVERE)
TEF03035	APPILA
TEF03036	ARDROSSAN
TEF03037	ARDROSSAN (MULARA)
TEF03038	ARDROSSAN (VITANA)
TEF03039	ARDROSSAN (WINULTA)
TEF03040	ARKAROOA
TEF03041	ARNO BAY
TEF03042	ARTHURTON (LOWANDALE)
TEF03043	ASHTON
TEF03044	ASHTON CO-OP
TEF03045	ATHELSTONE (BLACK HILL)
TEF03046	AUBURN
TEF03047	AUSTRALIA PLAINS
TEF03048	AVENUE (DOWNER)
TEF03049	BALAKLAVA
TEF03050	BALAKLAVA (DONALEEN)
TEF03051	BALAKLAVA (WANAPPE)
TEF03052	BALHANNAH (KILLARA PARK)
TEF03053	BALHANNAH CFS BASESTATION
TEF03054	BARMERA
TEF03055	BAROSSA VALLEY (DUCKPONDS CREEK)
TEF03056	BEACHPORT
TEF03057	BEAUMONT
TEF03058	BELAIR
TEF03059	BELAIR (ST JOHNS)
TEF03060	BELAIR (STATE FLORA NURSERY)
TEF03061	BELLEVUE HEIGHTS
TEF03062	BELTANA ROADHOUSE
TEF03063	BELTANA STATION
TEF03064	BELTON (SHADOW VALE)
TEF03065	BERRI
TEF03066	BIMBOWRIE
TEF03067	BIRDWOOD
TEF03068	BIRDWOOD

Post code	Suburb	Materiality
23001	5048 BRIGHTON	Y
23093	5039 CLARENCE GARDENS	Y
23079	5110 DRY CREEK	Y
23005	5065 LINDEN PARK	Y
23909	5134 MONTACUTE	Y
23096	5090 HOPE VALLEY	Y
23056	5067 KENT TOWN	Y
23090	5067 KENT TOWN	Y
23115	5035 KESWICK	Y
23132	5072 MAGILL	Y
23732	5162 MORPHETT VALE	Y
23098	5043 MORPHETTVILLE	Y
23026	5095 POORAKA	Y
23023	5108 SALISBURY	Y
23024	5023 SEATON	Y
23121	5044 SOMERTON PARK	Y
23748	5097 ST AGNES	Y
23018	5015 TORRENS ISLAND	Y
23034	5950 ADELAIDE AIRPORT	Y
23123	5950 ADELAIDE AIRPORT	Y
23124	5950 ADELAIDE AIRPORT	Y
23109	5950 ADELAIDE AIRPORT	Y
23055	5950 ADELAIDE AIRPORT	Y
22057	5558 AGERY	Y
25000	5311 ALAWOONA	N
25018	5311 ALAWOONA	N
23817	5154 ALDGATE	Y
16008	NIL	N
22800	5221 AMERICAN RIVER	N
22831	5222 NEPEAN BAY	N
16065	5722 ANDAMOOKA	Y
23300	5353 ANGASTON	Y
17004	5734 ANNA CREEK	N
21121	5381 APOINGA	Y
19001	5481 APPILA	Y
22000	5571 ARDROSSAN	Y
22032	5571 SANDILANDS	Y
22033	5571 ARDROSSAN	Y
22021	5571 WINULTA	Y
17099	5710 ARKAROOA VILLAGE	N
18001	5603 ARNO BAY	Y
22039	5573 MAITLAND	Y
23867	5137 ASHTON	Y
23803	5137 ASHTON	Y
23896	5076 ATHELSTONE	Y
21001	5451 AUBURN	Y
24501	5374 AUSTRALIA PLAINS	Y
26078	5271 AVENUE RANGE	Y
21002	5461 BALAKLAVA	Y
23128	5460 SALTER SPRINGS	Y
21104	5453 STOW	Y
23787	5242 BALHANNAH	Y
23918	5242 BALHANNAH	Y
24001	5345 BARMERA	Y
23372	5353 STOCKWELL	Y
26000	5280 BEACHPORT	Y
23114	5066 BEAUMONT	Y
23846	5152 BELAIR	Y
23890	5052 BELAIR	Y
23704	5152 BELAIR	Y
23916	5050 BELLEVUE HEIGHTS	Y
17119	5731 BELTANA STATION	Y
17012	5710 BELTANA STATION	Y
19004	5432 BELTON	N
24025	5343 BERRI	Y
20000	5440 BIMBOWRIE	N
23705	5233 FORRESTON	Y
23900	5233 BIRDWOOD	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03069 BIRDWOOD (MCVITTIES HILL)
TEF03070 BISCUIT FLAT (WOOLMI)
TEF03071 BLACK HILL
TEF03072 BLACKWOOD (WITTUNGA)
TEF03073 BLANCHETOWN (WYN-MOOR)
TEF03074 BLANCHETOWN LOCK 1
TEF03075 BLINMAN
TEF03076 BLINMAN (ANGORICHINA)
TEF03077 BLINMAN (MOOLOOLOO)
TEF03078 BLINMAN (NARRINA)
TEF03079 BLINMAN (WIRREALPA)
TEF03080 BLYTH
TEF03081 BOLIVAR TREATMENT WORKS
TEF03082 BON BON
TEF03083 BOOBOROWIE
TEF03084 BOOL LAGOON (LOCKSLEY FARM)
TEF03085 BOOLCOOMATTA
TEF03086 BOOLEROO CENTRE
TEF03087 BOOLEROO CENTRE (WILLOWIE)
TEF03088 BOOLEROO WHIM (CALLUM BRAE)
TEF03089 BORDERTOWN (BEEAMMA SECTION 95)
TEF03090 BORDERTOWN (INGLEWOOD)
TEF03091 BORDERTOWN (YACCA VALE)
TEF03092 BORDERTOWN INDUSTRIAL ESTATE
TEF03093 BOWER
TEF03094 BOWHILL
TEF03095 BOWILLIA
TEF03096 BOWMANS (PIGELDEE)
TEF03097 BRAEMAR
TEF03098 BRIDGEWATER
TEF03099 BRINKWORTH
TEF03100 BRINKWORTH (ANAMA PARK)
TEF03101 BRINKWORTH (BUNGAREE)
TEF03102 BROUGHAM'S GATE HOUSE (QUINYAMBIE)
TEF03103 BROWN HILL CREEK (SCOTCH COLLEGE)
TEF03104 BRUCE
TEF03105 BUCKLAND PARK (ADELAIDE-SI-RADAR)
TEF03106 BUCKLEBOO (HI-VIEW)
TEF03107 BUCKLEBOO (KARINYA)
TEF03108 BULGUNNIA
TEF03109 BURNSIDE
TEF03110 BURRA (BILLABONG)
TEF03111 BURRA (LEIGHTON)
TEF03112 BURRA (POONUNDA)
TEF03113 BURRA (WORLDS END)
TEF03114 BURRA COMMUNITY SCHOOL
TEF03115 BUTE
TEF03116 BUTLER (MOODY VALE)
TEF03117 BUTLER TANKS (NORTH PARNSDA)
TEF03118 CADNEY PARK (ARCKARINGA STATION)
TEF03119 CALIPH
TEF03120 CALLINGTON
TEF03121 CALLINGTON HILL
TEF03122 CALTOWIE
TEF03123 CAMBRAI (KONGOLIA)
TEF03124 CAMERON CORNER (LINDON)
TEF03125 CAPE BORDA
TEF03126 CAPE CASSINI WILDERNESS RETREAT
TEF03127 CAPE JAFFA (THE LIMESTONE)
TEF03128 CAPE WILLOUGHBY
TEF03129 CARRIETON
TEF03130 CARRIETON (EURELIA)
TEF03131 CARRIETON (GLENROY ESTATE)
TEF03132 CASTAMBUL (SIXTH CREEK)
TEF03133 CEDUNA (GOODE)
TEF03134 CEDUNA (MALTEE)
TEF03135 CEDUNA (NUNONG)
TEF03136 CEDUNA (THEVENARD NTC AWS)
TEF03137 CEDUNA (UWORRA)
TEF03138 CEDUNA AMO
TEF03139 CEDUNA OBSERVATORY
TEF03140 CHARLESTON
TEF03141 CHERRY GARDENS
TEF03142 CLARE
TEF03143 CLARE (CALCANNIA)
TEF03144 CLARE (HILL RIVER)
TEF03145 CLARE (NEAGLES ROCK)
TEF03146 CLARE HIGH SCHOOL
TEF03147 CLARE SES BASESTATION
TEF03148 CLARENDON
TEF03149 CLEVE
TEF03150 CLEVE (HEGGATON)
TEF03151 CLEVE (NINGANA)
TEF03152 CLEVE (PINEVIEW)
TEF03153 CLEVE AERODROME
TEF03154 CLIFTON HILLS
TEF03155 COCKBURN
TEF03156 COCKBURN (TEPCO)
TEF03157 COFFIN BAY
TEF03158 COMMODORE
TEF03159 CONCORDIA (TURRETFIELD DAM)
TEF03160 COOBER PEDY
TEF03161 COOBER PEDY (MCDQUALL PEAK)
TEF03162 COOBER PEDY AIRPORT
TEF03163 COOK
TEF03164 COOKE PLAINS

23786	5234	BIRDWOOD	Y
26030	5275	REEDY CREEK	Y
24502	5353	BLACK HILL	Y
23839	5050	BLACKWOOD	Y
25056	5357	NOTTS WELL	Y
24564	5357	BLANCHETOWN	Y
17014	5730	BLINMAN	Y
17097	5730	ANGORIGINA	Y
17032	5710	MOOLOOLOO	Y
17041	5710	NARRINA	N
17054	5730	WIRREALPA	N
21003	5462	BLYTH	Y
23081	5110	BOLIVAR	Y
16041	5710	BON BON	N
21004	5417	BOOBOROWIE	Y
26103	5271	BOOL LAGOON	Y
20001	5440	BOOLCOOMATTA	N
19006	5482	BOOLEROO CENTRE	Y
19047	5483	WILLOWIE	Y
19116	5483	BOOLEROO CENTRE	Y
26058	5268	WESTERN FLAT	Y
25525	5268	SENIOR	Y
26037	5268	WESTERN FLAT	Y
25560	5270	BORDERTOWN	Y
24504	5374	BOWER	Y
25040	5307	BOWHILL	Y
21106	5520	BOWILLIA	Y
21112	5550	BOWMANS	Y
20043	5440	FARAWAY HILL	N
23707	5155	BRIDGEWATER	Y
21007	5464	BRINKWORTH	Y
21000	5464	HART	Y
21010	5453	BUNGAREE	Y
17106	5710	QUINYAMBIE	N
23105	5062	MITCHAM	Y
19008	5485	BRUCE	Y
23130	5501	MIDDLE BEACH	Y
18172	5641	BUCKLEBOO	Y
18190	5641	BUCKLEBOO	N
16003	5710	BULGUNNIA	N
23042	5066	BURNSIDE	Y
21136	5418	BURRA	Y
21100	5417	LEIGHTON	Y
21041	5418	MONGOLATA	Y
21086	5374	WORLDS END	Y
21077	5417	BURRA	Y
21012	5560	BUTE	Y
18175	5607	MOODY	Y
18049	5604	BUTLER	Y
16093	5734	ARCKARINGA	N
25050	5333	CALIPH	N
24508	5254	CALLINGTON	Y
24551	5254	MONARTO	Y
21013	5490	CALTOWIE	Y
24513	5353	CAMBRAI	Y
17115	5731	LINDON	N
22823	5223	CAPE BORDA	N
22842	5223	CASSINI	N
26095	5275	CAPE JAFFA	Y
22803	5222	WILLOUGHBY	N
19009	5432	CARRIETON	Y
19013	5432	EURELIA	Y
19098	5432	BELTON	N
23852	5134	CASTAMBUL	Y
18033	5680	WANDANA	N
18047	5680	MALTEE	N
18218	5690	PENONG	N
18207	NIL	NIL	N
18182	5690	UWORRA	N
18012	5680	CEDUNA	N
18223	5680	WANDANA	N
23907	5244	CHARLESTON	Y
23709	5157	CHERRY GARDENS	Y
21129	5453	CLARE	Y
21075	5453	BARINIA	Y
21025	5453	HILL RIVER	Y
21135	5453	CLARE	Y
21131	5453	CLARE	Y
21107	5453	CLARE	Y
23710	5157	CLARENDON	Y
18014	5640	CLEVE	Y
18198	5602	MANGALO	Y
18184	5642	CAMPOONA	Y
18096	5602	COWELL	Y
18116	5640	CLEVE	Y
17016	5710	CLIFTON HILLS STATION	N
20002	5440	COCKBURN	N
20053	5440	TEPCO STATION	N
18188	5607	COFFIN BAY	Y
17017	5710	FLINDERS RANGES	Y
23141	5352	KINGSFORD	Y
16007	5723	COOBER PEDY	N
16027	5710	MCDQUALL PEAK	N
16090	5723	COOBER PEDY	N
18110	5710	NULLARBOR	N
25502	5261	COOKE PLAINS	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03165	COOKE PLAINS (KANBARA)
TEF03166	COOMANDOOK
TEF03167	COONALPYN
TEF03168	COONAWARRA
TEF03169	COONDAMBO
TEF03170	COPEVILLE (FISELL FLAT)
TEF03171	COPPER HILL STATION
TEF03172	CORDILLO DOWNS
TEF03173	CORNY POINT
TEF03174	COULTA
TEF03175	COULTA (COLES POINT)
TEF03176	COURELA (LINDARNOE)
TEF03177	COWELL
TEF03178	COWELL (WINTER SPRINGS)
TEF03179	CRADOCK
TEF03180	CRADOCK (SLATY CREEK)
TEF03181	CRADOCK (YEDNALUE)
TEF03182	CRAFERS (MT LOFTY)
TEF03183	CRAFERS WEST
TEF03184	CRAIGBURN FARM (STURT DAM)
TEF03185	CROMER ROAD
TEF03186	CRYSTAL BROOK
TEF03187	CRYSTAL BROOK SECTION 299
TEF03188	CUDLEE CREEK (MILLBROOK)
TEF03189	CUDLEE CREEK (O'DEAS ROAD)
TEF03190	CUMMINS
TEF03191	CUMMINS AERO
TEF03192	CURNOMONA (CURNAMONA)
TEF03193	CURRAMULKA
TEF03194	CURRAMULKA NORTH
TEF03195	DARKE PEAK
TEF03196	DAWSON (ANDA-VALE)
TEF03197	DRY CREEK (WINGFIELD)
TEF03198	DUFFIELD RAMCO
TEF03199	DUTTON
TEF03200	ECHUNGA
TEF03201	ECHUNGA GOLF COURSE
TEF03202	EDEN VALLEY (MT ADAM)
TEF03203	EDFOWIE
TEF03204	EDINBURGH RAAF
TEF03205	EDITHBURGH
TEF03206	ELLISTON
TEF03207	ELLISTON (LAMBING STATION)
TEF03208	ELLISTON (OAKLANDS)
TEF03209	ELLISTON (THREE LAKES)
TEF03210	ERNABELLA (PUKATJA)
TEF03211	ERUDINA
TEF03212	EUDUNDA
TEF03213	EUDUNDA (MOONDAH)
TEF03214	EVELYN DOWNS
TEF03215	FARRELL FLAT
TEF03216	FELIXSTOW (PAYNEHAM)
TEF03217	FINNISS
TEF03218	FLINDERS CHASE (ROCKY RIVER)
TEF03219	FRANCES
TEF03220	FREELING
TEF03221	FROME DOWNS
TEF03222	FURNER (KENNION SECTION 235)
TEF03223	FURNER (WOOMERA HOMESTEAD)
TEF03224	GALGA
TEF03225	GAMMON RANGES (ARCOONA BLUFF)
TEF03226	GAMMON RANGES (BALCANOONA)
TEF03227	GAMMON RANGES (MOOLAWATANA)
TEF03228	GAMMON RANGES (THE PLATEAU)
TEF03229	GAMMON RANGES (WERTALOOONA)
TEF03230	GAMMON RANGES (WOOLTANA)
TEF03231	GAWLER
TEF03232	GAWLER COUNCIL DEPOT
TEF03233	GAWLER RIVER (HEASLIP ROAD)
TEF03234	GEORGETOWN
TEF03235	GERANIUM
TEF03236	GLADSTONE
TEF03237	GLENDAMBO
TEF03238	GLUEPOT RESERVE (GLUEPOT)
TEF03239	GOOLWA BARRAGE
TEF03240	GOOLWA COUNCIL DEPOT
TEF03241	GOULD CREEK (HERMITAGE)
TEF03242	GOULD CREEK (LITTLE PARA RESERVOIR)
TEF03243	GREAT VICTORIA DESERT (EMU)
TEF03244	GREAT VICTORIA DESERT (LENNY'S TREE)
TEF03245	GREAT VICTORIA DESERT (SHOTLINE)
TEF03246	GREAT VICTORIA DESERT (TALLARINGA WELL)
TEF03247	GREENACRES
TEF03248	GREENOCK
TEF03249	GREENOCK
TEF03250	GREENWAYS (CORTINA)
TEF03251	GULNARE
TEF03252	GUMERACHA
TEF03253	HAHNDORF
TEF03254	HALBURY ROAD, SALISBURY (HALBURY ROAD)
TEF03255	HALLETT
TEF03256	HALLETT (ASHROSE)
TEF03257	HALLETT (LORRAINE)
TEF03258	HALLETT (OLD CANOWIE)
TEF03259	HALLETT (ULOOLOO)
TEF03260	HAMILTON

25555	5264	ASHVILLE	Y
25503	5301	COOMANDOOK	Y
25504	5265	COONALPYN	Y
26091	5277	COONAWARRA	Y
16009	5710	COONDAMBO	N
25057	5308	COPEVILLE	N
16094	5734	EVELYN DOWNS	N
17019	5731	CORDILLO DOWNS	N
22002	5575	CORNY POINT	N
18019	5607	COULTA	Y
18191	5607	COULTA	Y
18162	5661	PETINA	N
18022	5602	COWELL	Y
18176	5602	MILTALIE	Y
19010	5434	CRADOCK	Y
19109	5432	CRADOCK	Y
19061	5434	CRADOCK	N
23901	5152	CRAFERS	Y
23873	5152	CRAFERS WEST	Y
23136	5051	CRAIGBURN FARM	Y
23881	5235	MOUNT PLEASANT	Y
21016	5523	CRYSTAL BROOK	Y
21102	5523	WANDEARAH EAST	Y
23731	5232	MILLBROOK	Y
23879	5232	CUDLEE CREEK	Y
18023	5631	CUMMINS	Y
18217	5631	CUMMINS	Y
20004	5440	CURNAMONA	N
22003	5580	CURRAMULKA	Y
22055	5575	CURRAMULKA	Y
18024	5642	DARKE PEAK	Y
19014	5431	DAWSON	Y
23138	5013	DRY CREEK	Y
24031	5322	STOCKYARD PLAIN	Y
24509	5356	DUTTON	Y
23903	5153	ECHUNGA	Y
23713	5153	ECHUNGA	Y
23902	5235	FLAXMAN VALLEY	Y
19113	5730	FLINDERS RANGES	Y
23083	5111	EDINBURGH	Y
22046	5583	SULTANA POINT	Y
18069	5670	ELLISTON	N
18189	5607	KAPPAWANTA	N
18213	5607	BRAMFIELD	N
18204	5670	ELLISTON	N
16097	NIL	NIL	N
20005	5730	ERUDINA	N
24511	5374	EUDUNDA	Y
24555	5374	HANSBOROUGH	Y
16107	5734	EVELYN DOWNS	N
21019	5416	FARRELL FLAT	Y
23101	5070	FELIXSTOW	Y
23714	5255	FINNISS	Y
22817	5223	FLINDERS CHASE	N
26007	5262	FRANCES	Y
23325	5372	FREELING	Y
20006	5710	FROME DOWNS	N
26086	5280	FURNER	Y
26101	5280	FURNER	Y
25004	5308	GALGA	N
17049	5710	GAMMON RANGES	N
17010	5710	GAMMON RANGES	N
17131	5731	MOOLAWATANA	N
17103	5710	GAMMON RANGES	N
17052	5710	WERTALOOONA	N
17056	5710	WOOLTANA	N
23107	5118	GAWLER WEST	Y
23078	5118	WILLASTON	Y
23111	5117	ANGLE VALE	Y
21020	5472	GEORGETOWN	Y
25506	5301	GERANIUM	Y
21021	5473	GLADSTONE	Y
16084	5710	GLENDAMBO	N
20028	5417	GLUEPOT	Y
23825	5214	GOOLWA SOUTH	Y
23718	5214	GOOLWA	Y
23858	5125	GOULD CREEK	Y
23915	5114	GOULD CREEK	Y
16103	NIL	NIL	N
16101	NIL	NIL	N
16102	NIL	NIL	N
16104	NIL	NIL	N
23133	5086	GREENACRES	Y
23305	5360	GREENOCK	Y
23369	5360	GREENOCK	Y
26114	5272	GREENWAYS	Y
21022	5470	GULNARE	Y
23719	5233	GUMERACHA	Y
23720	5245	HAHNDORF	Y
23043	5108	PARALOWIE	Y
21023	5419	HALLETT	Y
21067	5419	WILLALO	Y
21024	5419	WILLALO	Y
21062	5491	BELALIE EAST	Y
21085	5420	ULOOLOO	Y
23361	5373	HAMILTON	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03261 HAMILTON STATION
TEF03262 HAMLEY BRIDGE
TEF03263 HAMLEY BRIDGE
TEF03264 HAMLEY BRIDGE (LINWOOD)
TEF03265 HAMMOND (COONATTO)
TEF03266 HANSBOROUGH
TEF03267 HAPPY VALLEY RESERVOIR
TEF03268 HARROGATE
TEF03269 HARTLEY (PINE HILL)
TEF03270 HASLAM
TEF03271 HAWKER
TEF03272 HAWKER (HOLLOWILIENA)
TEF03273 HAWKER (WARCOWIE)
TEF03274 HAWKER (WILSON)
TEF03275 HEATHFIELD WORKS DEPOT
TEF03276 HILLTOWN
TEF03277 HILTABA
TEF03278 HINDMARSH ISLAND (MUNDOD BARRAGE)
TEF03279 HINDMARSH ISLAND AWS
TEF03280 HINDMARSH VALLEY (FERNBROOK)
TEF03281 HINDMARSH VALLEY (SPRINGMOUNT)
TEF03282 HOYLETON (ROCKLEIGH)
TEF03283 HUDDLESTON (WILLOW PONDS)
TEF03284 INGLEWOOD
TEF03285 INMAN VALLEY
TEF03286 INNAMINCKA (BOOKABOURDIE)
TEF03287 INNAMINCKA (COOPER CREEK)
TEF03288 INNAMINCKA (DULLINGARI)
TEF03289 INNAMINCKA HOTEL
TEF03290 INNAMINCKA STATION
TEF03291 IRON KNOB
TEF03292 IRON KNOB (GILLES DOWNS)
TEF03293 IRONSTONE ROAD
TEF03294 JAMESTOWN
TEF03295 JAMESTOWN PIRSA
TEF03296 KADINA AWS
TEF03297 KALAMURINA
TEF03298 KALANGADOO
TEF03299 KALANGADOO (MIRNAT)
TEF03300 KANGARILLA (SADDLEBAGS)
TEF03301 KANMANTOO
TEF03302 KANMANTOO (MILLBRAE)
TEF03303 KAPUNDA
TEF03304 KAPUNDA (BAGOT WELL)
TEF03305 KARCULTABY
TEF03306 KAROONDA
TEF03307 KEITH
TEF03308 KEITH (MUNKORA)
TEF03309 KERSBROOK
TEF03310 KERSBROOK (MABENJO)
TEF03311 KEYNETON
TEF03312 KEYNETON (SEDAN HILL)
TEF03313 KI KI (MOORILLA)
TEF03314 KILBURN
TEF03315 KIMBA
TEF03316 KIMBA (BOTENELLA HILLS)
TEF03317 KIMBA (CORTLINYE EVAPORATION)
TEF03318 KIMBA (CORTLINYE)
TEF03319 KIMBA (CURTINYE)
TEF03320 KIMBA (MELALEUCA)
TEF03321 KINGOONYA (NORTH WELL)
TEF03322 KINGSCOTE
TEF03323 KINGSCOTE (KARINGA)
TEF03324 KINGSCOTE AERO
TEF03325 KINGSTON ON MURRAY
TEF03326 KINGSTON SE
TEF03327 KINGSTON SE (KEILIRA STATION)
TEF03328 KINGSTON SE (MOREVIEW)
TEF03329 KOKATHA
TEF03330 KONDOOLKA
TEF03331 KOOLUNGA
TEF03332 KOONAMORE
TEF03333 KOONGAWA (RETAWON)
TEF03334 KOPPIO
TEF03335 KUITPO FOREST RESERVE
TEF03336 KULKAMI
TEF03337 KYANCUTTA
TEF03338 KYANCUTTA (BILLABOWIE)
TEF03339 KYANCUTTA (KYANBRAE)
TEF03340 KYBUNGA (CLOVERLEA)
TEF03341 LAKE EVERARD
TEF03342 LAKE GEORGE (MAHARISHI VEDIC COLLEGE)
TEF03343 LAKE LEAKE (KOOEYONG)
TEF03344 LAMBINA
TEF03345 LAMEROO (ARTLARINGA)
TEF03346 LAMEROO (AUSTIN PLAINS)
TEF03347 LAMEROO (DESFORD)
TEF03348 LAMEROO COMPARISON
TEF03349 LANGHORNE CREEK
TEF03350 LAURA
TEF03351 LAURA (BEETALOO RESERVOIR)
TEF03352 LEAWOOD GARDENS (EAGLE ON THE HILL)
TEF03353 LEIGH CREEK (MAYNARDS WELL)
TEF03354 LEIGH CREEK (NORTH MOOLOOLOO)
TEF03355 LEIGH CREEK (PFITZNER'S WELL)
TEF03356 LEIGH CREEK AIRPORT

16083	5734	ERINGA	N
23095	5401	HAMLEY BRIDGE	Y
23135	5400	HAMLEY BRIDGE	Y
23356	5372	LINWOOD	Y
19108	5485	HAMMOND	Y
23374	5373	HANSBOROUGH	Y
23721	5159	HAPPY VALLEY	Y
23722	5244	HARROGATE	Y
23822	5255	HARTLEY	Y
18118	5661	HASLAM	N
19017	5434	HAWKER	Y
19018	5730	HOLLOWILIENA	N
19046	5434	HAWKER	Y
19050	5433	KANYAKA	Y
23843	5153	HEATHFIELD	Y
21059	5453	HILLTOWN	Y
16034	5710	HILTABA	N
23131	5214	HINDMARSH ISLAND	Y
23894	5214	HINDMARSH ISLAND	Y
23823	5211	HINDMARSH TIERS	Y
23824	5211	HINDMARSH VALLEY	Y
21137	5453	HOYLETON	Y
21072	5473	GEORGETOWN	Y
123700	5133	LOWER HERMITAGE	Y
23723	5211	INMAN VALLEY	Y
17125	5731	INNAMINCKA	N
17118	5731	INNAMINCKA	N
17111	5731	INNAMINCKA	N
17121	5731	INNAMINCKA	N
17028	5731	INNAMINCKA	N
18034	5601	IRON KNOB	Y
18031	5600	GILLES DOWNS	Y
23880	5231	FORRESTON	Y
21027	5491	JAMESTOWN	Y
21060	5491	JAMESTOWN	Y
22050	5554	KADINA	Y
17089	5710	KALAMURINA	N
26009	5278	KALANGADOO	Y
26113	5278	TRIH	Y
23910	5157	KANGARILLA	Y
23724	5252	KANMANTOO	Y
23863	5244	HARROGATE	Y
23307	5373	KAPUNDA	Y
23354	5373	BAGOT WELL	Y
18036	5655	KARCULTABY	N
25006	5307	KAROONDA	Y
25507	5267	KEITH	Y
25557	5267	KEITH	Y
23877	5231	KERSBROOK	Y
23758	5114	KERSBROOK	Y
23725	5353	KEYNETON	Y
24575	5353	KEYNETON	Y
25543	5261	KI KI	Y
23134	5084	KILBURN	Y
18040	5641	KIMBA	Y
18214	5641	WILCHERRY	N
18226	5641	CORTLINYE	N
18193	5641	CORTLINYE	N
18037	5641	KELLY	Y
18177	5641	PINKAWILLINIE	Y
16016	5710	WILGENA	N
22807	5223	KINGSCOTE	N
22808	5223	MACGILLIVRAY	N
22841	5223	CYGNET RIVER	N
24006	5331	KINGSTON ON MURRAY	Y
26012	5275	KINGSTON SE	Y
26010	5271	KEILIRA	Y
26110	5271	BLACKFORD	Y
16021	5720	KOKATHA	N
16022	5710	KONDOOLKA	N
21029	5464	KOOLUNGA	Y
20010	5440	KOONAMORE	N
18101	5650	KOONGAWA	Y
18043	5605	KOPPIO	Y
23887	5157	KUITPO	Y
25036	5307	LAMEROO	N
18044	5650	KYANCUTTA	Y
18208	5650	WARRAMBOO	Y
18170	5650	KYANCUTTA	Y
21073	5453	SPRING GULLY	Y
16024	5720	LAKE EVERARD	N
26109	5280	BEACHPORT	Y
26014	5280	KOORINE	Y
16100	5734	LAMBINA	N
25542	5302	LAMEROO	N
25562	5302	LAMEROO	N
25054	5307	LAMEROO	N
25509	5302	LAMEROO	N
24515	5255	LANGHORNE CREEK	Y
21031	5480	LAURA	Y
21124	5480	BEETALOO VALLEY	Y
23874	5152	LEAWOOD GARDENS	Y
17136	5710	MANNERS WELL	Y
17137	5710	NORTH MOOLOOLOO	Y
17138	5710	NORTH MOOLOOLOO	Y
17110	5710	LEIGH CREEK	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03357 LENSWOOD (STRINGYBARK)
TEF03358 LENSWOOD RESEARCH CENTRE
TEF03359 ILLYDAI F
TEF03360 LOBETHAL
TEF03361 LOBETHAL
TEF03362 LOBETHAL (MAIDMENT ROAD)
TEF03363 LOCK
TEF03364 LOCK (CALLAMONDAH)
TEF03365 LOCK (TERRAH WINDS)
TEF03366 LONG RIDGE (GREENHILL)
TEF03367 LONGWOOD
TEF03368 LONGWOOD
TEF03369 LOWALDIE (CARRAMAR STUD)
TEF03370 LOXTON (PYAP)
TEF03371 LOXTON RESEARCH CENTRE
TEF03372 LUCINDALE (GREENVALE)
TEF03373 LUCINDALE POST OFFICE
TEF03374 LYNDHURST
TEF03375 LYNDOCH
TEF03376 LYNTON (METRO SOUTH SES BASESTATION)
TEF03377 LYRUP
TEF03378 MACCLESFIELD
TEF03379 MACUMBA
TEF03380 MAGPIE CORNER (MURRAY'S COTTAGES)
TEF03381 MAITLAND
TEF03382 MAITLAND (CARINYA)
TEF03383 MAITLAND (KILKERRAN)
TEF03384 MALLALA
TEF03385 MALLALA (DOLAGHANS CROSSING)
TEF03386 MAMBRAY CREEK (BERNIE'S BLOCK)
TEF03387 MANGALO
TEF03388 MANNA HILL
TEF03389 MANNA HILL (WADNAMINGA)
TEF03390 MANNANARIE
TEF03391 MANNUM COUNCIL DEPOT
TEF03392 MANOORA
TEF03393 MANOORA (COOINDA)
TEF03394 MANTUNG
TEF03395 MARALINGA
TEF03396 MARALINGA (DOBO)
TEF03397 MARAMA
TEF03398 MARLA POLICE STATION
TEF03399 MARRABEL
TEF03400 MARREE (CALLANNA)
TEF03401 MARREE (CLAYTON)
TEF03402 MARREE (DULKANINNA)
TEF03403 MARREE (ETADUNNA)
TEF03404 MARREE (FARINA)
TEF03405 MARREE (MUNDOWDNA STATION)
TEF03406 MARREE (WILPOORINNA STATION)
TEF03407 MARREE (WITCHELINA STATION)
TEF03408 MARREE AERO
TEF03409 MARREE COMPARISON
TEF03410 MCLAREN FLAT (BELTUNGA)
TEF03411 MCLAREN VALE (PIRRAMIMMA WINERY)
TEF03412 MEADOWS
TEF03413 MELROSE
TEF03414 MELROSE (PARA GUMS)
TEF03415 MELROSE PARK
TEF03416 MENINGIE
TEF03417 MENINGIE (EGRETTA)
TEF03418 MENINGIE (GREEN PLAINS)
TEF03419 MENINGIE (MILL PARK)
TEF03420 MENINGIE (NARANGA)
TEF03421 MENINGIE (WALTOWA)
TEF03422 MERIBAH (MERALLEN)
TEF03423 MICHAEL PERRY RESERVE, STONYFELL (STONYF)
TEF03424 MILANG
TEF03425 MILANG (NAVARINO)
TEF03426 MILANG (POINT STURT)
TEF03427 MILLERS CREEK
TEF03428 MILLICENT
TEF03429 MINBURRA
TEF03430 MINDARIE
TEF03431 MINLATON
TEF03432 MINLATON (EVERSLEY)
TEF03433 MINLATON AERO
TEF03434 MINNIPA
TEF03435 MINNIPA (MOONLIGHT FLAT)
TEF03436 MINNIPA (WISTILLERE)
TEF03437 MINNIPA PIRSA
TEF03438 MINTABIE
TEF03439 MINTARO
TEF03440 MINTARO (MARTINDALE)
TEF03441 MITCHELL PARK (MARION)
TEF03442 MONARTO SOUTH (MONARTO SECTION 307)
TEF03443 MONARTO ZOOLOGICAL PARK
TEF03444 MONTACUTE
TEF03445 MOOLEULOOLOO
TEF03446 MOOMBA (DARALINGIE)
TEF03447 MOOMBA (TANTANNA)
TEF03448 MOOMBA (TIRRAWARRA)
TEF03449 MOOMBA AIRPORT
TEF03450 MOONAREE (KANGAROO WELL)
TEF03451 MOONTA
TEF03452 MOONTA (WARBURTO POINT)

23865	5134	LENSWOOD	Y
23801	5240	LENSWOOD	Y
20012	5440	MUTOOROO	N
23726	5241	LOBETHAL	Y
23862	5241	LOBETHAL	Y
23882	5244	LOBETHAL	Y
18046	5633	LOCK	Y
18084	5607	MURDINGA	Y
18165	5633	LOCK	Y
23860	5140	GREENHILL	Y
23108	5153	BRADBURY	Y
23727	5153	MYLOR	Y
25039	5307	KAROONDA	Y
24013	5333	PYAP	Y
24024	5333	LOXTON	Y
26069	5271	WOOLUMBOOL	Y
26016	5272	LUCINDALE	Y
17139	5731	LYNDHURST	Y
23309	5351	LYNDOCH	Y
23917	5062	LYNTON	Y
24008	5343	LYRUP	Y
23728	5201	MACCLESFIELD	Y
17030	5710	MACUMBA	N
26112	5277	MAAOUPE	Y
22008	5573	MAITLAND	Y
22056	5573	MAITLAND	Y
22010	5573	MAITLAND	Y
23009	5502	MALLALA	Y
23129	5502	REDBANKS	Y
19120	5495	MAMBRAY CREEK	Y
18173	5602	MANGALO	Y
20013	5440	MANNA HILL	N
20048	5440	WADNAMINGA	N
19115	5431	MANNANARIE	Y
24517	5238	MANNUM	Y
23310	5413	MANOORA	Y
21076	5415	MINTARO	Y
25051	5308	MANTUNG	Y
18114	NIL	NIL	N
18225	NIL	NIL	N
25032	5307	MARAMA	Y
16085	5724	MARLA	N
23311	5413	MARRABEL	Y
17130	5731	CALLANNA	N
17076	5710	CLAYTON STATION	N
17058	5710	DULKANINNA	N
17132	5710	ETADUNNA	N
17024	5731	FARINA	N
17038	5731	MUNDOWDNA	N
17129	5731	MUNDOWDNA	N
17055	5731	WITCHELINA	N
17126	5733	MARREE	N
17031	5733	MARREE	N
23861	5171	MCLAREN FLAT	Y
23876	5171	MCLAREN VALE	Y
23730	5201	MEADOWS	Y
19024	5483	MELROSE	Y
19042	5483	MELROSE	Y
23144	5039	MELROSE PARK	Y
24518	5264	MENINGIE	Y
24577	5264	MENINGIE	Y
25556	5264	MENINGIE	Y
25529	5264	MENINGIE	Y
25523	5261	FIELD	Y
24537	5264	WALTOWA	Y
25048	5311	MERIBAH	N
23145	5066	BURNSIDE	Y
24519	5256	MILANG	Y
24576	5255	ANGAS PLAINS	Y
24550	5256	POINT STURT	Y
16028	5710	MILLERS CREEK	N
26018	5280	MILLICENT	Y
19114	5440	MINBURRA PLAIN	N
25010	5309	MINDARIE	N
22009	5575	MINLATON	Y
22036	5575	MINLATON	Y
22031	5575	MINLATON	Y
18053	5654	MINNIPA	Y
18210	5654	MOUNT DAMPER	Y
18211	5654	MINNIPA	Y
18195	5654	MINNIPA	Y
16088	NIL	NIL	N
21033	5415	MINTARO	Y
21123	5415	MINTARO	Y
23140	5043	MITCHELL PARK	Y
24589	5254	MONARTO SOUTH	Y
24582	5254	MONARTO	Y
23892	5134	MONTACUTE	Y
20049	5440	MOOLEULOOLOO	N
17026	5731	STRZELECKI DESERT	N
17022	5731	MULKA	N
17112	5731	GIDGEALPA	N
17123	5731	GIDGEALPA	N
16086	5720	MOONAREE	N
22011	5558	MOONTA	Y
22053	5554	WARBURTO	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03453 MOOROOK
TEF03454 MORCHARD (THE ROCKS)
TEF03455 MORGAN (BRFENDA PARK STATION)
TEF03456 MORPHETTVILLE
TEF03457 MOUNT BARKER
TEF03458 MOUNT BARRY STATION
TEF03459 MOUNT BOLD RESERVOIR
TEF03460 MOUNT BRYAN
TEF03461 MOUNT COMPASS
TEF03462 MOUNT CRAWFORD (MT CRAWFORD AWS)
TEF03463 MOUNT CRAWFORD FOREST HEADQUARTERS
TEF03464 MOUNT DARE
TEF03465 MOUNT EBA
TEF03466 MOUNT GAMBIER (BLUE LAKE HOLIDAY PARK)
TEF03467 MOUNT GAMBIER AERO
TEF03468 MOUNT GAMBIER COUNCIL DEPOT
TEF03469 MOUNT HOPE (FAIRVIEW)
TEF03470 MOUNT IVE
TEF03471 MOUNT LOFTY
TEF03472 MOUNT LOFTY (CLELAND CONSERVATION PARK)
TEF03473 MOUNT MARY
TEF03474 MOUNT PENNY
TEF03475 MOUNT PLEASANT
TEF03476 MOUNT REMARKABLE (ALLIGATOR GORGE)
TEF03477 MOUNT SCHANK (IETHIA)
TEF03478 MOUNT TEMPLETON (GLENALBYN)
TEF03479 MOUNT VICTOR
TEF03480 MOUNT WEDGE
TEF03481 MOUNT WILSON
TEF03482 MOUNT WUDINNA
TEF03483 MOUNT ZION
TEF03484 MT BOLD (SCOTT CREEK)
TEF03485 MT DAVIDSON (WILLIPPA)
TEF03486 MT TORRENS
TEF03487 MULGUNDAWA SALT
TEF03488 MULOORINA STATION (MULOORINA HOMESTEAD)
TEF03489 MULYUNGARIE
TEF03490 MUNDOORA
TEF03491 MUNDOORA (BARUNGA NORTH)
TEF03492 MUNGERANIE
TEF03493 MUNGERANIE (COWARIE)
TEF03494 MURBKO
TEF03495 MURDINGA (MUNGALA)
TEF03496 MURRAY BRIDGE (LODMOOLOO)
TEF03497 MURRAY BRIDGE (PALLAMANA AERODROME)
TEF03498 MURRAY BRIDGE (TEPKO)
TEF03499 MURRAY BRIDGE COMPARISON
TEF03500 MURRAY LAGOON (HAWKS NEST)
TEF03501 MURRAY TOWN (MURRATANA)
TEF03502 MURRAYS LAGOON (BAYSIDE)
TEF03503 MUTOOROO
TEF03504 MYLOR (BIGGS FLAT)
TEF03505 MYPONGA
TEF03506 MYPONGA (LOVELY VALLEY)
TEF03507 MYPONGA RESERVOIR
TEF03508 NAIRNE
TEF03509 NANGWARRY FORESTRY SA DEPOT
TEF03510 NANTAWARRA (PINE GULLY)
TEF03511 NARACOORTE (BETTWS-Y-COED)
TEF03512 NARACOORTE (VIEW BANK)
TEF03513 NARACOORTE AERODROME
TEF03514 NARRUNG (YALKURI)
TEF03515 NEPTUNE ISLAND
TEF03516 NETHERTON (ROCKLEY GRAZERS)
TEF03517 NEW WELL (MARFIELD)
TEF03518 NILDOTTIE
TEF03519 NILDOTTIE (MOBRAE PARK)
TEF03520 NILPINNA
TEF03521 NOARLUNGA
TEF03522 NONNING
TEF03523 NORMANVILLE
TEF03524 NORTH ADELAIDE
TEF03525 NORTH SHIELDS (PORT LINCOLN AERODROME)
TEF03526 NORTH SHIELDS (PORT LINCOLN AWS)
TEF03527 NULLARBOR
TEF03528 NUNDROO
TEF03529 NUNDROO (CHINTULDA WELL)
TEF03530 NURIOOTPA
TEF03531 NURIOOTPA TOWN BRIDGE
TEF03532 NURIOOTPA VITICULTURAL
TEF03533 OAK VALLEY
TEF03534 OAKDALE
TEF03535 OLARY (WIAWERA)
TEF03536 OODLA WIRRA
TEF03537 OODLA WIRRA (MCCOYS WELL)
TEF03538 OODNADATTA (ALLANDALE)
TEF03539 OODNADATTA AIRPORT
TEF03540 ORROROO
TEF03541 ORROROO (BLACK ROCK)
TEF03542 ORROROO (KYLMOORN)
TEF03543 ORROROO (YALPARA)
TEF03544 OUTER HARBOUR (BLACK POLE)
TEF03545 OVERLAND CORNER
TEF03546 OWEN
TEF03547 PADTHAWAY (MARCOLLAT)
TEF03548 PADTHAWAY (SEPPELTS ROAD)

24010	5332	MOOROOK SOUTH	Y
19025	5431	PEKINA	Y
24578	5320	MORGAN	Y
23143	5043	MORPHETTVILLE	Y
23733	5251	MOUNT BARKER	Y
16082	5734	MOUNT BARRY	N
23734	5157	DORSET VALE	Y
21034	5418	MOUNT BRYAN	Y
23735	5210	MOUNT COMPASS	Y
23878	5351	MOUNT CRAWFORD	Y
23763	5351	MOUNT CRAWFORD	Y
17070	5710	WITIIRA	N
16030	5710	MOUNT EBA	N
26085	5290	MOUNT GAMBIER	Y
26021	5291	WANDILO	Y
26102	5290	MOUNT GAMBIER	Y
18171	5631	MOUNT HOPE	N
16067	5600	MOUNT IVE	N
23842	5152	CRAFERS	Y
23810	5152	CLELAND	Y
24586	5320	MOUNT MARY	Y
25563	5275	TINTINARA	Y
23737	5235	MOUNT PLEASANT	Y
19071	5485	WILMINGTON	Y
26067	5291	MOUNT SCHANK	Y
21035	5461	MOUNT TEMPLETON	Y
20052	5440	MOUNT VICTOR STATION	N
18056	5633	MOUNT WEDGE	N
23906	5171	MCLAREN FLAT	Y
18057	5652	WUDINNA	Y
21079	5480	BEEALOO VALLEY	Y
23921	5157	DORSET VALE	Y
19121	5730	WILLIPPA	N
24579	5234	MOUNT TORRENS	Y
24523	5259	MULGUNDAWA	Y
17037	5710	MULOORINA	N
20016	5440	MULYUNGARIE	N
21036	5521	MUNDOORA	Y
21115	5555	MUNDOORA	Y
17067	5710	MUNGERANIE	N
17020	5710	COWARIE	N
24587	5330	MURBKO	Y
18164	5642	MURLONG	Y
24507	5254	MONARTO SOUTH	Y
24584	5254	PALLAMANA	Y
24533	5254	TEPKO	Y
24521	5253	MURRAY BRIDGE	Y
22822	5223	MACGILLIVRAY	N
19119	5483	BANGOR	Y
22806	5223	SEAL BAY	N
20017	5440	MUTOOROO	N
23911	5153	MYLOR	Y
23738	5202	MYPONGA	Y
23851	5211	HINDMARSH TIERS	Y
23783	5202	MYPONGA	Y
23739	5252	NAIRNE	Y
26098	5277	NANGWARRY	Y
21132	5550	NANTAWARRA	Y
26062	5271	STEWART RANGE	Y
26104	5271	LOCHABER	Y
26099	5271	NARACOORTE	Y
24539	5259	NARRUNG	Y
18115	NIL	NIL	N
25558	5301	NETHERTON	Y
25044	5357	NEW WELL	Y
24547	5238	NILDOTTIE	Y
24588	5238	NILDOTTIE	Y
17127	5710	NILPINNA STATION	N
23885	5168	NOARLUNGA DOWNS	Y
16032	5600	NONNING	N
23741	5204	YANKALILLA	Y
23011	5006	NORTH ADELAIDE	Y
18071	5607	NORTH SHIELDS	Y
18192	5607	NORTH SHIELDS	Y
18106	5690	NULLARBOR	N
18060	5690	COORABIE	N
18199	5690	COORABIE	N
23357	5355	NURIOOTPA	Y
23320	5355	NURIOOTPA	Y
23373	5355	NURIOOTPA	Y
16049	NIL	NIL	N
18209	5607	TOOLIGIE	Y
20058	5440	WIAWERA	N
19031	5440	OODLA WIRRA	N
19106	5440	PARATOO	N
17007	5710	ALLANDALE STATION	N
17043	5734	OODNADATTA	N
19032	5431	ORROROO	Y
19005	5431	BLACK ROCK	Y
19012	5431	ERSKINE	Y
19057	5432	YALPARA	N
23052	NIL	NIL	Y
24012	5345	OVERLAND CORNER	Y
23012	5460	OWEN	Y
26017	5271	MARCOLLAT	Y
26115	5271	PADTHAWAY	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03549	PADTHAWAY SOUTH
TEF03550	PALMER
TEF03551	PANDIE PANDIE
TEF03552	PARACHILNA (MOTPENNA)
TEF03553	PARACHILNA (NILPENNA)
TEF03554	PARACOMBE (KANGAROO CREEK DAM)
TEF03555	PARADISE, SA 5075 (ATHELSTONE)
TEF03556	PARAFIELD AIRPORT
TEF03557	PARAWA (SECOND VALLEY FOREST AWS)
TEF03558	PARAWA (SHARON)
TEF03559	PARILLA
TEF03560	PARINGA LOCK 5
TEF03561	PARNDANA
TEF03562	PARNDANA (PIONEER BEND)
TEF03563	PARNDANA (TURKEY LANE)
TEF03564	PARNDANA CFS AWS
TEF03565	PARRAKIE
TEF03566	PARUNA
TEF03567	PASKEVILLE
TEF03568	PEAKE
TEF03569	PEEBINGA
TEF03570	PELICAN LAGOON
TEF03571	PELICAN POINT
TEF03572	PENNESHAW
TEF03573	PENOLA POST OFFICE
TEF03574	PENONG
TEF03575	PENONG (PENALUMBA)
TEF03576	PERPONDA
TEF03577	PETERBOROUGH
TEF03578	PETERBOROUGH (AMELIA PARK)
TEF03579	PETERSVILLE
TEF03580	PICCADILLY (MOUNT LOFTY BOTANIC GARDEN)
TEF03581	PICCADILLY (WOODHOUSE)
TEF03582	PINE POINT (AMELIA DOWNS)
TEF03583	PINE VALLEY
TEF03584	PINNAROO
TEF03585	PINNAROO (KOMBALI)
TEF03586	PIPALYATJARA
TEF03587	PLUMBAGO
TEF03588	POINT PASS
TEF03589	POLICEMAN POINT
TEF03590	POOCHERA
TEF03591	PORT AUGUSTA (CARRIEWERLOO STN)
TEF03592	PORT AUGUSTA (STIRLING NORTH)
TEF03593	PORT AUGUSTA AERO
TEF03594	PORT AUGUSTA POWER STATION
TEF03595	PORT AUGUSTA WEST
TEF03596	PORT BROUGHTON
TEF03597	PORT BROUGHTON (WANDEARAH)
TEF03598	PORT CLINTON (KADDYINNA)
TEF03599	PORT CLINTON (YARAROO)
TEF03600	PORT ELLIOT CARAVAN PARK
TEF03601	PORT GAWLER (BUCKLAND PARK)
TEF03602	PORT GERMEIN
TEF03603	PORT GERMEIN (GOWAN BRAE)
TEF03604	PORT KENNY
TEF03605	PORT KENNY (MOUNT COOPER)
TEF03606	PORT LINCOLN (BIG SWAMP)
TEF03607	PORT LINCOLN (WESTMERE)
TEF03608	PORT LINCOLN (WHITE FLAT)
TEF03609	PORT LINCOLN (WOOLGA)
TEF03610	PORT LINCOLN SOUTH
TEF03611	PORT NEILL
TEF03612	PORT PARHAM
TEF03613	PORT PIRIE AERODROME
TEF03614	PORT VICTORIA
TEF03615	PORT VINCENT
TEF03616	PORT WAKEFIELD
TEF03617	PORT WAKEFIELD (PAREORA)
TEF03618	PRICE
TEF03619	PROSPECT HILL
TEF03620	PUNTABIE (EAGLE VIEW)
TEF03621	PURNONG (CLAYPANS)
TEF03622	QUONDONG
TEF03623	QUORN
TEF03624	QUORN (DEPOT FLAT)
TEF03625	QUORN (OLIVE GROVE)
TEF03626	RED CREEK (BURWOOD)
TEF03627	REDHILL
TEF03628	REEVES PLAINS (PARANA PARK)
TEF03629	REGENCY PARK
TEF03630	RENMARK AERO
TEF03631	RENMARK IRRIGATION
TEF03632	RHYNIE
TEF03633	RHYNIE (SALTERS SPRINGS)
TEF03634	RIVERTON
TEF03635	RIVERTON (LEEWARD)
TEF03636	RIVERTON (MAROOMBA)
TEF03637	ROBE (BISCUIT FLAT)
TEF03638	ROBE AIRFIELD
TEF03639	ROBE COMPARISON
TEF03640	ROBERTSTOWN
TEF03641	ROCKLEIGH (BLACK HEATH)
TEF03642	ROCKY RIVER (BROOKLAND PARK)
TEF03643	ROSEDALE (TURRETFIELD RESEARCH CENTRE)
TEF03644	ROSEWORTHY

26100	5271	PADTHAWAY	Y
24525	5237	PALMER	Y
17045	5710	PANDIE PANDIE	N
17098	5710	MOTPENNA	Y
17113	5710	NILPENNA	Y
23912	5132	PARACOMBE	Y
23094	5075	PARADISE	Y
23013	5106	PARAFIELD	Y
23875	5204	PARAWA	N
23761	5204	PARAWA	N
25013	5303	PARILLA	N
24037	5343	PARINGA	Y
22837	5223	PARNDANA	N
22815	5223	CASSINI	N
22835	5223	DUNCAN	N
22843	5223	SEDDON	N
25512	5301	PARRAKIE	Y
25014	5311	PARUNA	N
22012	5552	PASKEVILLE	Y
25513	5301	PEAKE	Y
25023	5311	PEEBINGA	N
22836	5222	PELICAN LAGOON	N
26111	5291	PELICAN POINT	Y
22809	5222	PENNESHAW	N
26025	5277	PENOLA	Y
18063	5690	PENONG	N
18002	5690	BOOKABIE	N
25025	5307	PERPONDA	Y
19034	5422	PETERBOROUGH	Y
19118	5440	UCOLTA	Y
22037	5571	MAITLAND	Y
23788	5152	CRAFERS	Y
23891	5144	PICCADILLY	Y
22054	5571	PINE POINT	Y
20030	5417	PINE VALLEY STATION	N
25015	5304	PINNAROO	N
25046	5304	KARTE	N
16099	NIL	NIL	N
20050	5440	PLUMBAGO	N
24526	5374	POINT PASS	Y
26049	5264	COORONG	Y
18068	5655	POOCHERA	N
16005	5710	CARRIEWERLOO	Y
19078	5710	STIRLING NORTH	Y
18201	5700	PORT AUGUSTA WEST	Y
19066	5710	PORT PATERSON	Y
18224	5700	PORT AUGUSTA WEST	Y
21042	5522	PORT BROUGHTON	Y
21108	5523	WANDEARAH EAST	Y
22044	5570	CLINTON	Y
22022	5570	KAINTON	Y
23742	5212	PORT ELLIOT	Y
23032	5501	MIDDLE BEACH	Y
19037	5495	PORT GERMEIN	Y
19112	5540	TELOWIE	Y
18150	5607	PORT KENNY	N
18054	5671	COLLEY	N
18017	5607	PEARLAH	Y
18137	5606	SLEAFORD	Y
18092	5607	WHITES FLAT	Y
18107	5607	GREEN PATCH	Y
18205	5606	PORT LINCOLN	Y
18072	5604	PORT NEILL	Y
23076	5501	PARHAM	Y
21118	5540	PIRIE EAST	Y
22013	5573	PORT VICTORIA	Y
22014	5581	PORT VINCENT	Y
21044	5550	PORT WAKEFIELD	Y
21063	5550	PORT WAKEFIELD	Y
22015	5571	PRICE	Y
23799	5201	PROSPECT HILL	Y
18219	5680	PUNTABIE	N
25002	5238	CLAYPANS	Y
20054	5440	QUONDONG	N
19038	5433	QUORN	Y
19002	5433	YARRAH	Y
19030	5433	QUORN	Y
23864	5255	RED CREEK	Y
21045	5521	REDHILL	Y
23087	5501	REEVES PLAINS	Y
23137	5010	REGENCY PARK	Y
24048	5341	OLD CALPERUM	Y
24003	5341	RENMARK	Y
21130	5412	WOOLSHED FLAT	Y
23039	5460	SALTER SPRINGS	Y
23314	5412	RIVERTON	Y
23355	5412	RIVERTON	Y
23306	5411	RIVERTON	Y
26106	5272	CONMURRA	Y
26105	5275	ROBE	Y
26026	5276	ROBE	Y
24528	5381	ROBERTSTOWN	Y
23812	5236	ROCKLEIGH	Y
22820	5223	GOSSE	N
23343	5352	ROSEDALE	Y
23021	5118	ROSEWORTHY	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03645 ROSEWORTHY AWS
TEF03646 ROSSLYN PARK (SEAVIEW)
TF03647 ROSTREVOR (STRADBROKE)
TEF03648 ROWLAND FLAT (NEW JACOBS CREEK)
TEF03649 ROXBY DOWNS (OLYMPIC DAM AERODROME)
TEF03650 ROXBY DOWNS (PARAKYLIA STATION)
TEF03651 ROXBY DOWNS STATION
TEF03652 RUDALL (SWAFFPRO)
TEF03653 SADDLEWORTH
TEF03654 SADDLEWORTH
TEF03655 SALT CREEK (PITLOCHRY HOMESTEAD)
TEF03656 SALT CREEK (PITLOCHRY OUTSTATION 1)
TEF03657 SANDILANDS
TEF03658 SECOND VALLEY (POOLAMACCA)
TEF03659 SEDAN
TEF03660 SEDAN (SANDLETON)
TEF03661 SEDAN (YOOKAMURRA SANCTUARY)
TEF03662 SELICKS BEACH
TEF03663 SELICKS HILL (MOUNT TERRIBLE RADAR)
TEF03664 SEVENHILL
TEF03665 SHEA-OAK LOG (GREENOCK CREEK)
TEF03666 SHERINGA (LAKE HAMILTON)
TEF03667 SHERLOCK (WARRANA)
TEF03668 SIAM
TEF03669 SMITH BAY (SMITHS BAY)
TEF03670 SMITHFIELD
TEF03671 SMOKY BAY
TEF03672 SNOWTOWN (BANYULA)
TEF03673 SNOWTOWN (CONDOWIE)
TEF03674 SNOWTOWN (RAYVILLE PARK)
TEF03675 SPALDING
TEF03676 SPALDING (BUNDALEER RESERVOIR)
TEF03677 SPICER FLAT
TEF03678 ST KITTS
TEF03679 STANSBURY
TEF03680 STEINGARTEN VINEYARD (STEINGARTEN)
TEF03681 STENHOUSE BAY
TEF03682 STOCKPORT (CLIFTON)
TEF03683 STOCKPORT (STOCKWELL ROAD BRIDGE)
TEF03684 STRATHALBYN
TEF03685 STRATHALBYN RACECOURSE
TEF03686 STRATHEARN
TEF03687 STREAKY BAY
TEF03688 STRUAN
TEF03689 STURT VALE
TEF03690 SUTHERLANDS
TEF03691 SWAN REACH
TEF03692 SWAN REACH (PONDEROSA)
TEF03693 TAILLEM BEND
TEF03694 TAILLEM BEND (RIVER DOWNS (NATURI))
TEF03695 TAILLEM BEND (WOODLANDS)
TEF03696 TALDRA
TEF03697 TANTANOOLA
TEF03698 TANUNDA
TEF03699 TAPLAN
TEF03700 TARCOOLA (COMMONWEALTH HILL)
TEF03701 TARCOOLA (MOBELLA)
TEF03702 TARCOOLA (MULGATHING)
TEF03703 TARCOOLA AERO
TEF03704 TARCOWIE
TEF03705 TARCOWIE (OAKLANDS)
TEF03706 TARLEE
TEF03707 TARLEE (HAZELTON)
TEF03708 TARNMA
TEF03709 TEROWIE
TEF03710 THE TWINS STATION
TEF03711 THEVENARD WIND
TEF03712 THURLGA
TEF03713 TICKERA
TEF03714 TIEYON
TEF03715 TINTINARA
TEF03716 TINTINARA (COLEBATCH DOWNS)
TEF03717 TINTINARA (RICHARDS)
TEF03718 TODMORDEN
TEF03719 TRURO
TEF03720 TUMBY BAY
TEF03721 TUMBY BAY (WARRATTA VALE)
TEF03722 TUMBY BAY (YADNARIE)
TEF03723 TWO WELLS
TEF03724 UNGARRA
TEF03725 UNLEY (ROBERTS STREET)
TEF03726 UPPER HERMITAGE
TEF03727 URAIDLA
TEF03728 URAIDLA (SUTTON CREEK)
TEF03729 VERDUN
TEF03730 VICTOR HARBOR (BERRIMA)
TEF03731 VICTOR HARBOR (ENCOUNTER BAY)
TEF03732 VICTOR HARBOR (RIVINGTON GRANGE)
TEF03733 VICTOR HARBOR (WAITPINGA CLIFFS)
TEF03734 VIVONNE BAY (HIGHGATE)
TEF03735 WADDIKEE
TEF03736 WAIKERIE (EREMOPHILA PARK)
TEF03737 WAIKERIE COUNCIL WORKS DEPOT
TEF03738 WALLAROO
TEF03739 WANILLA
TEF03740 WAROOKA

23122	5400	WASLEYS	Y
23085	5072	ROSSLYN PARK	Y
23086	5073	ROSTREVOR	Y
23376	5351	ROWLAND FLAT	Y
16096	5725	OLYMPIC DAM	Y
16035	5710	PARAKYLIA	Y
16040	5710	ROXBY DOWNS STATION	Y
18174	5642	RUDALL	Y
23315	5413	SADDLEWORTH	Y
23349	5413	SADDLEWORTH	Y
26083	5275	DEEPWATER	Y
26065	5275	TILLEY SWAMP	Y
22016	5571	SANDILANDS	Y
23744	5204	SECOND VALLEY	N
24531	5354	SEDAN	Y
24530	5356	SANDLETON	Y
24581	5354	FISHER	Y
23871	5173	ALDINGA BEACH	Y
23886	5172	SELICKS HILL	Y
21127	5453	SEVENHILL	Y
23348	5355	SHEA-OAK LOG	Y
18045	5632	KIANA	N
25042	5301	SHERLOCK	Y
18186	5600	SIAM	N
22811	5223	WISANGER	N
23025	5114	SMITHFIELD	Y
18077	5680	SMOKY BAY	N
21101	5555	WOKURNA	Y
21015	5555	CONDOWIE	Y
21133	5555	SNOWTOWN	Y
21047	5454	SPALDING	Y
21009	5471	SPALDING	Y
22052	5575	KOOLYWURTIE	Y
23360	5373	ST KITTS	Y
22017	5582	STANSBURY	Y
23146	5351	ROWLAND FLAT	Y
22049	5577	INNESTON	N
23370	5410	STOCKPORT	Y
23347	5355	LIGHT PASS	Y
23747	5255	STRATHALBYN	Y
24580	5255	STRATHALBYN	Y
20055	5440	MOOLEULOOLOO	N
18079	5680	STREAKY BAY	N
26082	5271	STRUAN	Y
20022	5440	STURT VALE	N
24534	5374	SUTHERLANDS	Y
24535	5354	SWAN REACH	Y
24585	5354	FISHER	Y
24536	5260	TAILLEM BEND	Y
24554	5261	NATURI	Y
24510	5254	CHAPMAN BORE	Y
24017	5333	TALDRA	Y
26027	5280	TANTANOOLA	Y
23318	5352	TANUNDA	Y
24032	5333	TAPLAN	Y
16006	5710	COMMONWEALTH HILL	N
16059	5710	COMMONWEALTH HILL	N
16031	5710	MULGATHING	N
16098	5710	TARCOOLA	N
19043	5431	TARCOWIE	Y
19117	5431	TARCOWIE	Y
23319	5411	TARLEE	Y
23365	5412	GILES CORNER	Y
23323	5373	HAMILTON	Y
21050	5421	TEROWIE	Y
16048	5710	MCDOWALL PEAK	N
18200	NIL	NIL	N
16046	5710	THURLGA	N
21110	5555	TICKERA	Y
16095	5734	TIEYON	N
25514	5266	TINTINARA	Y
25526	5275	COLEBATCH	Y
25546	5275	TINTINARA	Y
16047	5734	TODMORDEN	N
24573	5356	TRURO	Y
18086	5605	TUMBY BAY	Y
18091	5605	LIPSON	Y
18203	5605	TUMBY BAY	Y
23028	5501	TWO WELLS	Y
18088	5604	UNGARRA	Y
23119	5061	UNLEY	Y
23806	5131	UPPER HERMITAGE	Y
23750	5142	URAILDA	Y
23905	5144	URAILDA	Y
23866	5242	VERDUN	Y
23834	5211	MOUNT JAGGED	Y
23804	5211	VICTOR HARBOR	Y
23743	5211	BACK VALLEY	Y
23889	5211	WAITPINGA	N
22839	5223	VIVONNE BAY	N
18089	5641	WADDIKEE	Y
24029	5308	WOOLPUNDA	Y
24038	5308	WAIKERIE	Y
22020	5556	WALLAROO	Y
18144	5607	WANILLA	Y
22018	5577	WAROOKA	Y

FOR IDENTIFICATION ONLY
PwC
ADELAIDE

TEF03741 WARRAMBOO
TEF03742 WATERFALL GULLY (WATERFALL)
TEF03743 WATERVALE
TEF03744 WEETULTA
TEF03745 WELLINGTON (BRINKLEY SOUTH)
TEF03746 WHARMINDA
TEF03747 WHYALLA (BROADVIEW STATION)
TEF03748 WHYALLA (MOOLA)
TEF03749 WHYALLA (MOUNT YOUNG)
TEF03750 WHYALLA (MULLAQUANA)
TEF03751 WHYALLA AERO
TEF03752 WHYTE YARCOWIE
TEF03753 WHYTE-YARCOWIE (GUM PARK)
TEF03754 WIGTON FLAT (DOWLINGVILLE)
TEF03755 WILKAWATT (NEWHOUSE FARM)
TEF03756 WILLALOOKA (NIOKA)
TEF03757 WILLALOOKA (YARDOOKRA)
TEF03758 WILLIAMSTOWN
TEF03759 WILLIAMSTOWN (GLEN GILLIAN)
TEF03760 WILLIAMSTOWN (SOUTH PARA RESERVOIR)
TEF03761 WILLOCHRA PLAIN (GUM GLEN)
TEF03762 WILLUNGA
TEF03763 WILLUNGA HILL
TEF03764 WILMINGTON
TEF03765 WILMINGTON (STONEHAVEN)
TEF03766 WILPENA (MARTINS WELL)
TEF03767 WILPENA (ORAPARINNA)
TEF03768 WILPENA POUND
TEF03769 WIRRABARA
TEF03770 WIRRABARA FOREST
TEF03771 WIRRAMINNA HOMESTEAD
TEF03772 WIRREGA (TAUNTON)
TEF03773 WIRRULLA
TEF03774 WIRRULLA (GAWLER VIEW)
TEF03775 WIRRULLA (PIMBENA)
TEF03776 WOLSELEY
TEF03777 WOLSELEY (HONITON)
TEF03778 WOODSIDE
TEF03779 WOODSIDE (INVERBRACKIE)
TEF03780 WOODSIDE (WICKS ESTATE)
TEF03781 WOOLGANGI
TEF03782 WOOMERA (ARCOONA)
TEF03783 WOOMERA (MAHANEWO)
TEF03784 WOOMERA (OAKDEN HILLS)
TEF03785 WOOMERA (PERNATTY STATION)
TEF03786 WOOMERA (SOUTH GAP STATION)
TEF03787 WOOMERA AERODROME
TEF03788 WOOMERA PROFILER
TEF03789 WORLDS END (NARKUNDA)
TEF03790 WRATTONBULLY (JOEVILLE)
TEF03791 WUDINNA
TEF03792 WUDINNA (LOOKOUT)
TEF03793 WUDINNA AERO
TEF03794 YACKA
TEF03795 YALATA COMMUNITY
TEF03796 YALLUNDA FLAT (MEETIGILLY)
TEF03797 YANINEE
TEF03798 YANKALILLA
TEF03799 YARDEA
TEF03800 YARRAMBA
TEF03801 YEELANA (BRIMPTON LAKE)
TEF03802 YEELANA (BROOKER)
TEF03803 YEELANNA
TEF03804 YELLABINNA REGIONAL RESERVE (JACINTH-AMB)
TEF03805 YONGALA
TEF03806 YORKETOWN
TEF03807 YUDNAPINNA
TEF03808 YUNDI (MUNDAWORA)
TEF03809 YUNTA (MELTON)
TEF03810 YUNTA (PANARAMITEE)
TEF03811 YUNTA (PARATOO)
TEF03812 YUNTA (TEETULPA STATION)
TEF03813 YUNTA (WINNININNIE STATION)
TEF03814 YUNTA AIRSTRIP

18090	5650	WARRAMBOO	Y
23908	5064	WATERFALL GULLY	Y
21054	5452	WATERVALE	Y
22058	5572	WEETULTA	Y
24572	5259	BRINKLEY	Y
18113	5603	WHARMINDA	Y
18006	5600	MIDDLEBACK RANGE	Y
18117	5600	MIDDLEBACK RANGE	Y
18221	5600	MIDDLEBACK RANGE	Y
18058	5600	MIDDLEBACK RANGE	Y
18120	5600	MULLAQUANA	Y
21055	5420	WHYTE YARCOWIE	Y
21120	5420	CANOWIE BELT	Y
22048	5571	DOWLINGVILLE	Y
25539	5301	LAMEROO	N
26107	5267	WILLALOOKA	Y
26088	5267	WILLALOOKA	Y
23752	5351	WILLIAMSTOWN	Y
23756	5351	WILLIAMSTOWN	Y
23820	5351	WILLIAMSTOWN	Y
19122	5433	WILLOCHRA	Y
23753	5172	WILLUNGA	Y
23857	5172	WILLUNGA SOUTH	Y
19048	5485	WILMINGTON	Y
19103	5485	WILMINGTON	Y
19111	5730	MARTINS WELL	N
19107	5730	FLINDERS RANGES	Y
19070	5730	FLINDERS RANGES	Y
19052	5481	WIRRABARA	Y
19053	5481	WIRRABARA	Y
16062	5720	WIRRAMINNA	N
25518	5267	WIRREGA	Y
18094	5661	WIRRULLA	N
18197	5661	WALLALA	N
18166	5680	NUNIIKOMPITA	N
25519	5269	WOLSELEY	Y
25561	5269	POOGINAGORIC	Y
23829	5244	WOODSIDE	Y
24583	5244	WOODSIDE	Y
23920	5244	WOODSIDE	Y
20025	5417	WARNES	Y
16000	5720	ARCOONA	Y
16025	5720	MAHANEWO	N
16033	5720	OAKDEN HILLS	Y
16036	5720	PERNATTY	Y
16043	5720	SOUTH GAP	Y
16001	5710	WOOMERA	Y
16105	5710	COONDAMBO	N
21138	5381	HALLELUJAH HILLS	Y
26075	5271	WRATTONBULLY	Y
18095	5652	WUDINNA	Y
18167	5653	WUDINNA	Y
18083	5653	WUDINNA	Y
21057	5470	YACKA	Y
18161	5690	YALATA	N
18104	5605	YALLUNDA FLAT	Y
18098	5653	YANINEE	Y
23754	5203	YANKALILLA	Y
16055	5710	YARDEA	N
20059	5440	YARRAMBA	N
18005	5632	MITCHELL	N
18007	5607	BROOKER	Y
18099	5632	YEELANNA	Y
18222	5710	YELLABINNA	N
19062	5431	YONGALA	Y
22023	5576	YORKETOWN	Y
16056	5710	YUDNAPINNA	Y
23897	5172	YUNDI	Y
20051	5440	MELTON STATION	N
20020	5440	YUNTA	N
20021	5440	GRAMPUS	N
20061	5440	YUNTA	N
20024	5440	WINNININNIE	N
20062	5440	YUNTA	N

FOR IDENTIFICATION ONLY
PwC
ADELAIDE



Basis of Preparation

AER Benchmarking

April 2014

Version FINAL RESPONSE



FOR IDENTIFICATION ONLY
PwC
ADELAIDE

ElectraNet Corporate Headquarters

52-55 East Terrace, Adelaide, South Australia 5000 • PO Box, 7096, Hutt Street Post Office, Adelaide, South Australia 5000
Tel: (08) 8404 7966 • Fax: (08) 8404 7104 • Toll Free: 1800 243 853

Copyright and Disclaimer

Copyright in this material is owned by or licensed to ElectraNet. Permission to publish, modify, commercialise or alter this material must be sought directly from ElectraNet.

Reasonable endeavours have been used to ensure that the information contained in this report is accurate at the time of writing. However, ElectraNet gives no warranty and accepts no liability for any loss or damage incurred in reliance on this information.

Revision Record

Date	Version	Description	Author	Checked By	Approved By
------	---------	-------------	--------	------------	-------------



Contents

1.	INTRODUCTION	8
2.	REVENUE	9
2.1	REVENUE GROUPING BY CHARGEABLE QUANTITY (TREV0101-TREV0110)	9
2.1.1	<i>Data requirement</i>	9
2.1.2	<i>Data source and methodology</i>	9
2.1.3	<i>Basis of estimation</i>	11
2.1.4	<i>Changes to accounting policies</i>	11
2.2	REVENUE GROUPING BY TYPE OF CONNECTED EQUIPMENT (TREV0201-0205)	11
2.2.1	<i>Data requirement</i>	11
2.2.2	<i>Data source and methodology</i>	12
2.2.3	<i>Basis of estimation</i>	12
2.2.4	<i>Changes to accounting policies</i>	13
	<i>There has been no change to accounting policies that impact revenue by chargeable quantities</i> ...	13
2.3	REVENUE (PENALTIES) ALLOWED (DEDUCTED) THROUGH INCENTIVE SCHEMES (TREV0301-TREV0303)	13
2.3.1	<i>Data requirement</i>	13
2.3.2	<i>Data source and methodology</i>	13
2.3.3	<i>Basis of estimation</i>	14
2.3.4	<i>Changes to accounting policies</i>	14
3.	OPERATING EXPENDITURE ('OPEX')	15
3.1	OPERATING EXPENDITURE CATEGORIES (TOPEX0101-TOPEX0103A)	15
3.1.1	<i>Data requirement</i>	15
3.1.2	<i>Data source and methodology</i>	15
3.1.3	<i>Basis of estimation</i>	15
3.1.4	<i>Changes to accounting policies</i>	16
3.2	PROVISIONS (TOPEX02-TOPEX0212)	16
3.2.1	<i>Data requirement</i>	16
3.2.2	<i>Data source and methodology</i>	16
3.2.3	<i>Basis of estimation</i>	19
3.2.4	<i>Changes to accounting policies</i>	19
4.	ASSETS (RAB)	22
4.1	REGULATORY ASSET BASE VALUES	22
4.2	ASSET VALUE ROLL FORWARD	22
4.2.1	<i>Data requirement</i>	22
4.2.2	<i>Data source</i>	22
4.2.3	<i>Methodology</i>	23
4.2.4	<i>Basis of estimation</i>	24
4.2.5	<i>Changes to accounting policies</i>	26
4.3	TOTAL DISAGGREGATED RAB ASSET VALUES	26
4.3.1	<i>Data requirement</i>	26
4.3.2	<i>Data source</i>	26

4.3.3	Methodology	26
4.3.4	Basis of estimation	26
4.3.5	Changes to accounting policies.....	26
4.4	ASSET LIVES	27
4.4.1	Data requirement.....	27
4.4.2	Data source	27
4.4.3	Methodology.....	27
4.4.4	Basis of estimation	28
4.4.5	Changes to accounting policies.....	28
5.	OPERATIONAL DATA.....	29
5.1	ENERGY DELIVERY (TOPED0101-TOPED0103)	29
5.1.1	Data requirement.....	29
5.1.2	Data source and methodology	29
5.1.3	Basis of estimation	29
5.1.4	Changes to accounting policies.....	29
5.2	CONNECTION POINT NUMBERS	30
5.2.1	Data requirement.....	30
5.2.2	Data source and methodology	30
5.2.3	Basis of estimation	30
5.2.4	Changes to accounting policies.....	31
5.3	SYSTEM DEMAND (TOPSD0101-TOPSD0308)	31
5.3.1	Annual system maximum demand characteristics (TOPSD0101-TOPSD0206)	31
5.3.1.1	Data requirement.....	31
5.3.1.2	Data source and methodology	31
5.3.1.3	Basis of estimation	32
5.3.1.4	Changes to accounting policies.....	32
5.3.2	Power factor (TOPSD0301-TOPSD0308).....	32
5.3.2.1	Data requirement.....	32
5.3.2.2	Data source and methodology	32
5.3.2.3	Basis of estimation	34
5.3.2.4	Changes to accounting policies.....	34
6.	PHYSICAL ASSETS	35
6.1	TRANSMISSION SYSTEM CAPACITIES VARIABLES – OVERHEAD CIRCUIT LENGTH (TPA0101-TPA06) 35	
6.1.1	Data requirement.....	35
6.1.2	Data source	35
6.1.3	Basis of estimation	35
6.1.4	Changes to accounting policies.....	36
6.2	UNDERGROUND CABLE CIRCUIT LENGTH AT EACH VOLTAGE (TPA0201 – TPA0207).....	37
6.2.1	Data requirement.....	37
6.2.2	Data source and methodology	37
6.2.3	Basis of estimation	37
6.2.4	Changes to accounting policies.....	37
6.3	ESTIMATED OVERHEAD NETWORK WEIGHTED AVERAGE MVA CAPACITY BY VOLTAGE CLASS (TPA0301 – TPA0307).....	38
6.3.1	Data requirement.....	38

6.3.2	<i>Data source and methodology</i>	38
6.3.3	<i>Basis of estimation</i>	38
6.3.4	<i>Changes to accounting policies</i>	39
6.4	ESTIMATED UNDERGROUND NETWORK WEIGHTED AVERAGE MVA CAPACITY BY VOLTAGE CLASS (TPA0401 – TPA0407).....	39
6.4.1	<i>Data requirements</i>	39
6.4.2	<i>Data source and methodology</i>	40
6.4.3	<i>Basis of estimation</i>	40
6.4.4	<i>Changes to accounting policies</i>	40
6.5	INSTALLED TRANSMISSION SYSTEM TRANSFORMER CAPACITY (TPA0501 – TPA0505).....	40
6.5.1	<i>Data requirements</i>	40
6.5.2	<i>Data source and methodology</i>	41
6.5.3	<i>Basis of estimation</i>	42
6.5.4	<i>Changes to accounting policies</i>	43
6.6	COLD SPARE CAPACITY (TPA06).....	43
6.6.1	<i>Data requirements</i>	43
6.6.2	<i>Data source and methodology</i>	43
6.6.3	<i>Basis of estimation</i>	43
6.6.4	<i>Changes to accounting policies</i>	43
7.	QUALITY OF SERVICES	44
7.1	SERVICE COMPONENT	44
7.1.1	<i>Service parameter 1 – Average circuit outage rate (TQS0101-TQS0115)</i>	44
7.1.1.1	<i>Data requirement</i>	44
7.1.1.2	<i>Data source and methodology</i>	45
7.1.1.3	<i>Basis of estimation</i>	46
7.1.1.4	<i>Changes to accounting policies</i>	46
7.1.2	<i>Service parameter 2 – Loss of supply event (TQS0116-TQS0117)</i>	46
7.1.2.1	<i>Data requirement</i>	46
7.1.2.2	<i>Data source and methodology</i>	46
7.1.2.3	<i>Basis of estimation</i>	47
7.1.2.4	<i>Changes to accounting policies</i>	47
7.1.3	<i>Service parameter 3 – Average outage duration (TQS0118)</i>	48
7.1.3.1	<i>Data requirement</i>	48
7.1.3.2	<i>Data source and methodology</i>	48
7.1.3.3	<i>Basis of estimation</i>	48
7.1.3.4	<i>Changes to accounting policies</i>	48
7.1.4	<i>System parameter – Proper operation of equipment – number of failure events (TQS0119-TQS0121)</i>	48
7.1.4.1	<i>Data requirement</i>	48
7.1.4.2	<i>Data source and methodology</i>	49
7.1.4.3	<i>Basis of estimation</i>	50
7.1.4.4	<i>Changes to accounting policies</i>	51
7.2	MARKET IMPACT COMPONENT	51
7.2.1	<i>Data requirement</i>	51
7.2.2	<i>Data source and methodology</i>	51
	<i>The process is applied to the Version 3 or earlier MIC data for 2006 – 2012</i>	51
7.2.3	<i>Basis of estimation</i>	52

7.2.4	<i>Changes to accounting policies</i>	52
7.3	SYSTEM LOSSES	52
7.3.1	<i>Data requirement</i>	52
7.3.2	<i>Data source and methodology</i>	52
7.3.3	<i>Basis of estimation</i>	52
7.3.4	<i>Changes to accounting policies</i>	52
8.	OPERATING ENVIRONMENT	53
8.1	TERRAIN FACTORS (TEF010-TEF0108).....	53
8.1.1	<i>Data requirement</i>	53
8.1.2	<i>Data source and methodology</i>	55
8.1.3	<i>Basis of estimation</i>	59
8.1.4	<i>Changes to accounting policies</i>	59
8.2	NETWORK CHARACTERISTICS	59
8.2.1	<i>Data requirement</i>	59
8.2.2	<i>Data source and methodology</i>	60
8.2.3	<i>Basis of estimation</i>	62
8.2.4	<i>Changes to accounting policies</i>	62
8.3	WEATHER STATIONS	62
8.3.1	<i>Data requirement</i>	62
8.3.2	<i>Data source and methodology</i>	62
8.3.3	<i>Basis of estimation</i>	63
8.3.4	<i>Changes to accounting policies</i>	63

Figures

Figure 2-1: MTC service charges	11
Figure 3-1: Retirement benefit obligations mapping.....	18
Figure 3-2: Retirement benefit obligations analysis	21
Figure 8-1: Climate Zones Based on Temperature and Humidity	57
Figure 8-2: SA Generators	61

Tables

Table 2-1: Notification of Murraylink revenue amount for each financial year	10
Table 4-1: Mapping regulated asset classes to RIN asset categories	23
Table 4-2: Land value apportionment	26

1. Introduction

On 28 November 2013, ElectraNet Pty Limited was served with a Regulatory Information Notice pursuant to Division 4 of Part 3 of the National Electricity (South Australia) Law (the RIN).

A requirement of the Benchmarking RIN set out in the Instructions and Definitions accompanying the RIN, is that ElectraNet in addition to providing to the AER a completed data template, must provide a 'Basis of Preparation' which explains for each variable inputted to the data template the basis upon which the input has been prepared.

In accordance with the requirements of the RIN, the following sections of this report provides ElectraNet's basis of preparation for all variables inputted to the data template accompanying this report. Consistent with the Instructions and definitions this basis of preparation addresses the following:

- How the information provided is consistent with the requirements of the notice;
- Explains the source from which ElectraNet obtained the information provided;
- Explains the methodology ElectraNet applied to provide the required information, including any assumptions ElectraNet made;
- Where ElectraNet could not provide an input for a variable using actual information and an estimate was required:
 - Why an estimate was required, including why it was not possible for ElectraNet to use actual information; and
 - The basis for the estimate, including the approach used, assumptions made and reasons why the estimate is ElectraNet's best estimate, given the information sought in the notice.
- In the case of financial information, an explanation if applicable, of the nature and impact of any accounting changes adopted by ElectraNet which have materially changed during any of the regulatory years covered by the notice.

Note that this basis of preparation relates to ElectraNet's 'first response' and as such under the notice, the AER does not require the numbers to be audited or verified by statutory declaration. ElectraNet are still in the process of obtaining assurance sign-off and therefore this basis of preparation and accompanying data remains subject to change.

In accordance with the requirements of the RIN, ElectraNet will submit a final audited and verified version of the data template and Basis of Preparation and accompanying audit report on 30 April 2014.

2. Revenue

2.1 Revenue grouping by chargeable quantity (TREV0101-TREV0110)

2.1.1 Data requirement

ElectraNet is required under the instructions and definitions for the final economic benchmarking RIN to report revenues allocated to the chargeable quantity that most closely reflects the basis upon which the revenue was charged by ElectraNet to customers.

Consistent with the RIN instructions and definitions, ElectraNet has reported revenue by chargeable quantity on the following basis:

- Revenues from Exit services where they are bill on a fixed annual charge based on location only 'From Fixed Customer (Exit Point) charges' (TREV0101),
- Revenues from Entry services where they are bill on a fixed annual charge based on location only 'From Fixed Generator (Entry Point) charges' (TREV0103),
- Revenues from TUOS Usage services (also referred to as TUOS Locational from 2009-10) where they are bill on a locational "nominated / agreed" demand basis against 'From Fixed Energy Usage Charges (Charge per day basis)' (TREV0105),
- Revenues from Common Service and TUOS General charges (also referred to TUOS Non-location from 2009-10) where they are billed on an energy accumulation basis against 'From Energy based Common Service and TUOS General Charges' (TREV0107);
- Revenues from Common Service and TUOS General charges (also referred to TUOS Non-location from 2009-10) where they are billed on a "nominated / agreed" demand basis against 'From Fixed Demand based Usage Charges' (TREV0108); and
- Revenues from other source, is revenue from Settlements Residues Auction (SRA) Proceeds, intra-regional settlement residues, under/over recovery of revenue from previous years plus interest (TREV0110).

Please note that ElectraNet does not charge revenue from the following groups:

- From Variable customer (Exit Point) charges, TREV0102;
- From Variable Generator (Entry Point), TREV0104;
- From Variable Energy Usage Charges (Charge per day basis), TREV0106; and
- From Variable Demand based Usage Charges TREV0109.

2.1.2 Data source and methodology

ElectraNet has sourced the revenue information for table 2.1 directly from the Regulatory Financial Reports for the respective years.

Removal of Murraylink revenue (not ElectraNet's revenue): TREV0105, TREV0107 and TREV0108

ElectraNet is the Co-ordinating Network Service Provider for South Australia and collects both ElectraNet's and the Murraylink Transmission Company (MTC)'s regulated revenue entitlements via ElectraNet's prescribed transmission service prices.

As the Regulatory Financial Reports show revenue charge categories that are inclusive of revenue collected by ElectraNet on behalf of MTC, ElectraNet have adjusted the impacted categories.

MTC is required to advise ElectraNet annually of the Aggregate Annual Revenue Requirement (AARR) and optimised replacement cost (ORC) for its transmission system assets which are used to provide prescribed transmission services within the South Australian region. MTC's revenue must be removed from the revenue groupings. Given revenue charged is calculated using the AARR and ORC, we have used this to remove the revenue on the same basis from the relevant categories in table 2.1 of the data template. Revenue amount for Murraylink for each financial year is shown in **Table 2-1: Notification of Murraylink revenue amount for each financial year below:**

Table 2-1: Notification of Murraylink revenue amount for each financial year

MTC Allocation by Class of Service (GST exclusive)	2005-06	2006-07	2007-08	2008-09	2009-10	2010-11	2011-12	2012-13
Entry service ORC	-	-	-	-	-	-	-	-
Exit service ORC	-	-	-	-	-	-	-	-
TUOS Service ORC	43,652,411	43,652,411	43,652,411	43,652,411	43,652,411	43,652,411	43,652,411	43,652,411
Common Service ORC	2,678,689	2,678,689	2,678,689	2,678,689	2,678,689	2,678,689	2,678,689	2,678,689
Total ORC	46,311,100	46,311,100	46,311,100	46,311,100	46,311,100	46,311,100	46,311,100	46,311,100
AARR	4,845,520	4,977,972	5,084,766	5,147,603	5,420,161	5,386,652	5,463,472	5,549,744

Split of Common service charges and TUOS general charges in line with the RIN revenue categories


Common service charges and TUOS general charges as reported in the Regulatory Financial Report for each respective year includes both "Energy based Common Service

and General Charges” (TREV0107) and “Fixed Demand based Usage Charges” (TREV0108).

The split between TREV0107 and TREV0108 have been sourced from customer invoices where these charges are individually identified.

Overall, after factoring in the MTC adjustment (detailed above), the sum of Common service charges and TUOS general charges per the Regulatory Financial Reports agree to the sum of variables TREV0107 and TREV0108. The breakdown of MTC AARR service charges is presented in Figure 2-1: MTC service charges below:

Figure 2-1: MTC service charges



2.1.3 Basis of estimation

There is no estimation involved in table 2.1.

2.1.4 Changes to accounting policies

There has been no change to accounting policies that impact revenue by chargeable quantities.

2.2 Revenue grouping by type of connected equipment (TREV0201-0205)

2.2.1 Data requirement

ElectraNet is required under the instructions and definitions for the final economic benchmarking RIN to report in accordance with the type of connection equipment.

External project work and gross proceeds from the sale of assets where related to Prescribed Transmission Services were reported as “other revenue (TREV0205).”

Consistent with the RIN instructions and definitions, ElectraNet has reported revenue by chargeable quantity on the following basis:

- From other connected transmission networks (TREV0201), ElectraNet does not have any other regulated connections to transmission networks thus this is zero for all years.
- From Distribution networks (TREV0202), is revenue charged to the South Australian Distribution Network Service Provider (DNSP) they are referred to as ETSA Utilities or ETSA Transmission Service Charges in the Customer totals sheets for the respective years
- From Directly Connected end users (TREV0203), is revenue charged to directly connected customer of the ElectraNet network it does not contain the Distribution networks customer.
- Revenues from Generators (TREV0204) is the same as (TREV0103), Entry services where they are bill on a fixed annual charge based on location only ‘From Fixed Generator (Entry Point) charges’ as generators are only charged Entry Services.
- Other revenue (TREV0205) is the same as (TREV0110), Revenues from other sources, this is revenue from SRA Auction Proceeds intra-regional settlement residues, under/over recovery of revenue from previous years plus interest.

2.2.2 Data source and methodology

ElectraNet has sourced the revenue information for TREV0202 through to TREV0204 from customer invoices. Based on customer invoice information, ElectraNet have summarised revenue by type of charge on an annual basis for each customer. The total revenue by charge has been reconciled to the total revenue reported in the Regulatory Financial reports. TREV0205 has been sourced directly from the respective Regulatory Financial Reports.

As stated in 2.1, these revenue numbers contain the revenue collected for both ElectraNet and MTC, thus MTC’s revenue must be removed for the purposes of this RIN. ElectraNet collect revenue on behalf of MTC from only Distribution Networks and directly connected end-users (TREV0202 and TREV0203).

The adjustment required to TREV0202 and TREV0203 to remove the AARR for MTC is on the same basis as detailed in section 2.1.2 of this document. The split of revenue collected on behalf of MTC (as advised in the annual AARR letters) between TREV0202 and TREV0203 is based on actual revenue charged by connected equipment type. No estimation or assumptions are involved.

As TREV0204 relates only to entry charges, this line item does not need to be adjusted, nor does the TREV0205 need to be adjusted for Murraylink’s revenue.

2.2.3 Basis of estimation

There is no estimation involved in table 2.2.

2.2.4 Changes to accounting policies

There has been no change to accounting policies that impact revenue by chargeable quantities.

2.3 Revenue (penalties) allowed (deducted) through incentive schemes (TREV0301-TREV0303)

2.3.1 Data requirement

ElectraNet is required under the instructions and definitions for the final economic benchmarking RIN to report penalties or rewards of incentive schemes.

Consistent with the RIN instructions and definitions, revenues and penalties from incentives schemes are reported in the year in which the penalty or reward was applied as opposed to the year it was gained.

2.3.2 Data source and methodology

ElectraNet has reported revenue on the following basis from the following sources:

- EBSS (TREV0301), ElectraNet obtained these figures directly from Table 7.9 AER's final decision on annual building block revenue requirement (\$m, nominal) labelled Opex efficiency (glide path) allowance from the Final decision ElectraNet transmission determination 2008-09 to 2012-13 dated 11 April 2008.
- STIPS (TREV0302), is the additional revenue or penalty the AER approved as part of the annual Transmission service standards review. The source of the data is taken directly from the letters provided by the AER to ElectraNet annual. The letters are as follows:
 - Letter dated 3 May 2006 – Service standard review for 2005, revenue for the financial year 2006-07
 - Letter dated 24 April 2007 – Transmission service standards compliance review for 2006, revenue for the financial year 2007-08
 - Letter dated 28 April 2008 – Transmission service standards compliance review for 2007, revenue for the financial year 2008-09
 - Letter dated 28 April 2009 – Transmission service standards review for 2008, revenue for the financial year 2009-10
 - Letter dated 30 April 2010 – Transmission service standards review for 2009, revenue for the financial year 2010-11
 - Letter dated 20 April 2011 – Transmission service standards review for 2010, revenue for the financial year 2011-12
 - Letter dated 23 April 2012 – Transmission service standards review for 2011, revenue for the financial year 2012-13
- Other (TREV0303) ElectraNet does not have any other schemes

2.3.3 Basis of estimation

There is no estimation involved in table 2.3.

2.3.4 Changes to accounting policies

There has been no change to accounting policies that impact revenue through incentive schemes.

3. Operating Expenditure ('Opex')

3.1 Operating expenditure categories (TOPEX0101-TOPEX0103A)

3.1.1 Data requirement

As per the AER's RIN requirements, given that ElectraNet's cost allocation approach, basis of preparation for its regulatory accounting statements, or response to the information guidelines have not changed across the Benchmarking reporting period, ElectraNet have not filled out table 3.1.1 but rather used table 3.1.2 for section 3.1.

Table 3.1.2 requires ElectraNet to report Opex activities (for example: network, operations, asset management support and field maintenance) reported in its Information Guidelines response for individual Regulatory Year. For the avoidance of doubt this means that

- The accounting principles applied by the NSP to complete its regulatory Financial Statements for each individual Regulatory Year must be applied when reporting Opex for that Regulatory Year.
- Opex reported must be prepared in a consistent manner to that of Opex reported in the Regulatory Financial Statements.
- Opex line items reported in Table 3.1.2 should equal Opex line items reported in the Regulatory Accounting Statements for each Regulatory Year.

ElectraNet must report, for all Regulatory Years, Opex in accordance with its Cost Allocation Approach and the Regulatory Accounting Statements that were in effect for the relevant Regulatory Year.

Opex must be reported in accordance with the categories for the relevant Regulatory Year and should directly reconcile to the Opex in ElectraNet's response to the Information Guidelines for that year.

The information provided by ElectraNet is sourced from regulatory reporting for the 2009-2013 regulatory period and agrees to the regulatory financial reports for each reported year. Comparable information is provided for the 2006-2008 period.

3.1.2 Data source and methodology

ElectraNet has sourced the opex information from the Regulatory Financial Reports – Historic Opex by Expenditure Category schedule for the years 2009 to 2013. For the 2006 to 2008 years, ElectraNet has compiled comparable information from the historical data available.

3.1.3 Basis of estimation

No estimates have been made in the compilation of this information. Estimates and judgements may be required in accordance with the Transmission Network Service Providers Information Guidelines when compiling the underlying data within the relevant regulatory financial reports. ElectraNet notes that there have been changes to the

business structure and improvements to financial systems which have occurred during the reported period. After any change, ElectraNet has endeavoured to ensure that reported regulatory opex data is as consistent as possible with reset decisions and reporting in prior years.

3.1.4 Changes to accounting policies

There has been a change to the accounting for retirement benefit obligations which was first applied from 1 July 2011. The nature and impact of this change to opex is disclosed in detail within section 3.2.4 Provisions – Changes to accounting policy.

There have been no changes to ElectraNet's cost allocation approach and regulatory accounting principles or policies which affect historical opex reporting.

3.2 Provisions (TOPEX02-TOPEX0212)

3.2.1 Data requirement

ElectraNet must report, for all Regulatory Years, Financial Information on provisions for Prescribed Transmission Services in accordance with the Cost Allocation Approach and the Information Guidelines that were in effect for the relevant Regulatory Year.

ElectraNet must report Financial Information for each of its provisions.

Provisions must be reported in accordance with the regulatory principles and policies within the Information Guidelines for each Regulatory Year.

Financial information on provisions should reconcile to the reported amounts for provisions in the Regulatory Financial Reports for each Regulatory Year.

3.2.2 Data source and methodology

Information on annual and long service leave and self-insurance provisions has been sourced from the Regulatory Financial Report for each financial year.

Information on the retirement benefit obligation provision has been extracted from ElectraNet's Statutory Financial Reports for each financial year. Information has been extracted from the Statutory Financial Reports as there is more detailed information provided to satisfy the data requirements of the RIN (e.g. variables TOPEX0205B and TOPEX0211B).

Leave provisions

The information extracted from the Regulatory Financial Reports is tabled for each year from the Provisions Reconciliation – Prescribed Transmission Services.

Each year there is calculation of the proportion of ElectraNet's cost applicable to prescribed network services. This proportion varies each year. The amounts tabled are the balances and movements applicable to prescribed network services.

Given the proportion of prescribed network services to total network services changes each year, an adjustment is made to the "increases to provisions" row to ensure the

opening balance of the current year is equal to the closing balance of the preceding year. The adjustment is made up of the difference in the current and prior year's prescribed network services percentage, multiplied by the closing value of the preceding year.

To derive the split of provisions between capital expenditure (capex) and opex, ElectraNet have made an estimation based on the labour activity allocation to capex and opex costs. For further details of the estimation refer to 3.2.3 Basis of Estimation.

For long service leave (LSL), for each year from 2009 onwards, ElectraNet has calculated the provision movement due to the change in the annual discount rate applied to the leave accrued for employees who have not reached the full LSL entitlement period of seven years. The previous year's discount rate has been substituted into each annual LSL calculation of the current year to derive the liability using the previous discount rate. The recalculated provision amount is subtracted from the current year's actual calculation to derive the movement.

ElectraNet uses the Commonwealth Government five year bond rate as the annual discount rate. The movement due to the discount rate is shown in TOPEX205A for opex and TOPEX211A for capex, with a corresponding offset in TOPEX202A and TOPEX208A.

Retirement benefit obligation

Information is extracted from the detailed notes which form part of the annual ElectraNet Statutory Financial Reports. The statutory information is more comprehensive than the information disclosed in the annual Regulatory Financial Report.

The information extracted from the ElectraNet Statutory Financial Report is adjusted to the portion applicable to prescribed network services based on the prescribed network services percentage disclosed in the Regulatory Financial Report. Opening and closing balances of the retirement benefit obligation provision agrees with the Regulatory Financial Report balances for each year.

The detailed extracted information is summarised in the format required in table 3.2 of the data template in accordance with the mapping shown in **Figure 3-1: Retirement benefit obligations mapping** on the following page:

Figure 3-1: Retirement benefit obligations mapping

TOPEX02B Retirement benefit obligations analysis			
RIN analysis			
Opex	Capex	Description	Statutory financial report analysis
TOPEX0201B	TOPEX0207B	Opening balance	Net defined benefit liability/(asset) at start of year
TOPEX0202B	TOPEX0208B	Increases to the provision	Current service cost Interest cost Expected return on plan assets Interest income Contributions by scheme participants Benefits paid Taxes & premiums paid
TOPEX0203B	TOPEX0209B	Amounts used (that is, incurred and charged against the provision) during the period	Employer contributions
TOPEX0204B	TOPEX0210B	Unused amounts reversed during the period	N/A
TOPEX0205B	TOPEX0211B	The increase during the period in the discounted amount arising from the passage of time and the effect of any change in the discount rate.	Actuarial gains/(losses) demographic assumption changes Actuarial gains/(losses) financial assumption changes Fair value actuarial gains/(losses) Present value actuarial gains/(losses) Transfers in
TOPEX0206B	TOPEX0212B	Closing balance	Net defined benefit liability/(asset) at end of year

Increase in the retirement benefit obligation provision reflects movements that have been included within historical opex reported.

Amounts used reflect payments by ElectraNet in relation to the retirement benefit obligation.

The increase during the period in the discounted amount arising from the passage of time and the effect of any change in the discount rate includes items presented in other comprehensive income within the Statutory Financial Reports which are not included in reported historical opex.

Each year ElectraNet calculates the proportion of cost applicable to prescribed network services. This proportion varies each year. The amounts tabled are the balances and movements applicable to prescribed network services.

Given the proportion of prescribed network services to total network services changes each year, an adjustment is made to the “increases to provisions’ row to ensure the opening balance of the current year is equal to the closing balance of the preceding year. The adjustment is made up of the difference in the current and prior year’s prescribed network services percentage, multiplied by the closing value of the preceding year.

Self-insurance

This provision has been reported from 2008/09 onwards and is reported only in each year’s Regulatory Financial Report.

Self-insurance is only applicable to opex and therefore no apportionment has been applied between capex and opex.

3.2.3 Basis of estimation

Estimates and judgements are required when compiling the underlying data within the relevant statutory financial reports for leave and retirement benefit obligation provisions. These are made in accordance with the relevant Australian Accounting Standards.

Estimates and judgements may be required in accordance with the Information Guidelines when compiling the underlying data for self-insurance provisions disclosed in the relevant regulatory financial reports.

ElectraNet has calculated a capex and opex split for provisions for the years 2011 to 2013. The cost allocation is derived from the ElectraNet cost accounting system in which labour activities are allocated to capex and opex cost collectors. Using standard SAP report S_ALR_87013611, ElectraNet has analysed primary costs by activity postings to capex and opex, to derive the annual apportionment.

Prior to 2011 ElectraNet operated a less detailed costing system and therefore the same estimation methodology cannot be applied. For the years 2006 to 2010 a 50/50 split has been assumed which was applied during the last revenue reset determination for 2009 to 2013.

3.2.4 Changes to accounting policies

Effective 1 July 2011, ElectraNet adopted the revised *AASB 119 Employee Benefits* standard as issued by the Australian Accounting Standards Board within their Statutory Financial Reports.

The revised accounting standard changed the way retirement benefit obligations were measured and disclosed.

ElectraNet obtained actuary reports which measured the impact of the change in the accounting standard for 2011 & 2012. The impact of these changes is summarised in

Figure 3-2: Retirement benefit obligations **analysis** on the following page:

Figure 3-2: Retirement benefit obligations analysis

TOPEX02B Retirement benefit obligations analysis		With AASB119 revision	Before AASB119 revision		With AASB119 revision	Before AASB119 revision	
RIN analysis		Reported in RIN	Restated	Change	Restated	Reported in RIN	Change
Opex	Description	2012	2012	2012	2011	2011	2011
TOPEX0201B	Opening balance	7,118	7,118	0	8,320	8,320	0
TOPEX0202B	Increases to the provision	871	496	375	1,078	647	431
TOPEX0203B	Amounts used (that is, incurred and charged against the provision) during the period	(1,011)	(1,011)	0	(839)	(839)	0
TOPEX0204B	Unused amounts reversed during the period	0	0	0	0	0	0
TOPEX0205B	The increase during the period in the discounted amount arising from the passage of time and the effect of any change in the discount rate.	8,671	9,046	(375)	(843)	(412)	(431)
TOPEX0206B	Closing balance	15,649	15,649	0	7,716	7,716	0

		Reported in RIN	Restated	Change	Restated	Reported in RIN	Change
Capex	Description	2012	2012	2012	2011	2011	2011
TOPEX0207B	Opening balance	8,424	8,424	0	8,438	8,438	0
TOPEX0208B	Increases to the provision	1,031	587	444	1,094	657	437
TOPEX0209B	Amounts used (that is, incurred and charged against the provision) during the period	(1,197)	(1,197)	0	(851)	(851)	0
TOPEX0210B	Unused amounts reversed during the period	0	0	0	0	0	0
TOPEX0211B	The increase during the period in the discounted amount arising from the passage of time and the effect of any change in the discount rate.	10,263	10,707	(444)	(855)	(418)	(437)
TOPEX0212B	Closing balance	18,521	18,521	0	7,826	7,826	0

4. Assets (RAB)

4.1 Regulatory asset base values

Table 4.1 in the template is the aggregate of the Asset value roll forward information in Table 4.2.

For details of the data requirement, source, methodology, basis of estimation and changes to accounting policies, refer to the details below within 4.2 Asset value roll forward.

4.2 Asset value roll forward

4.2.1 Data requirement

ElectraNet must report RAB values in accordance with the standard approach per the RIN and the Assets (RAB) Financial Reporting Framework.

RAB Financial Information must be allocated from, and reconcile to, the 'as commissioned' RAB. RAB Financial Information must reconcile to:

- For years prior to any AER determination of RAB values, determinations made in relation to RAB values made by the previous jurisdictional regulator.
- Any decision that the AER has made in relation to RAB values unless that decision incorporates forecasts (for example, for the last year of the previous regulatory period) in which case those forecast values should be replaced with actual values where possible. Actual values must reconcile to amounts reported in the response to the Information Guidelines.
- For years where the AER has not made a decision on values for the RAB, RAB values must be prepared in accordance with the RAB Framework. In this circumstance, actual additions (recognised in the RAB) and disposals must reconcile to amounts reported in the response to the Information Guidelines.

4.2.2 Data source

The information provided by ElectraNet is sourced from the Roll Forward Models (RFM) for the 2003-2008 and 2008-2013 revenue reset periods which have previously been submitted to the AER as part of their revenue determinations.

Forecast values for the year ended 30 June 2013 have been replaced with actual commissioned values that were used in determining the incurred additions in the regulatory financial report submitted to the AER for the period then ended.

Forecast values for the year ended 30 June 2008 have been replaced with actual values and adjusted for during the 30 June 2013 regulatory year as reported in the RFM 2008 – 2013 submitted to the AER.

4.2.3 Methodology

ElectraNet has extracted the RFM information for opening balances, additions, disposals, inflation, depreciation and closing balances directly from the 2003-2008 and 2008-2013 RFMs, and the values used in preparing the regulatory financial report for the year ended 30 June 2013

ElectraNet has mapped the regulatory asset classes shown in the RFM to the RIN categories as shown in **Table 4-1: Mapping regulated asset classes to RIN asset categories** below:

Table 4-1: Mapping regulated asset classes to RIN asset categories

RIN asset category	Regulated asset class
Overhead transmission assets	Transmission lines - Overhead Refurbishment
Underground transmission assets	Transmission lines - Underground
Transmission switchyards, substations	Substation Establishment Substation Primary Plant Refurbishment Projects 2008-2013 Land - Substations Accelerated Depreciation
Easements	Easements
Other assets with long lives	Substation Secondary Systems - Electromechanical Substation Secondary Systems - Electronic Substation Demountable Buildings Substation Fences Communications - Civil Communications - Other Commercial Buildings Land - Other long life assets Office furniture, movable plant, and misc Capital Work in Progress Equity Raising Cost - 2003 Opening RAB and 2003-08 capex Equity Raising Cost 2013-2018
Other assets with short lives	Network Switching Centres Computers, software, and office machines

The classes of assets previously reported in the 2003-2008 and 2008-2013 RFMs, and the regulatory financial report for the year ended 30 June 2013 are consistent with the RIN asset categories above, except for Land.

Split of land to satisfy the RIN asset categories

The RIN requires Land to be split by, Land – Substations and Land – Other long life assets.

Substation land is included in the “Transmission switchyards and substations” RIN asset category. Other land is included in the “Other assets with long lives” RIN asset category. Other land comprises commercial land for offices and parking, in addition to strategic land purchased in advance of provision of substation assets.

ElectraNet have allocated each parcel of land per ElectraNet’s SAP fixed asset register between the two classes based on the actual land use.

This is the most accurate basis of splitting land values between the RIN asset categories given it is based on the actual use of land – i.e. for substations or other purposes. ElectraNet have not adopted the standard approach per the RIN Instructions and Definitions document as the depreciated replacement cost estimates are not applicable to land, and there is insufficient information in the RAB to do so.

4.2.4 Basis of estimation

In some instances, a parcel of land per ElectraNet's fixed asset register comprises substation and other commercial land. Therefore an apportionment is required in order to allocate the value of the parcel of land between the two RIN asset categories. This has been performed based on the land area and its use per area apportionment from survey or the ElectraNet geographical information system (GIS).

This is the best available estimate as it relies on historical accounting records for the book value of the total parcel of land. Two apportionments rely on titles and independent land survey information. The third apportionment relies on the land title and a GIS area calculation.

ElectraNet has calculated an apportionment percentage of total land additions from its fixed asset register between "Transmission switchyards and substations" and "Other assets with long lives". The apportionment percentage is applied to the RFM land additions. Due to the "Difference Between Actual and Forecast Net Capex" and the "Return on Difference – Net Capex" relating to 2008 which are adjusted for in 2013 year within the RFM, the calculation allows for the land asset additions and related CPI inflation for the 2008 year to be adjusted out of the 2008 to 2012 years and to be added into the 2013 land asset category in the RAB. These 2008 land additions were included in the "Difference Between Actual and Forecast Net Capex" in the 2008-2013 RFM. The related "Return on Difference – Net Capex" has also been apportioned between "Transmission switchyards and substations" and "Other assets with long lives" and adjusted in the 2013 year.

A minor adjustment is required to the additions apportionment to reconcile to the closing balance split of land between "Transmission switchyards and substations" and "Other assets with long lives". This adjustment is required to ensure the closing balance of land apportioned to "Transmission switchyards and substations" and "Other assets with long lives" for each year is equal to the closing balances derived by adding through opening balance, additions, disposals and regulatory depreciation.

The land values apportioned to the "Transmission switchyards and substations" and "Other assets with long lives" categories are shown in

Table 4-2: Land value **apportionment** on the following page:

Table 4-2: Land value apportionment

Closing value (\$'000)	2006	2007	2008	2009	2010	2011	2012	2013
Land - transmission switchyards & substations	9,629	9,934	10,502	10,867	11,625	11,954	12,354	24,783
Land - other assets with long lives	1,138	1,174	1,241	1,329	1,948	667	3,386	27,440
Land total	10,767	11,108	11,743	12,196	13,573	12,621	15,739	52,223
Substation land %	89.4%	89.4%	89.4%	89.1%	85.6%	94.7%	78.5%	47.5%

4.2.5 Changes to accounting policies

There are no changes to accounting policies which impact ElectraNet's RAB values.

4.3 Total disaggregated RAB asset values

4.3.1 Data requirement

ElectraNet must report average RAB Asset values that have been disaggregated into the categories in this table. These must be calculated as the average of the opening and closing RAB values for the relevant Regulatory Year for each of the RAB Asset categories and should be directly reconcilable to the opening and closing values in Table 4.2 per the template for the relevant categories.

The information provided by ElectraNet is sourced from the Roll Forward Models for the 2003-2008 and 2008-2013 revenue reset periods.

4.3.2 Data source

ElectraNet has sourced the opening and closing balances for each of the RIN asset categories as reported in table 4.2 of the data template, asset value roll forward.

4.3.3 Methodology

ElectraNet has averaged the opening and closing balances for each of the RIN asset categories in table 4.2 of the data template, asset value roll forward, in accordance with the RIN requirements.

4.3.4 Basis of estimation

No estimation has been applied to calculate the data presented in table 4.3 of the data template.

4.3.5 Changes to accounting policies

There are no changes to accounting policies which impact ElectraNet's RAB values.

4.4 Asset lives

4.4.1 Data requirement

In relation to Table 4.4.1 'Asset Lives – estimated service life of new assets' and Table 4.4.2 'Asset lives – estimated residual service life', ElectraNet must report asset lives for all RAB Assets in accordance with the category definitions provided in chapter 9 in the RIN.

The information provided by ElectraNet is sourced from the detailed asset records to which regulated service lives have been applied and remaining lives calculated.

4.4.2 Data source

ElectraNet has extracted detailed asset information from its SAP fixed asset register.

Regulatory asset lives used are approved by the AER.

4.4.3 Methodology

ElectraNet has used the detailed asset information contained in its fixed asset register for these calculations. This allows a standard basis of calculation for service and remaining lives whereas the RAB contains an averaged remaining service life for each asset class, which would allow a service life calculation but not an average remaining life calculation.

ElectraNet has mapped its asset register asset classes to RFM asset classes and then to the RIN asset categories.

Work in progress assets are excluded from the calculations. These assets are not complete and their cost is not yet allocated to asset classes in ElectraNet's fixed asset register.

Land and easement assets are excluded from the calculations, because they do not have a finite life.

Equity raising costs and accelerated depreciation costs are excluded. These assets are not physical assets with a service life and are not incorporated in ElectraNet's fixed asset register.

The RFM accelerated depreciation asset class is used for reclassifying assets which are intended to be replaced in the next regulatory period (2013-2018). This does not reflect the historical service or residual service lives of those assets and consequently these assets are included in their original asset class.

Table 4.4.1

Regulated asset class service lives have been applied to individual assets. For each financial year covered by the RIN, the service years are multiplied by the asset net book values (NBV) to calculate \$_{service_years} for each asset. For each RIN asset category, the \$_{service_years} are aggregated then divided by the aggregated NBV, to give an average service life in years.

Table 4.4.2

Regulated asset class service lives have been applied to individual assets. For each year covered by the RIN, the remaining regulated life of each individual asset is calculated with reference to the asset register acquisition date and the RFM asset class service life. For each financial year the remaining lives in years are multiplied by the asset net book values (NBV) to calculate \$remaining_years for each asset. For each RIN asset category, the \$remaining_years are aggregated then divided by the aggregated NBV, to give an average remaining life in years.

4.4.4 Basis of estimation

ElectraNet has used the regulated lives per the RAB asset classes. No estimation is involved.

4.4.5 Changes to accounting policies

There are no changes to accounting policies which impact ElectraNet's asset lives.

5. Operational Data

5.1 Energy delivery (TOPED0101-TOPED0103)

5.1.1 Data requirement

According to Economic Benchmarking RIN for Transmission Network Services Provider Instructions and Definitions November 2013 Chapter 5 Section 5.1 ElectraNet are required to report the amount of electricity transported through ElectraNet's network in the relevant Regulatory Year (measured in GWh). This must be as metered at the downstream settlement location rather than the import location to ElectraNet's network. Energy delivered must be actual energy delivered data, unless this is unavailable.

Energy delivery 'To other connected transmission networks' (TOPED0101) must include both imported and exported energy.

Where energy delivery 'To directly connected end-users' (TOPED0103) is confidential, in the public version of the RIN Templates, cells associated with this Variable should be blacked out and energy delivered that would otherwise be reported as part of TOPED0103 must be included in energy delivered 'To Distribution networks' (TOPED0102).

5.1.2 Data source and methodology

National Grid Metering (NGM) data on which the NEM financial settlement is based has been used. This has been previously Quality Controlled by the Metering Data Agent (meter reader) and by the Australian Energy Market Operator (AEMO) prior to use in NEM settlement. It is also checked weekly by ElectraNet's internal processes for reasonableness of Transmission Loss Factor.

NGM Data is extracted from the ElectraNet Oracle database by classification of:

- Generators;
- Interconnectors; and
- Load connections: Wholesale (directly connected end-users) and Distribution.

The extracted data is used to calculate the required RIN parameters on yearly basis via appropriate formulae, following Chapter 9 Definitions of the RIN Instructions and Definitions wherever appropriate.

5.1.3 Basis of estimation

N/A

5.1.4 Changes to accounting policies

N/A – Information reported within 5.1 of the data template relates to non-financial information.

5.2 Connection point numbers

5.2.1 Data requirement

Connection point numbers must be reported as the average of connection point numbers in the relevant Regulatory Year under system normal conditions. The average is calculated as the average of the number of connection points on the first day of the Regulatory Year and on the last day of the Regulatory Year.

ElectraNet must report the number of entry and exit points at each voltage level. ElectraNet must add additional rows as necessary to Table 5.2 to report each voltage level for entry or exit points.

5.2.2 Data source and methodology

Information on all ElectraNet substations was extracted from ElectraNet's SAP Network Statistics report to establish functional location, name, substation start-up date and voltage of the.

System switching diagrams (SSDs) were downloaded from ElectraNet's drawing management system, SPF and the number of unique customers was identified on the SSDs to determine Entry and Exit connection points.

The Network Statistics report was used to identify the SSDs to ensure all substations were captured.

Where multiple voltages for entry and exits exist, new records were manually added and any additional commentary prepared based on the review of single line diagrams.

5.2.3 Basis of estimation

For the basis of this estimation, Connection Point is defined as each unique customer. In the case where a substation has transformers feeding different subsystems, each subsystem has been counted as a separate connection point.

The connection point count includes both regulated and unregulated connection points.

Connection point voltage has been taken to mean the voltage at the high side of the connection transformer, that is, the voltage seen on the ElectraNet side or if applicable the voltage of the line or cable where it is the connection between customers or subsystems.

ElectraNet notes that an alternate basis of estimation would be to count the number of network metering identifiers which are at the physical point of connection to customers. This would result in a materially higher number than the methodology chosen. We have been guided in our choice of estimation methodology by the by the list of connection points in the South Australian Electricity Transmission Code.

Consistent with the email correspondence provided by Andrew Ley from the AER on 12 February 2014, interconnectors have been treated as an exit point.

5.2.4 Changes to accounting policies

N/A – Information reported within 5.2 of the data template relates to non-financial information.

5.3 System demand (TOPSD0101-TOPSD0308)

5.3.1 Annual system maximum demand characteristics (TOPSD0101-TOPSD0206)

5.3.1.1 Data requirement

Table 5.3 of the data template must be completed in accordance with the Economic Benchmarking RIN for Transmission Network Services Provider Instructions and Definitions November 2013 Chapter 9. ElectraNet must provide inputs for these cells if it calculates historical Weather Adjusted Maximum Demands.

Where ElectraNet does not calculate Weather Adjusted Maximum Demands it may estimate the historical Weather Adjusted data or shade the cells black. For Subsequent Regulatory Years ElectraNet will be required to provide Weather Adjusted Maximum Demand on an ongoing basis in accordance with best regulatory practice weather adjustment methodologies.

5.3.1.2 Data source and methodology

National Grid Metering (NGM) data on which the NEM financial settlement is based has been used. This has been previously Quality Controlled by the Metering Data Agent (meter reader) and by AEMO prior to use in NEM settlement. It is also checked weekly by ElectraNet's internal processes for reasonableness of Transmission Loss Factor.

NGM Data is extracted from the ElectraNet Oracle by classification of:

- Interconnectors; and
- Load connections: Wholesale (directly connected end-users) and Distribution.

The extracted data is used to calculate the required RIN parameters via appropriate formulae, following Chapter 9 Definitions of the RIN Instructions and Definitions wherever appropriate.

Both calculations on National Metering Identifier level and Substation level have been considered and we believed that the Substation level base calculation satisfies the intent of the requirement.

The interconnector contribution to maximum MW demand has been included only for those half hours when the interconnector is acting as a load (export to Victoria).

The interconnector contribution to maximum MVA demand has been included only for those half hours when the interconnector is acting as a load (MW half hour exporting to Victoria).

5.3.1.3 Basis of estimation

TOPSD0201 and TOPSD0204

Six of the 212 ElectraNet connection points do not have the kVAR values metered. These are minor connection points in terms of energy consumed. The impact of this lack of actual metered data on the calculation of MVA has been estimated to be of the order of 0.5%. The impact of this on MVA is operationally minimal. As such and considering the accuracy of any estimation method no estimation has been made on these missing KVAR values.

5.3.1.4 Changes to accounting policies

N/A – Information reported within 5.3 of the data template relates to non-financial information.

5.3.2 Power factor (TOPSD0301-TOPSD0308)

5.3.2.1 Data requirement

ElectraNet must report the power factor to allow for conversion between MVA and MW measures for each voltage. If both MVA and MW demand for a network are available then the power factor is the total MW divided by the total MVA. ElectraNet must provide a power factor for each voltage level and for the network as a whole. The average overall power factor conversion (TOPSD0301) is the total MW divided by the total MVA.

If either the MW or MVA measure is unavailable the average power factor conversion can be calculated as an approximation based on best engineering estimates.

When completing the Templates for Regulatory Years subsequent to the 2013 Regulatory Year, if ElectraNet can provide Actual Information for Table 5.3.3 it must do so; otherwise ElectraNet must provide estimated information.

5.3.2.2 Data source and methodology

Data source for this section is from ElectraNet's Subload database, this contains 30 minute instantaneous SCADA figures. This is used to extract voltage, real power and reactive power.

The data extracted was for every Line that reports either a voltage or real power or reactive power for that day.

The data extracted does not differentiate between regulatory and non-regulatory lines, or the owner of those lines. Therefore, the data may include some SAPN 66kV or BHP 275kV that we have SCADA information for. This is arguably a more accurate picture of the network.

The voltage is shown for the first half hour of each day and this is used for the classification of the line. As system voltage may vary, ranges have been used to determine the nominal voltage of the line. These are:

- Between 50-100 kV = 66kV
- Between 100-200 kV = 132kV

- Between 200-350 kV = 275 kV
- Between 50-350 kV = overall network

As it is the voltage at the first half hour that determines classification if the line is off (i.e. zero) or low voltage (<50kV) this day of calculated power factors for that line is excluded.

There is some small chance of misclassifying a higher voltage line during de-energisation, if the snapshot (first half hour of the day) catches during the voltage going down.

This query will also capture the metering (line CT's) at both ends of a line.

Power factor for a line can have 4 quadrants of operation with lines usually measured at both ends. Convention being that positive is outwards from the bus end and negative is towards the bus, with P being real power and Q being reactive power.

- P+,Q+ = lagging
- P-,Q- = lagging
- P+,Q- = leading
- P-,Q+ = leading

Power factor = P / S (definition as per Instructions) where $S = \sqrt{P^2 + Q^2}$.

If power factor is lagging give a negative sign to P / S (usually dimensionless) and if power factor is leading give a positive sign to P / S (usually dimensionless) i.e. + = leading and - = lagging.

In an excel spreadsheet, unity power factor is 1 and to do a proper average of a line that may have reactive power swinging back and forth we need to average around 1, hence we used the following formulas below:

```
=IF(E3=0,"NA",IF(E3="null","NA",IF(E3=-1,1,IF(E3=1,1,E3))))
```

The formula above normalises the -1 figure and removes 0's and nulls from the average.

```
=IF(BB3="NA","NA",IF(BB3<0,BB3*-1,1+(1-BB3)))
```

The formula above creates a power factor range centred on 1 (unity) if it is greater than 1 = leading, if it is < 1 = lagging. If the power factor is leading this number must be subtracted from 1 and then added back to 1 as a power factor can only range between zero and one.

An average is calculated for all the power factors (every 30min) for that line for a day, then an average determined from that daily average power factor for all lines within the voltage range.

This is the figure ElectraNet have reported in the data template. This number will not reconcile with total MW divided by the total MVA (TOPSD0101/ TOPSD0201) as the AER definitions and instructions specifically ask for power factor on lines whereas TOPS0101 and TOPS0201 relate to loads.

5.3.2.3 Basis of estimation

N/A

5.3.2.4 Changes to accounting policies

N/A – Information reported within 5.3.3 of the data template relates to non-financial information.

6. Physical Assets

6.1 Transmission system capacities variables – Overhead Circuit Length (TPA0101-TPA06)

6.1.1 Data requirement

ElectraNet is required to report overhead network length of circuit at each voltage level. The network length of circuit is the circuit length (measured in kilometres) of lines in service (the total length of lines including interconnectors, backbones and spurs). A double circuit line counts as twice the length. Length does not take into account vertical components such as sag.

6.1.2 Data source

The primary source used to report overhead circuit length and voltage is ElectraNet's Line Schedule database, which contains structure and span information. The information sourced from the database included overhead span lengths, circuits, voltage and section build dates. This is a live database and therefore data downloaded reflects the network status at that moment in time.

SAP, ElectraNet's integrated business and asset management system was used to provide a list of all ElectraNet built sections historically for the network. This was required to provide historical structural and span information and also the date of any lines removed/scrapped.

The Network Statistics Report from the ElectraNet Grazer asset management reporting tool provided an additional source of asset information as well providing a data cross-check for overhead span lengths and voltage by built section including for removed and scrapped lines.

The list of built sections extracted from SAP was reconciled against the built section list in the Line Schedules database and with the Network Statistics Report. This was to ensure only regulated lines were included in the line asset list and to identify what lines were decommissioned and when.

Note that to determine circuit length, Line Schedules data was used.

From the reconciled asset list, line length for each built section at each voltage was then summed to determine total overhead network length of circuit for each voltage type.

6.1.3 Basis of estimation

Some assumptions were made based on the available data to estimate overhead circuit length including:

Date of build

In some instances, the structures and spans in the line schedules did not include start-up/build dates due to some inconsistencies with the data analysed. If these dates were

unavailable, the date was estimated on the one of the basis below depending on availability of information:

1. The date as found in line schedules which is consistent with rest of the built section;
 - (a) By definition, a built section is a consistent section of line built at the same time
2. The SAP start-up date;
 - (a) Although SAP is not ElectraNet's primary database for line details for some items it may include start-up dates.
3. The terminal substation start-up date from SAP.
 - (a) Generally a line is built to reach a substation (certainly for a radial)

As identified in the previous section, the preferred approach if applicable was to use the date found in the Line Schedules data as this information is actively maintained.

Length of circuits within a substation

Consistent with ElectraNet's internal procedures for determining circuit length, information on the length of circuits within a substation is not currently maintained. These have been excluded from the data presented as ElectraNet defines a transmission line as from the substation gantry structure to another substation gantry structure.

Consistent with the AER's data requirement, double circuit lines were counted as twice the length.

The lengths reported in the data templates are in kilometres and are classified by the kV ratings and year.

De-energised lines

De-energised line circuit lengths are included in the provided figures. This is as these lines can be returned to service quickly with minor works and these sections are still maintained.

Decommissioned lines

For scrapped and decommissioned lines the SAP decommissioning date (changed on date) is used for date of line removal and for length and spans of removed lines. For lines removed, old archived historical line schedules were used to determine line length.

6.1.4 Changes to accounting policies

N/A – Information reported within 6.1.1 of the data template relates to non-financial information.

6.2 Underground cable circuit length at each voltage (TPA0201 – TPA0207)

6.2.1 Data requirement

ElectraNet is required to report underground cable circuit length at each voltage level. The underground cable circuit length is the circuit length (measured in kilometres) of lines in service (the total length of lines including interconnectors, backbones and spurs).

6.2.2 Data source and methodology

The primary source used to report underground circuit length and voltage is SAP, ElectraNet's integrated business and asset management system. This database provided a list of all ElectraNet underground built sections over the history of the network, cable circuit length and voltage and section build date. The database also provided the date of any lines removed or scrapped.

Note that unlike for overhead circuit lengths, for underground cables there is no line schedules database as there are no spans and structures. Therefore it was determined that the SAP data available provides the most reliable basis for determining underground circuit length, voltage and asset start-up date.

Google Earth and information from the Network Stats Report was used to establish circuit length for 66kV cable sections.

All other assumptions regarding underground circuit length were consistent with the methodology (only regulated etc.) applied for overhead circuit length described in section 6.1 of this report.

6.2.3 Basis of estimation

Length of circuits within a substation

The length of circuit within substations is not maintained. These have been excluded from the data presented as ElectraNet defines a transmission cable as from substation cable bushing to another substation cable bushing. For 66kV only the end point is classed as the substation fence.

The lengths reported in the data templates are in kilometres and are classified by the kV ratings and year.

66kV Cables

66kV cables have been included based on Google Earth measured lengths, as there is no available data in either the Lines Schedules database or SAP.

6.2.4 Changes to accounting policies

N/A – Information reported within 6.1.2 of the data template relates to non-financial information.

6.3 Estimated overhead network weighted average MVA capacity by Voltage class (TPA0301 – TPA0307)

6.3.1 Data requirement

ElectraNet must provide estimated typical or weighted average capacities for each of the listed voltage classes under normal circumstances taking account of limits imposed by thermal or by voltage drop considerations as relevant.

This information will be used to calculate an overall MVA x km 'carrying capacity' for each voltage class under normal circumstances. ElectraNet is required to provide summer Maximum Demands for summer peaking assets and winter Maximum Demands for winter peaking assets. If ElectraNet's peak has changed from winter to summer (or vice versa) over the time period, winter ratings should be applied for those years where there was a winter peak and summer ratings for those years where there were summer peaks.

Where circuits travel both overhead and underground and the capacity of the overhead and underground components is not available separately, ElectraNet may split the circuit capacity by the ratio of the network that is overhead and underground to form estimates of the overhead capacity and underground capacity components.

6.3.2 Data source and methodology

Base information including circuit length, voltage, energisation date and regulated/unregulated status were derived from the Network Statistics Report that extracts data from SAP.

ElectraNet used the internal Plant and Line Rating database as the source to determine the seasonal thermal normal ratings for all regulated lines.

Where information was not available, usually for decommissioned lines, the historical ratings as per the AEMO ratings workbooks was used as a basis for seasonal thermal normal ratings. If this information was not available a rating was applied that was consistent with those for a line of similar conductor type and design temperature.

All other assumptions in this section are consistent with section 6.1.1 of the data template unless otherwise stated in the basis of estimate in the following section.

6.3.3 Basis of estimation

ElectraNet has provided weighted average capacity by distance. Only summer overhead network weighted Average MVA capacity by voltage has been reported, as ElectraNet is a summer peak demand network.

In the event that the maximum rating achievable at any time during the year was used, consistent with the winter rating, a materially higher number would result.

In preparing weighted average MVA, ElectraNet assumed that all uprating's are from the 1st January each year if no better information is available.

Ratings have been prepared on a per circuit basis. Therefore if a single built section is changed this does not change the commissioning date (commissioning date is defined as the oldest built section in the circuit) or the ratings for the line (limited by lowest rated built section, if this is changed will be captured as an uprating).

There are some small sections of 66 kV which is underground as well as overhead, but the underground component is immaterial and therefore all of the circuit is assumed to be overhead.

Where information was not available, usually for older lines, the historical ratings as per the AEMO ratings workbooks was used as a basis for seasonal thermal normal ratings. If this information was not available a rating was applied that was consistent with those for a line of similar conductor type and design temperature.

De-energised lines were included if the line has a rating in the Plant and Line Rating database.

In some instances, the Network Statistics Report did not include start-up/build date or length of the circuit. This was mainly due to some data lookup errors to do with line tees where there may be different rated circuits that all report to the same feeder number. If these are unavailable, ratings were estimated using either the Line Schedules database or within SAP.

The preferred approach if applicable was to use the data found in the Line Schedules database as opposed to SAP as this information is actively maintained.

6.3.4 Changes to accounting policies

N/A – Information reported within 6.1.3 of the data template relates to non-financial information.

6.4 Estimated underground network weighted average MVA capacity by Voltage class (TPA0401 – TPA0407)

6.4.1 Data requirements

ElectraNet is required to provide estimated typical or weighted average capacities for each of the listed voltage classes under normal circumstances taking account of limits imposed by thermal or by voltage drop considerations as relevant.

This information will be used to calculate an overall MVA x km 'carrying capacity' for each voltage class under normal circumstances. ElectraNet is required to provide summer Maximum Demands for summer peaking assets and winter Maximum Demands for winter peaking assets. If a ElectraNet's peak has changed from winter to summer (or vice versa) over the time period, winter ratings should be applied for those years where there was a winter peak and summer ratings for those years where there were summer peaks.

Where circuits travel both overhead and underground and the capacity of the overhead and underground components is not available separately, ElectraNet may split the circuit capacity by the ratio of the network that is overhead and underground to form estimates of the overhead capacity and underground capacity components.

From the 2015 Regulatory Year onwards ElectraNet is required to report actual overhead and underground capacity.

6.4.2 Data source and methodology

As described in the previous section, base information including circuit length, voltage, energisation date and regulated/unregulated status were derived from ElectraNet's Network Statistics Report. ElectraNet used the internal Plant and Line Rating database as the source to determine ratings for all regulated underground lines.

All other assumptions in this section are consistent with those used in 6.1.2 and 6.1.3 of the data template unless otherwise stated in the basis of estimate.

6.4.3 Basis of estimation

There are some small sections of 66 kV which is underground as well as overhead, but the underground component is immaterial and therefore all of the circuit is assumed to be overhead. This results in a zero for variable TPA0406.

Note that underground cables do not have seasonal ratings so only normal ratings have been reported.

6.4.4 Changes to accounting policies

N/A – Information reported within 6.1.4 of the data template relates to non-financial information.

6.5 Installed transmission system transformer capacity (TPA0501 – TPA0505)

6.5.1 Data requirements

ElectraNet must report transformer capacity involved in transformation levels indicated within the table. For the purposes of these measures the transmission system includes transformers, overhead and underground lines and cables in service that serve a transmission function. The transformer capacities Variables must be reported inclusive of Cold Spare Capacity.

For each level, report the summation of normal assigned continuous capacity or rating (with forced cooling or other capacity improving factors included if relevant). Also include capacity of tertiary windings as relevant. Assigned rating must be, if available, the rating determined from results of temperature rise calculations from testing or otherwise the nameplate rating. Do not include step-up transformers at generation connection location.

For category the 'Transformer Capacity for Directly Connected End-Users Owned by the End-User' (TPA0504), report transformer capacity at connection point to directly connected end user where the capacity is owned by the directly connected end user. Where ElectraNet knows what the directly connected customer's transformer capacity is, it should include that information. Where this information is not available to ElectraNet, a summation of non-coincident individual Maximum Demands of each such directly connected customer whenever they occur (i.e. the summation of a single annual Maximum Demand for each customer) is used as a proxy for capacity within the

customer's installation. The Variable should be the sum of the direct information where this is available and of the proxy MVA measure where the direct measure is not available.

Where ElectraNet utilises installed transformer capacity which is not included in the other categories within this table, report this transformer capacity against 'other installed transformer capacity' (TPA0506) and specify its type.

Interconnector Capacity

This is ElectraNet's Network thermal capacity available for network interconnector purposes to another network – i.e. regarding other network as an export capacity required on the source network.

ElectraNet has provided a data response consistent with the requirement described in the AER's Instructions and Definitions. However, it should be noted that NSPs generally refer to Interconnector capacity on the basis of MWs (real power flow), that is, the power that is capable of doing actual work. Murraylink (V_SA MNSP1) interconnector is a DC interconnector and MVA is only really useful in the context of AC power. Therefore for the purpose of providing capacity data for Murraylink, ElectraNet have assumed MW = MVA assuming the power factor is unity.

6.5.2 Data source and methodology

TPA0501-04

Capacities provided are normal continuous ratings (with forced cooling if available (ODAF)) from nameplate.

The primary source used for transformer capacity information was SAP, ElectraNet's integrated Business and Asset Management System. This database provided all transformer (inc. spares) sizes and dates of energisation and where applicable decommissioning. Note that figures are given as asserts in commission as at 30 June of the reporting year.

ElectraNet's System Switching Diagrams were used to determine if the substation is a transmission transformer substation, if the customer is the DNSP or not, if ElectraNet or a direct connect customer own the transformer and the size of non ElectraNet (customer) Transformers.

The ElectraNet Networks report was used to establish the list of ElectraNet substations and their energisation dates for installed transmission system transformer capacity.

TPA0505 Interconnector capacity

ElectraNet Transmission-Annual Planning Reports was used to source interconnector transfer capacities each year. This is a publicly available document that ElectraNet is required to produce annually under the Rules.

The given figure for the variable TPA0505 is the thermal capacity information for the two interconnectors that connect South Australia to the rest of the NEM.

This figure is comprised of 220 MW at the receiving end from the Murraylink interconnector, this comes from information from the Asset owner, APA Group. The capacity is limited by the power electronics within the HVDC link when working as an inverter.

This figure is comprised of 460 MW from the South East Interconnector (also known as Heywood Interconnector). This information comes from the Asset owner and planner, SPAusnet and AEMO. The capacity is limited by the two Heywood 500/275 kV transformers that are rated at 525 MVA (short term). These transformers set the limit for the interconnector at 460 MW bi-directionally. This is an N-1 capacity.

Note that many other factors can limit the interconnector flow to less than the thermal capacity quoted, including:

- Thermal limitations and voltage stability in the South Australian Network;
- Thermal limitations and transient stability in the Victorian Network; and
- Oscillatory stability limits.

6.5.3 Basis of estimation

To convert MW measure to MVA in relation to Interconnector capacity, ElectraNet assumed $MVA = MW$ assuming power factor is unity.

Station supply (auxiliaries) transformers are excluded as they do not perform a transmission function. SVC transformers are included as transmission transformers.

As the energisation dates and sizes of non-ElectraNet transformers are not known, ElectraNet has assumed the energisation date (from ElectraNet Network Report) of the associated substation or line (as per Line schedules) as a proxy and size as per the Substation Switching Diagrams as this is the best available information.

Tertiary winding capacity is not considered relevant as this capacity is already captured in the nameplate primary to secondary capacity. Capacity taken from the tertiary is normally subtracted from the primary to secondary capacity.

ElectraNet has provided the size of directly connected transformers that are owned by the direct connect customer; this information is based on reporting from the customer, and may be confidential. The onus is on the customer to notify ElectraNet of any changes in size.

For the variable TPA0503, Transformer capacity for directly connected end-users owned by the TNSP, the input includes both regulated and unregulated transformers.

For variables TPA0503, Transformer capacity for directly connected end-users owned by the TNSP and TPA0504, Transformer capacity for directly connected end-users owned by the end-user, generator step up transformers are included. Power station house supply (auxiliaries) transformers are excluded.

For variable TPA0501, Transmission substations and TPA0502, Terminal points to DNSP systems, spare transformers are included.

For variable TPA0504, Transformer capacity for directly connected end–users owned by the end–user only end user, transformers at the boundary between networks is counted (not transformers deeper within their networks)

For all variables, regulators are excluded; this is as the capacity of the fixed tap transformer is captured and this is the capacity of the flow path.

6.5.4 Changes to accounting policies

N/A – Information reported within 6.1.5 of the data response relates to non-financial information.

6.6 Cold Spare capacity (TPA06)

6.6.1 Data requirements

Report the capacity of spare transformers owned by ElectraNet but not currently in use.

6.6.2 Data source and methodology

The primary source used to report cold spare capacity is SAP, ElectraNet’s integrated business and asset management system. This provided all transformer (inc. spares) sizes and energisation and decommissioning dates. Regulators have been excluded.

In SAP search query IH06 was used on equipment functional location “TSP” (transmission spare) with functional location description “TF”. The functional locations identified were then searched on to identify the transformers within them using query IH08 with equipment description “TRANS.”

To identify scrapped spares, search IH08 on equipment description “SPARE” excluding “REG” and technical object type SUBS0028, TRF* excluding the deleted flag was performed in SAP.

For decommissioned spares, a count was performed from start-up to valid from date. For regular spares, a count from valid from date was performed. Ratings and dates were as per the SAP information.

6.6.3 Basis of estimation

As per 6.1.5 in the data template, spare regulators have been excluded; this is as the capacity of the fixed tap transformer is captured and this is the capacity of the flow path.

6.6.4 Changes to accounting policies

N/A – Information reported within 6.1.6 relates to non-financial information.

7. Quality of Services

"Quality of services must be reported in accordance with the definitions specified in the December 2012 electricity transmission network service providers service target performance incentive scheme documents dated December 2012 (the STPIS documents)"

7.1 Service component

7.1.1 Service parameter 1 – Average circuit outage rate (TQS0101-TQS0115)

7.1.1.1 Data requirement

'Outage' means 'loss of connection' rather than loss of supply by a connected system or customer. To allow summation into an overall Average Circuit outage rate, both numerator (No. of Events with defined circuits unavailable per annum) and denominator (Total No. of defined circuits) are needed as well as the calculated percentage rate for each item.

'Number of lines fault outages' (TQS0102) and 'number of defined lines' (TQS0103) must be reported as the amounts used to calculate the "Lines outage rate - fault" (TQS0101).

'Number of Transformer fault outages' (TQS0105) and 'Number of defined Transformers' (TQS0106) must be reported as the amounts used to calculate the 'Transformers outage rate - fault' (TQS0104).

'Number of Reactive plant fault outages' (TQS0108) and 'Number of defined reactive plant'

(TQS0109) must be reported as the amounts used to calculate 'Reactive plant outage rate - fault' (TQS0107).

'Number of Lines forced outages' (TQS0111) must be reported as the amount used to calculate the 'Lines outage rate – forced outage' (TQS0110).

'Number of Transformers forced outages' (TQS0113) must be reported as the amount used to calculate the 'transformer outage rate – forced outage' (TQS0112).

'Number of reactive plant forced outages' (TQS0115) must be reported as the amount used to calculate 'Reactive plant outage rate – forced outage' (TQS0115).

Prior to 2013, the Average Outage Circuit Rate was not required to be submitted to the AER as it was not a service component under the STPIS (data however was being captured within the Events Database). A new worksheet was created in 2013 (within the Workbook - Monthly Report Calendar Year YYYY.xlsm) for the purpose of reporting the new Service Parameter 1 – Average Circuit Outage Rate parameter. This new worksheet was used to generate the figures for the years 2006 to 2013.

7.1.1.2 Data source and methodology

ElectraNet's Events database is the single source of raw data for use in calculating the service components. Exclusions, defined by the AER's "Final Electricity transmission network service providers Service target performance incentive scheme" document, are set within the Events Database against the raw data.

The figures used for the 2014 RIN submission are the actual figures generated out of the Events database, not the annually submitted figures to the AER even though some years the figures will align.

The data relating to SM and AOD is highly dependent on the determination of the events fault cause code. As post fault event analysis to determine the confirmed cause code can take lengthy periods of time, in some cases greater than six months, it is possible, that at the time of the yearly AER submission, not all fault events will have had their cause code determined. At the time of the yearly submission, a fault event that had been included in the STPIS submission due to its initial cause code, is now not included. For example, a fault event that was included at the time of submission, reclassified as 3rd Party post submission, would now be excluded as per the AER STPIS definition for exclusions.

Considering this, ElectraNet have used Events database actual data has and are of the opinion that this will provide the best available source of data into the future.

For service components TQS0101, TQS0102, TQS0104, TQS0105, TQS0107, TQS0108, TQS0110, TQS0111, TQS0112, TQS0113, TQS0114 and TQS0115, the following data sources were used:

1. Workbook - Monthly Report Calendar Year YYYY.xlsm
2. Worksheet – Average Circuit Outage Rate
3. E-Terra Archive Report (database query) - 391Circuit Outage Rates.

For service component TQS0103 (Number of defined lines), the following data sources were used:

1. Workbook - Monthly Report Calendar Year YYYY.xlsm
2. Worksheet – Average Circuit Outage Rate
3. E-Terra Archive Report (database query) – 359 All Enet Lines.

Prior to 2013, where the AER has accepted the STPIS yearly submissions, they have by default, accepted the total number of lines. This is because the total number of lines is required for calculating the "S1 - Transmission Availability Circuit" indicator as part of the yearly STPIS submission. The submissions for 2006 – 2012 have been accepted by the AER under then "Service Standards Compliance Reviews" documentation for each calendar year. These documents can be found on the AER's web site via the link below, but will only show the final submitted, audited and accepted figures which do not include total number of lines. Note that the total number of lines was not required as a separate figure for the yearly submissions.

http://www.aer.gov.au/taxonomy/term/319?order=title&sort=asc&field_type_value=354&field_sector_value=4&field_segment_value=All

Service Components - TQS0106 (number of defined transformers), TQS0109 (number of defined reactive plant)

1. The total number of defined transformers and reactive plant for 2006 – 2013 has been derived from ElectraNet’s asset information system, SAP.
2. Total Reactive Plant is the summation of Reactors, Capacitors and SVC’s.
3. Assets not providing prescribed transmission services have been excluded (as stated in final STPIS document December 2012 page 22 under the exclusions section).

7.1.1.3 Basis of estimation

N/A – the data used is actual data.

7.1.1.4 Changes to accounting policies

N/A – Information reported within 7.1.1 of the data template relates to non-financial information.

7.1.2 Service parameter 2 – Loss of supply event (TQS0116-TQS0117)

7.1.2.1 Data requirement

ElectraNet must enter the loss of supply event frequency thresholds x and y. Where the loss of supply event frequency thresholds have changed, ElectraNet must specify all loss of supply event frequency thresholds that applied in the period and the years to which they applied.

Prior to 2013, the Average Outage Circuit Rate was not required to be submitted to the AER as it was not a service component under the STPIS (data however was being captured within ElectraNet’s Events Database). A sub component of the database was created in 2013 for the purpose of reporting the new Service Parameter 1 – Average Circuit Outage Rate parameter. This was used to generate the figures for the years 2006 to 2013.

For Service Parameter 2 – Loss of supply event frequency – number in ranges specified follow the same definitions as stated in the “Final Electricity transmission network service providers Service target performance incentive scheme December 2012” document.

7.1.2.2 Data source and methodology

As noted in 7.1.1.2, ElectraNet’s Events Database is the single source of raw data for use in calculating the service components.

The figures used for the 2014 RIN submission are the actual figures generated out of the Events database, not the annually figures previously audit by the AER. Accordingly some annual figures may not align due to information on primary cause which has come to light post annual audit.

The data relating to SM and AOD is highly dependent on the determination of the events fault cause code. As post fault event analysis to determine the confirmed cause code

can take extended periods of time, in some cases greater than six months, it is possible, that at the time of the yearly AER submission, not all fault events will have had their cause code determined. At the time of the yearly submission, a fault event that had been included in the STPIS submission due to its initial cause code, is now not included. For example, a fault event that was included at the time of submission, reclassified as 3rd Party post submission, would now be excluded as per the AER STPIS definition for exclusions.

X & y values for the period 2003 to 2008 were derived from the AER Web site, "Decision – South Australian Transmission Network Revenue Cap 2003-2007/08" dated 11 December 2002, page 98

X & y values for the period from 2008 to 2013 were derived from the AER Web site, "Final - ElectraNet transmission determination 2008-09 to 2012-13" dated 11 April 2008, page 96.

ElectraNet have included the x and y value applied in each year of the reporting period in the data template as a comment for each input cell.

For the service components TQS0116 and TQS0117 the following data sources were used:

1. Workbook - Monthly Report Calendar Year YYYY.xlsm
2. Worksheet – ETerra Sys Mins (Filtered)
3. E-Terra Archive Report (database query) - 119 System minutes - Filtered.

Within the monthly Eterra System Minutes section of the database ElectraNet entered the start and end dates. The E-Terra Archive query was then used to establish correct number of system minutes.

For the 2008 reporting period the x and y values of 2008H2 were used for the calculation of the 2008 calendar year figures. This provides consistent x and y values across the majority of the reporting periods (2008H2-2013H1 and 2013H1-2018H2) compared to the minority periods (2006 and 2007).

For the 2013 half year reporting the x and y values of 2013 H2 were used for calculation of the 2013 calendar figures. This is purely administrative since the x and y values did not change between the period 2008H2-2013H1 and 2013H2-2018H1.

7.1.2.3 Basis of estimation

N/A – the data used is actual data.

7.1.2.4 Changes to accounting policies

N/A – Information reported within 7.1.2 of the data template relates to non-financial information.

7.1.3 Service parameter 3 – Average outage duration (TQS0118)

7.1.3.1 Data requirement

Service Parameter 3 – Average outage duration the data reported prior to 2013 follow the same definitions as stated in the “Final Electricity transmission network service providers Service target performance incentive scheme December 2012” document.

7.1.3.2 Data source and methodology

As noted in 7.1.1.2, ElectraNet’s Events Database is the single source of raw data for use in calculating the service components. As noted in section 7.1.2.2 above, not all outages are determined at the time of the yearly AER submission. Therefore, ElectraNet are of the opinion that the Events database will provide the best available source of actual data into the future for service components TQS0118, the following supporting documentation was used:

1. Workbook - Monthly Report Calendar Year YYYY.xlsm
2. Worksheet – ETerra Sys Mins (Filtered)
3. E-Terra Archive Report (database query) - 119 System minutes - Filtered.

Start and end dates were defined to establish average outage durations.

7.1.3.3 Basis of estimation

N/A – the data used is actual data.

7.1.3.4 Changes to accounting policies

N/A – Information reported within 7.1.3 of the data template relates to non-financial information.

7.1.4 System parameter – Proper operation of equipment – number of failure events (TQS0119-TQS0121)

7.1.4.1 Data requirement

Quality of services must be reported in accordance with the definitions specified in the December 2012 electricity transmission network service providers service target performance incentive scheme documents dated December 2012 (the STPIS documents).

Number of failures of protection systems (TQS0119)

As defined on page 26 of the STPIS documents::

“Protection system failure events” are those events where the relevant protection equipment does not operate for a fault event as designed or where the relevant equipment operates when there is no relevant fault rate.

Material failure of SCADA system (TQS0120)

As defined on page 26 of the STPIS documents:

The number of SCADA failures per annum as notified to the TNSP by the Australian Energy Market Operator (AEMO) on a monthly basis in the SCADA Minutes Lost report.

Incorrect operational isolation of primary or secondary equipment (TQS0121)

As defined on page 26 of the STPIS documents:

The number of "incorrect operational isolation events" per annum where "incorrect operational isolation events" are those events where primary or secondary equipment was not been properly isolated during scheduled or emergency maintenance, irrespective of whether an outage occurred as a result.

ElectraNet has provided data on quality of services on the basis above which is consistent with the requirements of the AER Benchmarking regulatory information notice.

7.1.4.2 Data source and methodology

Number of failures of protection systems (TQS0119)

A network event is managed by ElectraNet's System Monitoring and Switching Centre (SMSC) who log the event in ElectraNet's Events Database. ElectraNet's fault investigation team review the event and record the results in a fault investigation report. The root cause analysis (RCA) in the fault investigation report identifies if the event is a failure of a protection system.

The Incorrect Protection Operation Count from WebQuery run each month on the Events Database to extract all failure events that occurred. The number of events that occurred for the month is entered in the monthly STPIS and MITC performance reports. The number of events identified in the monthly STPIS performance report for each calendar year has been totalled to determine the total per annum events for the each period.

Material failure of SCADA system (TQS0120)

AEMO provides to ElectraNet on a monthly basis the SCADA minutes lost report which is reported in ElectraNet's monthly STPIS and MITC performance reports. The number of events identified in the monthly STPIS performance report for each calendar year has been totalled to determine the total per annum events for the each period.

Incorrect operational isolation of primary or secondary equipment (TQS0121)

Suspected switching incidents associated with primary plant are advised by field technicians to ElectraNet's System Monitoring and Switching Centre (SMSC) who in turn advise the ElectraNet Switching Committee that a switching incident may have occurred. The Switching Committee's role is to investigate reported events to establish if a switching incident has actually occurred.

In the case that a switching incident where primary plant is not isolated has occurred, it is reported in the monthly STPIS and MITC performance reports. The number of events

identified in the monthly STPIS performance report for each calendar year has been totalled to determine the total per annum events for the each period.

Incorrect isolation events associated with secondary systems are recorded in ElectraNet's Events Database. The SMSC daily log managed within the Events Database records the details of any event where secondary equipment has not been isolated.

To establish the number of incorrect operational isolation events per annum associated with secondary systems, ElectraNet reviewed the SMSC daily log within the Events Database. For each calendar year the number of identified incorrect isolation events identified associated with secondary systems was totalled.

7.1.4.3 Basis of estimation

Number of failures of protection systems (TQS0119)

Prior to the 1st of January 2013 ElectraNet were not required to report protection system failure events as per the definition set out in the December 2012 electricity transmission network service providers service target performance incentive scheme (STPIS) document.

As ElectraNet have historically not been required to report this information, the number of protection system failure events available in the Events Database prior to calendar year 2012 will not be consistent with the current STPIS definition. Historically the protection system failure events were captured for internal purposes, but the information was based on different criteria than that defined in the December 2012 STPIS document.

Therefore, to provide an estimate of the number of protection system failures over the historical period, ElectraNet reviewed the number of protection system failure events against the total failure events for calendar year 2013. ElectraNet then assumed the same proportion as for 2013 calendar year of protection system failure events to total failure events to estimate the number of protection system failure events for prior periods.

Material failure of SCADA system (TQS0120)

No estimations have been made in the compilation of the number of material SCADA system failure events. Whilst material SCADA system failure events historically have not been a performance parameter applicable to TNSPs under STPIS, this information has been collected on a monthly basis over the benchmarking RIN back-cast period as part of existing business performance reporting.

Incorrect operational isolation of primary or secondary equipment (TQS0121)

No estimations have been made in the compilation of the number of incorrect isolation events. Whilst incorrect operational isolation of primary and secondary events historically have not been a performance parameter applicable to TNSPs under STPIS, this information has been collected on a monthly basis over the benchmarking RIN back-cast period as part of existing business performance reporting.

7.1.4.4 Changes to accounting policies

N/A – Information reported within 7.1.4 of the data template relates to non-financial information.

7.2 Market impact component

7.2.1 Data requirement

ElectraNet is required to report the MIC Data in accordance with the definitions specified in the December 2012 Electricity Transmission Network Service Providers Service Target Performance Incentive Scheme (STPIS) document December 2012 Version 4. The difference with respect to MIC between earlier Versions and Version 4 is that “Coordinated Generator Outages” are excludable in earlier Versions but not in Version 4.

7.2.2 Data source and methodology

ElectraNet’s MITC Events Database is the source of data from which the report “AER Submission Details by Date Range” is produced on a yearly basis. The “AER Submission Details by Date Range” report summarises the included and excluded constraint Dispatch Intervals in a year. The number of “Coordinated Generator Outage” (CGO) related dispatch intervals that have been excluded per Version 3 or earlier was worked out by applying appropriate data filter to the “AER Submission Details by Date Range” report.

The number of dispatch intervals that excluded Coordinated Generator Outages (CGO) (per Version 3 or earlier) was obtained from Page 40 of AER Explanatory Statement – STPIS – September 2012 for 2006 to 2011. For 2012 it was obtained from the outcome of AER’s Service Standards Compliance Review. For 2013, the actual MIC submitted to AER is used. The number of Generator Coordinated Outage related dispatch intervals was worked out by applying data filter for this exclusion.

ElectraNet’s “AER Submission Details by Date Range” yearly report has been used to find, by filtering, the number of “Coordinated Generator Outages” related Dispatch Intervals that have been excluded in the year. This number is added to the corresponding Version 3 or earlier MIC data as approved by the AER to work out the Version 4 data.

The process is applied to the Version 3 or earlier MIC data for 2006 – 2012.

For 2013, because the AER changed the MIC submission template in late 2013 ElectraNet has not yet been able to modify the MIC database structure for automatic reporting according to the new template. So for 2013 RIN MIC data the “AER Submission Details by Date Range” report is unavailable. Instead the actual 2013 MIC Submission to the AER is used. The number of “Coordinated Generator Outages” related Dispatch Intervals has been captured for each half year in two versions of the submission, one with the relevant DIs included and one with them excluded. These can be inspected by checking the inclusion and exclusions in each spreadsheet filter.

7.2.3 Basis of estimation

ElectraNet has not captured the data to the STPIS guideline which was produced in 2012 and not scheduled to apply to ElectraNet until the 2018-2023 regulatory control period.

The substantive difference between the 2012 version of the scheme and the previous version is the treatment of exclusions for “Coordinated Generator Outages” from the MIC parameter. Prior to 2012 these outages were excluded entirely whereas under the 2012 version these outages are not excluded.

An appropriate basis for estimation is to add the number of “Coordinated Generator Outages” in each period to the annual performance previously reported to the AER in accordance with the pre 2012 definitions. In addition in the case of the 2013 calendar year data has not yet been approved by the AER.

7.2.4 Changes to accounting policies

N/A

7.3 System losses

7.3.1 Data requirement

ElectraNet must report system losses in accordance with the definitions specified in the Economic Benchmarking RIN for Transmission Network Services Providers Instruction and Definitions November 2013 Chapter 7 Section 7.3 System losses.

7.3.2 Data source and methodology

National Grid Metering (NGM) data on which the NEM financial settlement is based has been used. This has been previously Quality Controlled by the Metering Data Agent (meter reader) and by AEMO prior to use in NEM settlement. It is also checked weekly by ElectraNet’s internal processes for reasonableness of Transmission Loss Factor.

NGM Data is manually extracted from the ElectraNet Oracle database through the SA Market V2.0 application to an Excel spreadsheet on yearly basis.

The Electricity Inflow, Electricity Outflow, again on yearly basis, is calculated using the extracted data and appropriate formulae following the formula specified in RIN Instructions and Definitions Chapter 7 Section 7.3.

7.3.3 Basis of estimation

No estimations have been required.

7.3.4 Changes to accounting policies

N/A

8. Operating Environment

8.1 Terrain factors (TEF010-TEF0108)

8.1.1 Data requirement

Complete the table in accordance with the definitions provided in chapter 9.

If ElectraNet records poles rather than spans, the number of spans is the number of poles less one.

We require five years of back cast data for the terrain factors and the following Variables have the most recent Regulatory Year shaded yellow and the remaining four years shaded orange:

- Number of vegetation Maintenance Spans (TEF0101)
- Average Number Of Trees Per Maintenance Span (TEF0103)
- Average number of Defects per vegetation Maintenance Span (TEF0104)
- Tropical proportion (TEF0105)
- Standard Vehicle Access (TEF0106)
- Altitude (TEF0107)
- Bushfire risk (TEF0108)

If ElectraNet has Actual Information, ElectraNet must report all years of available data. If ElectraNet does not have actual information on these variables, then it must estimate data for the most recent Regulatory Year.

Number of vegetation Maintenance Spans

The total count of spans in the network that are subject to vegetation management practices in the relevant year. If ElectraNet records towers rather than spans, the number of spans is the number of towers less one. A maintenance span is defined as a span in ElectraNet's network that is subject to active vegetation management practices in the relevant year. Active vegetation management practices do not include Inspection of vegetation Maintenance Spans.

Average vegetation maintenance span cycle

If there is no available data for the 'average vegetation maintenance span cycle' variable (TEF0102), ElectraNet is required to estimate five years of back cast data. The average vegetation Maintenance Span Cycle (defined as the planned number of years between which cyclic vegetation maintenance is performed) can be calculated based on a simple average of all the Maintenance Span Cycles.

Average number of trees per vegetation Maintenance Span

ElectraNet must report the average number of trees per maintenance span. If ElectraNet does not have actual information for the average number of Trees per Maintenance Span it must, estimate this Variable using one or a combination of the following data sources:

- Encroachment Defects (e.g. ground or aerial Inspections, LiDAR) and/or records of vegetation works scoping, or GIS vegetation density data;
- Field surveys using a sample of Maintenance Spans within each vegetation management zone to assess the number of mature trees within the maintenance corridor. Sampling must provide a reasonable estimate and consider the nature of Maintenance Spans in urban versus rural environments in determining reasonable sample sizes.
- Vegetation data such as:
 - the Normalised Difference Vegetation Index (NDVI) grids and maps available from the Bureau of Meteorology (BOM);
 - data from the National Vegetation Information System (VIS data) overlaid on network GIS data to assess the density of vegetation in the direct vicinity of the Maintenance Spans; or
 - Similar data from other sources such as Geoscience Australia or commercial suppliers of satellite imagery overlaid on network GIS data records.
- Any other data source based on expert advice.

ElectraNet must outline its estimation approach for the Average Number of Trees per Maintenance Span in its Basis of Preparation.

When completing the Templates for Regulatory Years subsequent to the 2013 Regulatory Year, if ElectraNet can provide Actual Information for the average number of trees per vegetation maintenance span it must do so; otherwise ElectraNet must provide Estimated Information.

Average number of Defects per vegetation Maintenance Span

ElectraNet must report the average number of vegetation related Defects that are recorded per Maintenance Span in the relevant year.

In its Basis of Preparation, ElectraNet must specify whether it records the total number of Defects for each vegetation Maintenance Span, or whether it records Defects on a vegetation Maintenance Span as one, regardless of the number of Defects on the span.

When completing the Templates for Regulatory Years subsequent to the 2013 Regulatory Year, if ElectraNet can provide Actual Information for the average number of defects per vegetation maintenance span it must do so; otherwise ElectraNet must provide Estimated Information.

Tropical spans

The tropical spans are the approximate total number of urban and rural Maintenance Spans in the Hot Humid Summer and Warm Humid Summer regions as defined by the Australian Bureau of Meteorology Australian Climatic Zones map (based on temperature and humidity).

When completing the Templates for Regulatory Years subsequent to the 2013 Regulatory Year, if ElectraNet can provide Actual Information for tropical spans it must do so; otherwise ElectraNet must provide Estimated Information.

Standard vehicle access

Areas with Standard Vehicle Access are serviced through made roads, gravel roads and open paddocks (including gated and fenced paddocks). An area with no Standard Vehicle Access would not be accessible by a two wheel drive vehicle. The intended unit of measure for the in the economic benchmarking RIN is the km of route line length that does not have standard vehicle access.

Altitude

The Route Line Length that is 600 metres above sea level.

Bushfire risk

The bushfire risk Variable is the number of Maintenance Spans in high bushfire risk areas as classified by a person or organisation with appropriate expertise on fire risk. This includes but is not limited to:

- ElectraNet's jurisdictional fire authority
- local councils
- insurance companies
- ElectraNet's consultants
- Local fire experts

When completing the Templates for Regulatory Years subsequent to the 2013 Regulatory Year, if ElectraNet can provide Actual Information for bushfire risk it must do so; otherwise ElectraNet must provide Estimated Information.

Note that for TEF0101 and TEF0103 to TEF0108, ElectraNet are not required to provide historical data for the regulatory period 2006-12 as ElectraNet does not currently measure the information in accordance with the variable requirement and it would be unnecessarily burdensome to estimate and it is illogical to enter '0'.

8.1.2 Data source and methodology

Number of Vegetation Maintenance Spans (TEF0101)

ElectraNet in establishing total number of vegetation maintenance spans, average number of trees per span and defects relied on information estimated by the vegetation maintenance contractor, Vemco.

A maintenance Span is defined as a span in ElectraNet's network that is subject to active vegetation management practices during the relevant year. ElectraNet has included spans requiring tree trimming, removal or scrub removal, but does not include inspection or measuring of vegetation in spans. This is based on expert advice from ElectraNet's vegetation maintenance contractor, Vemco.

To establish the total number of maintenance spans, ElectraNet have been advised that Vemco reviewed an Access database which contains collated data from Vemco inspector and cutting crew worksheets for the 2013 regulatory year. This data provided the number of spans that are actively managed by Vemco during the year.

Average vegetation maintenance span cycle (TEF0102)

ElectraNet operates under more than one vegetation maintenance span cycle. Routinely, ElectraNet actively manages all spans on a 3 year cycle. However, for spans in bushfire and high bushfire risk areas, ElectraNet also performs pre-bushfire season vegetation maintenance on an annual basis.

Therefore to reasonably estimate the average vegetation maintenance span cycle, the number of bushfire spans as a proportion of total spans for the 2013 regulatory year was determined and a weighted average span cycle calculated for all spans.

The proportion of bushfire spans to total spans for the 2013 regulatory year was then used to estimate a weighted average span cycle for prior regulatory years.

It is ElectraNet's opinion that this is reasonable as the ratio of bushfire to non-bushfire spans has not changed significantly over the period as it is estimated that the total number of spans has only grown by around 2% over the back-cast period.

Average number of trees per vegetation maintenance span (TEF0103)

Average number of trees per span has been estimated based on expert advice from Vemco. ElectraNet were advised that Vemco sourced information on number of trees per span from an Access database which provides collated information from daily worksheets from inspectors and cutting crews for the 2013 regulatory year.

To estimate the number of trees per vegetation span, ElectraNet were advised that Vemco took the number of trees actively maintained (trimmed, removed or scrub removal) divided by the number of spans requiring vegetation maintenance.

Average number of defects per vegetation maintenance span (TEF0104)

Average number of defects per span was estimated based on advice from Vemco advice. Vemco estimated the average number of defects per vegetation maintenance span by reviewing information for the 2013 regulatory year in an Access database which provides collated daily worksheet information from inspectors and cutting crews.

Note that ElectraNet records the total number of defect for each vegetation maintenance span. Vemco's records identified the total number of defect spans inspected and total number of trees actively maintained (removed or scrub removed) in each defect span. Total number of trees actively maintained within defect spans was divided by the number of defect spans to estimate number of defects per maintenance span.

Tropical Proportion (TEF0105)


The Australian Bureau of Meteorology (BOM) Australian Climatic Zones map (based on temperature and humidity) was used to determine the number of spans in hot humid summer and warm humid summer regions. Link to the zone map is below:

http://www.bom.gov.au/jsp/ncc/climate_averages/climate-classifications/index.jsp

ElectraNet reviewed the Climatic Zone map to assess the number of spans ElectraNet has within hot humid summer or warm humid summer climate zones. Based on this assessment, ElectraNet can confirm that 0% proportion of spans is in in hot humid summer and warm humid summer regions.

A copy of the Australian Climatic Zones map used to review the ElectraNet network is included as **Figure 8-1: Climate Zones Based on Temperature and Humidity** below:

Figure 8-1: Climate Zones Based on Temperature and Humidity



Product Code: IDCJCM0000

Standard vehicle access - kms

Information for standard vehicle access was sourced from road information from South Australian Government Data Directory (once loaded into the GIS) as well as ElectraNet's internal network data for the GIS system.

Note that reporting standard vehicle access kilometres in ElectraNet's case is likely to be of limited value to the AER as all ElectraNet's access easements are only accessible by diesel vehicles due to bushfire risk consistent with ElectraNet policy. ElectraNet's vehicle fleet is almost entirely made up of diesel 4WD vehicles and these are the only type of vehicle used by ElectraNet and its contractors to access asset easements.

However, for the purposes of this response, ElectraNet have calculated standard vehicle access as being the route length that is not able to be accessed by a 2WD vehicle.

As all ElectraNet access (easement) tracks are 4WD only, all Government roads except those that cannot support 2WD access for inspecting line assets are included to calculate the number of kilometres of standard vehicle access. Government roads excluded were roads with a bus thoroughfare as vehicles are not allowed to traverse the bus lane, freeways as they do not enable vehicles to stop to inspect lines and 4WD tracks as these do not enable standard vehicle access. These roads are the nearest access available to a standard vehicle (2WD) to ElectraNet lines. From these 2WD accessible roads a 50m buffer either side of a road is created in the GIS system. The total distance of road contained within this buffer zone is subtracted from the total route length, residual amount of route line length taken to be accessible for a 2WD vehicle. 50m is used as the criteria as this is approximately the longest distance from which it is reasonably possible to inspect a line from the ground clearly (insulator string intact).

Route line length is calculated using a consistent methodology as with TEF0201 (route line length) described in section 8.2 of this response. The calculation includes the regulated network only and excludes lines not owned by ElectraNet.

Altitude (TEF0107)

Altitude information is sourced from the Line Schedules spreadsheet as described in section 6.1 of this response. The spreadsheet is filtered to show the structures that are greater than 600m in altitude. A review was then performed over structures identified as being over 600m in altitude and obvious data anomalies were removed from the list.

Examples of exclusions are structure heights greater than the highest point in South Australia, heights recorded as being over 600m in known low lying areas and structures with no height value entered. We note the number of excluded items and data anomalies is sufficiently small as to be immaterial for the purposes of this calculation.

From the listing, the route length either side of each identified structure is divided by two and summed to calculate a total route line length for this variable.

Bushfire Risk (TEF0108)

The Line Schedule database (using the same preparation methods and assumptions as described in section 6.1 of this response) in the Grazer asset management reporting tool was used as a source for this variable.

To identify bushfire risk areas, ElectraNet relied on the classifications of the Government of South Australia, Office of the Technical Regulator (SA OTR) defined schedule 4 of the Electricity (Principles of Vegetation Clearance) Regulations 2010. Each section in ElectraNet's Line Schedule is historically assigned a bushfire risk, based on data from the SA OTR.

The Line Schedules spreadsheet was filtered to show bushfire risk area by built section. The number of structures assigned as having a bushfire risk was then summed to give the total variable value.

Unregulated and non-ElectraNet owned lines are excluded, which is consistent with the assumptions used for the TEF0204 variable. As ElectraNet is using poles rather than spans for this section, the number of spans is the number of poles less one.

8.1.3 Basis of estimation

The above methodology represents ElectraNet's best estimate of the requirements.

As ElectraNet contracts out vegetation maintenance activities, for TEF0101-TEF0104, ElectraNet have had to rely on estimated information from the contractor to provide the data requirements.

Average number of trees per vegetation maintenance span (TEF0103)

Note that this is an approximation to the nearest thousand and therefore this parameter is not provided to 4 significant figures.

Average number of defects per vegetation maintenance span (TEF0104)

Number of trees (collated through daily worksheets from inspectors/cutting crews for the period) is an approximation to the nearest ten. Hence this parameter is not provided to 4 significant figures.

8.1.4 Changes to accounting policies

N/A – Information reported within 8.1 of the data template relates to non-financial information.

8.2 Network characteristics

8.2.1 Data requirement

Route line length

ElectraNet must input the route line length of lines for ElectraNet's network. This is based on the distance between line segments and does not include vertical components such as line sag. The route line length does not necessarily equate to the circuit length as the circuit length may include multiple circuits.

Variability of Dispatch

ElectraNet must input the Variability of dispatch. This is the proportion of energy dispatch from non-thermal generators.

Concentrated load distance

ElectraNet must input the concentrated load distance. This is the greatest distance (Route Line Length) from node having at least 30 per cent of generation capacity to

node having at least 30 per cent of load, where a node is a connection point from a generation source or location to the (transmission) network at source end and a connection point to a load or distribution system at the destination end.

Where there is no concentrated source or load above 30 per cent, respond relative to the largest concentrated source and load and indicate the generation and load magnitudes.

Total number of spans

ElectraNet must input the total number of spans.

8.2.2 Data source and methodology

Route line length (TEF0201)

Route line length data has been sourced from the same spreadsheet as the circuit length pivot sheet as described in ElectraNet's response in section 6.1. Single circuit kilometres were totalled for each voltage. Note that double and triple circuits were excluded from the listing, as per the AER requirement to report true route line length (not necessarily equal to circuit length).

The filtered spreadsheet only included route line length for regulated lines and de-energised lines. Cables have been excluded from the calculation.

Variability of Dispatch (TEF0202)

A grid entry metering report was run from SAMarket which is an SQL database viewer, which shows thermal versus non-thermal energy generation for each half hour time period for the regulatory year. Non thermal energy generation is taken as a percentage of total energy generation for each of the reporting years.

ElectraNet divided all Wind Farm energy generation by the sum of all Wind Farm energy generation and Power Station energy (as classified in SA Market) generation at every half hour and then averaged these half hours across the year. This analysis excluded the Interconnector. All generators included in the report are listed in **Figure 8-2: SA Generators** on the following page:

Figure 8-2: SA Generators

- [-] Power Stations
 - [+] Canowie (Hallett)
 - [+] Dry Creek Power Station
 - [+] Ladbroke Grove Power Station
 - [+] Mintaro Power Station
 - [+] Northern Power Station
 - [+] OCPL
 - [+] Pelican Point Power Station
 - [+] Playford Power Station
 - [+] Port Lincoln Power Station
 - [+] Quarantine Power Station
 - [+] Snuggery Power Station
 - [+] Torrens Island A Power Station
 - [+] Torrens Island B Power Station
- [-] Wind Farms
 - [+] Canowie (Hallett)
 - [+] Cathedral Rocks
 - [+] Clements Gap Windfarm
 - [+] Hallett Hill Windfarm
 - [+] Mayurra
 - [+] Mt Millar
 - [+] North Brown Hill
 - [+] Porcupine Range (Bluff) WF
 - [+] Snowtown WF Stage 1
 - [+] Snowtown WF Stage 2
 - [+] Waterloo East Windfarm
 - [+] Wattle Point

Concentrated Load Distance (TEF0203)

It is unclear what purpose the Concentrated Load Distance (TEF0203) serves in an SA network context. The largest load AMD connection point is the Metro Southern Suburbs (as per T-APR 2013). The largest generation node (by nameplate capacity) is Torrens Island (also SA's Regional Reference Node), which is also metro generation (this generates into the Metro Western suburbs); and these metro nodes can be meshed. For this reason 0km has been entered as the nodes are effectively coincident.

ElectraNet suggests that a more appropriate figure may be the South East Interconnector to Metro Area (approximately 350 km line of sight). This would reflect SA's increased energy reliance on the South East Interconnector.

The Northern generating node (Northern and Playford power stations) to the Metro Area (approximately 250 km line of sight) may also be more appropriate. This is the largest conventional generation centre outside the metro area.

Total Number of Spans (TEF0204)

Total number of spans is calculated from the same spreadsheet as circuit lengths as described in section 6.1 of this response. The spreadsheet was filtered to identify the number of individual spans which were then totalled to identify the total number of spans for each regulatory year.

The filtered spreadsheet only included route line length for regulated lines and de-energised lines only. Cables and have been excluded from the calculation.

8.2.3 Basis of estimation

N/A

8.2.4 Changes to accounting policies

N/A – Information reported within 8.2 of the data template relates to non-financial information.

8.3 Weather stations

8.3.1 Data requirement

ElectraNet must input the weather station number, post code, suburb/locality for all weather stations in its service area. The weather station details are available from the BOM.

Where ElectraNet considers weather data from a weather station is not relevant to the management of its network, ElectraNet must input a 'no' in the 'Materiality' column and provide supporting evidence (in its Basis of Preparation) as to why the weather station is not relevant. For all other weather stations, ElectraNet must input a 'yes' in the 'Materiality' column.

ElectraNet must also input a Variable code for each weather station (for example, TEF03001 for the first weather station).

ElectraNet must add (or remove) rows from Table 8.3 such that all weather stations within its network will be included.

8.3.2 Data source and methodology

ElectraNet reviewed a number of data sources to prepare a list of weather stations in accordance with the requirements set out in the instructions and definitions. ElectraNet used the GIS system to identify all ElectraNet weather stations in ElectraNet's service area.

To establish BOM weather stations used in the management of the network, ElectraNet reviewed weather station data from the Australian Bureau of Meteorology (BOM) to identify the weather station name, location and weather station type.

ElectraNet downloaded BOM weather station data from the link identified below as a text file that was pasted into an excel spreadsheet. The data in the spreadsheet was filtered to identify all active South Australian stations:

<http://www.bom.gov.au/climate/cdo/about/sitedata.shtml> - All BOM stations

The South Australian Government Data Directory suburbs data available at the link below was then used to apply suburb names to each weather station based on the weather station location in the spreadsheet:

<http://data.sa.gov.au/dataset/suburb-boundaries/>

Suburb names were then matched to postcodes in the spreadsheet using the Australian Bureau of Statistics post code data available as per the link below:

[http://www.ausstats.abs.gov.au/ausstats/subscriber.nsf/0/33A877E7086CA98FCA25731A00217F82/\\$File/2923030001poa06aaust.zip](http://www.ausstats.abs.gov.au/ausstats/subscriber.nsf/0/33A877E7086CA98FCA25731A00217F82/$File/2923030001poa06aaust.zip)

This provided a list included in the data template which includes all in-service BOM weather stations in ElectraNet's service area.

The BOM weather text file used to derive base BOM weather site information was uploaded to ElectraNet's GIS system. Two spatial intersection queries were produced, BOM site to post code and BOM site to post code to suburb and exported to an excel spreadsheet.

8.3.3 Basis of estimation

A weather station is classed as material if it is within 50km of the ElectraNet network (including unregulated and non-ElectraNet lines, this is as the weather does not change due to classification and the use of power at the end of a non-ElectraNet line due to local weather will affect ElectraNet's network). The 50km figure is chosen as it gives a reasonable representation of the conditions experienced by the network (distance at which weather (temp and wind) is likely to be consistent).

Note that weather sites situated over water or in the Far North West of SA will not have a suburb or postcode.

Note that as a post code can exist across multiple suburbs. To produce a unique list of BOM weather stations to postcode to suburb, the first Post code suburb match was used.

8.3.4 Changes to accounting policies

N/A – Information reported within 8.3 of the data template relates to non-financial information.

STATUTORY DECLARATION

I, IAN FRANCIS STIRLING
of 52-55 EAST TERRACE ADELAIDE
(Full Name)
(Address)
in the State of South Australia CHIEF EXECUTIVE OFFICER
do solemnly and sincerely declare that: (Occupation)

1. I am an officer, for the purposes of the *National Electricity (South Australia) Law (NEL)*, of ElectraNet Pty Limited (ACN 094 482 416), a regulated network service provider for the purposes of section 28D of the NEL. I am authorised by ElectraNet Pty Limited to make this statutory declaration as part of the response of ElectraNet Pty Limited (**ElectraNet**) to the Regulatory Information Notice dated 28 November 2013 (**Notice**) served on ElectraNet by the Australian Energy Regulator (**AER**).
2. Having had regard to the Notice, I say that the actual information provided in ElectraNet's response to the Notice is, to the best of my information, knowledge and belief:
 - (a) in accordance with the requirements of the Notice; and
 - (b) true and accurate.
3. Where it is not possible to provide actual information to comply with the Notice, ElectraNet has, to the best of my information, knowledge and belief, for the purposes of complying with the Notice:
 - (a) provided ElectraNet's best estimate of the information in accordance with the requirements of the Notice; and
 - (b) provided the basis for each estimate, including assumptions made and reasons why the estimate is the best estimate, given the information sought in the Notice.

And I make this solemn declaration conscientiously believing the same to be true, and by virtue of the provisions of the Oaths Act, 1936.

Signature 

Declared and subscribed at ADELAIDE

in the said State by the said IAN STIRLING

this 14th day of APRIL, 2014

Before me:

DOROTHY ANNE SHORNE J.P. 23893

Note- This Declaration must be signed before a Justice of the Peace, a Commissioner for Taking Affidavits, or a Notary Public.


Any alteration made must be initialled by both the applicant and the Justice of the Peace.

DOROTHY SHORNE
JUSTICE of the PEACE 23893

FOR IDENTIFICATION
PWC
ADELAIDE



FOR IDENTIFICATION ONLY
PwC
ADELAIDE



PricewaterhouseCoopers, ABN 52 780 433 757
91 King William Street, ADELAIDE SA 5000, GPO Box 418, ADELAIDE SA 5001
T: +61 8 8218 7000, F: +61 8 8218 7999, www.pwc.com.au

Liability limited by a scheme approved under Professional Standards Legislation.



FOR IDENTIFICATION ONLY
PwC
ADELAIDE

