


Submission on the AER's public lighting supplementary draft decision







Contents

1.	PROCESS TO DATE	2
1.1	Law and Rule requirements	
1.2	Our June 2008 proposal	
1.3	AER's draft determination	3
1.4	Our response to the draft determination with respect to public lighting	
1.5	AER's supplementary draft determination	
1.6	Our response to the March 2009 draft decision	4
2.	ENERGYAUSTRALIA'S RESPONSE	6
2.1	Representation of EnergyAustralia's information	6
2.2	EnergyAustralia's annuity approach	
2.3	Reasonable opportunity to recover costs	
2.4	Assumptions	
2.5	New problems as a result of AER decision to use asset roll forward	16
2.6	Inconsistencies and errors	10

l. Process to date

- EnergyAustralia has not revised its June 2008 proposal with respect to the control mechanism for the construction and maintenance of public lighting (referred to here in this submission as public lighting services) but it has updated some inputs into the control mechanism.
- In addition to setting out EnergyAustralia's updated inputs for the purposes of its proposed control mechanism, this Chapter is EnergyAustralia's submission in relation to the AER's draft decision NSW Draft Distribution Determination 2009-2010 to 2013-14 Alternative Control (public lighting) services, published by the AER on 17 March 2009
- This Chapter together with Chapter 7 of Part II of the June 2008 proposal is EnergyAustralia's current proposal in relation to public lighting services and should be considered in conjunction with EnergyAustralia's submission in Chapter 7 of Part II of EnergyAustralia's January 2009 Revised Regulatory Proposal and Interim Submission

1.1 Law and Rule requirements

Making a distribution determination

Transitional Rules require the AER to make its determination with respect to public lighting services¹ in accordance with clause 6.2.5 (c)(2) and (d) and clause 6.2.6 of the Transitional Rules. Clause 6.2.5 specifies what a control mechanism for alternative control services may consist of and the matters the AER must have regard to when deciding on such a control mechanism.

As an alternative control service, the public lighting component of the AER's distribution determination is predicated on a decision on the control mechanism for alternative control services and a decision on how compliance with that control mechanism is to be demonstrated. It may also be predicated upon a decision in which the AER decides any other

appropriate amounts, values or inputs.³ The AER's discretion in making its distribution determination on public lighting is subject to clause 6.12.3 of the Transitional Rules and must set out the basis and rationale for the decision in accordance with clause 6.12.2 of the Transitional Rules.

The AER must also take into account the revenue and pricing Principles set out in section 7A of the NEL when it is exercising discretion in making those parts of a distribution determination relating to alternative control services⁴.

1.2 Our June 2008 proposal

In June 2008, EnergyAustralia proposed a control mechanism which consisted of a schedule of prices for each type of public lighting asset used to provide public lighting services. EnergyAustralia also proposed that the control mechanism inflate prices annually based on the most recent inflation information.

Our proposed control mechanism was consistent with the control mechanism set out in the AER's Statement on Control Mechanisms for alternative control services ACT and NSW published in February 2008. EnergyAustralia's proposal did however differ from the AER's statement of approach in that it put forward a different methodology for establishing the asset (investment) returns on which the control mechanism was to be based. EnergyAustralia's 'cost of service' approach used an annuity approach to derive investment returns on the annual value of the replacement cost in 2008, and an allocation of EnergyAustralia's forecast public lighting operating and maintenance expenditure.

In contrast the approach outlined in the AER's guideline calculated asset returns using a roll forward regulated asset based (RAB), similar to what is currently provided for standard control services.

EnergyAustralia's approach to allocating EnergyAustralia's forecast public lighting operating and maintenance expenditure was consistent with the AER's guideline.

Clause 6.2.3B(b)(1) deems public lighting services to be a direct control service and further an alternative control service.

² Clauses 6.12.1(12) & (13)

³ Clause 6.12.1(10)

Section 16 National Electricity Law.

Since June 2008, the AER has requested a lot of detailed information about EnergyAustralia's public lighting business. The AER has also requested that EnergyAustralia calculate public lighting prices under various scenarios. We have fully complied with all requests for information and tried to assist the AER where possible, while always maintaining that we see no reason or evidence that would justify a move away from the approach that we originally proposed in June 2008.

This submission maintains the annuity method that we proposed in June 2008. However, EnergyAustralia has updated the model to include the most up to date information, including updated:

- Customer information
- Asset inventory
- CPI and labour escalation
- Discount rate consistent with that used in our revised proposal
- Updated historic operating expenditure and bulk maintenance program costs

These updates are contained in the annuity model, which is Attachment 3 and is submitted to the AER in confidence.

1.3 AER's draft determination

In November 2008, the AER published its draft decision *New South Wales draft distribution determination 2009-10 to 2013-14 and a Draft Distribution Determination* ("the AER's November Decision").

The AER's November Decision rejected EnergyAustralia's proposed control mechanism but it did not include a substitute control mechanism in a form required by clause 6.5.2 of the Transitional Rules.

Instead of imposing an alternative control mechanism on prices or revenues, the AER's November 2008 draft decision proposed only the preferred "form" of control mechanism for alternative control services. That being:

 A schedule of fixed prices in the first year of the next regulatory control period for assets constructed before 1 July 2009 and a schedule of fixed prices in

- the first year of the next regulatory control period for assets constructed after 30 June 2009
- A price path, such as CPI, for the remaining years of the regulatory control period.

The AER's draft decision set out the following process before it would make a decision on the actual prices to form the schedule of fixed prices:

- 16 February 2009 DNSPs to calculate prices as specified by the AER's draft decision.
- 9 March 2009 The AER would publish its proposed price schedules and seek submissions.
- 23 March 2009 Interested parties would make submissions to the AER.
- April 2009 The AER would make its final determination.⁵

1.4 Our response to the draft determination with respect to public lighting

EnergyAustralia did not revise its June 2008 proposal with respect to public lighting in response to the AER's Draft Determination as permitted by clause 6.10.3 of the Transitional Rules. This was because the AER had not completed its Draft Determination in relation to alternative control services. Without the actual control mechanism, EnergyAustralia could not assess the impact of the AER's Draft Determination. However, EnergyAustralia responded to the AER's Draft Determination in its *Revised Regulatory Proposal and Interim Submission* dated 14 January 2009 ("the Interim Submission").

In the Interim Submission, EnergyAustralia raised concerns regarding the incompleteness of the AER's November draft decision and requested that the AER "formally proceed to make a draft determination with respect to the control mechanism for public lighting". We noted that this affected

⁵ Page 345 of AER draft determination, Nov 2008.

Page 172 of the revised proposal and interim submission.

Process to date (continued)

our ability to make a submission on the draft decision and further restricted our ability to formally revise our proposal.⁷

Also the Interim Submission included additional information for the AER to take into account when completing its draft decision.

After receiving EnergyAustralia's Interim Submission, the AER requested further detailed information about EnergyAustralia's public lighting pricing model and the public lighting business. This information request included a specific request to calculate prices for public lighting services under certain assumptions. EnergyAustralia provided8 this information to the AER on 9 March, 2009.

AER's supplementary draft 1.5 determination

On 17 March 2009, the AER published its draft decision in relation to alternative control services ("the March 2009 draft decision"). In contrast to the AER's November 2008 draft decision, the March 2009 draft decision imposed controls on the price of public lighting services. This control mechanism was set out as follows:

For assets constructed before 1 June 2009:

- A schedule of fixed prices for the first year of the next regulatory control period for assets constructed before 1 July 2009 as set out in Appendix B to the draft decision; and
- A price path for the remaining years of the next regulatory period, calculated by applying 60 per cent of the NSW EGW real labour growth rates to maintenance costs and the draft decision forecast inflation rates used in table 3.11 of the draft decision.

For assets constructed after 30 June 2009:

- A schedule of fixed prices for the first year of the next regulatory control period for assets constructed after 30 June 20099, as set out in appendix B
- A price path for the remaining years of the next regulatory control period, calculated using the AER's draft decision on forecast inflation rates set out in table 3.11.

The effect of the AER's decision is that it rejected EnergyAustralia's proposed schedule of fixed prices and the underlying annuity model for assets constructed before 1 July 2009. The March 2009 draft decision substituted a schedule of fixed prices based on an approach using a regulatory asset base (RAB) roll forward.

With respect to assets constructed after 30 June 2009, the AER rejected EnergyAustralia's proposed schedule of fixed prices but not the underlying annuity model. The March 2009 draft decision adopted the annuity model but it substituted certain assumptions regarding construction costs and amended certain inputs.

Our response to the March 2009 draft decision

EnergyAustralia has previously raised concerns with the process leading up to, and including, the AER's March 2009 draft decision. These concerns are outlined in the Interim Submission and a letter from EnergyAustralia to the AER¹⁰.

The AER's process which has only allowed EnergyAustralia ten business days to consider the AER's decision has severely compromised EnergyAustralia's ability to fully consider and respond to the AER's decision.

EnergyAustralia is also concerned with the way in which the AER has represented information that EnergyAustralia has

Page 172 of our revised proposal and interim submission.

EnergyAustralia also provided further public lighting information to the AER on January 20th, March 2nd, 10th and 11th

⁽Note: The AER's decision at page 49 appears to be incorrect as it refers to assets constructed *before* 30 June 2009 rather than after 30 June 2009)

Attachment 2: Letter from EnergyAustralia dated 26 March 2009). This letter is confidential and should not be made public without EnergyAustralia's consent.

provided the AER in response to the requirements of the AER's November 2008 draft decision and further requests received since that time. The information provided in response to the AER's information requests is presented incorrectly in the March 2009 draft decision as being part of EnergyAustralia's proposal.

EnergyAustralia does not agree with the AER's November 2008 draft decision or its March 2009 draft decision. EnergyAustralia's reasons for not agreeing with the AER's Complete Draft Determination¹¹ are explained in detail in this submission and include:

- the AER has not given adequate consideration to the information provided by EnergyAustralia and has unreasonably substituted its own inputs and assumptions
- the AER has not properly taken into account the revenue and pricing principles and in particular has not given consideration to whether it has provided EnergyAustralia with a reasonable opportunity to recover at least the efficient costs

Section 2.1 clarifies the status of EnergyAustralia's proposal and the information that EnergyAustralia has provided to the AER.

Section 2.2 addresses why the AER has incorrectly rejected EnergyAustralia's proposed control mechanism for assets constructed before 1 July 2009 and why the annuity model (with some amended inputs to address issues raised by the AER's complete draft determination) should be applied to all assets used to provide public lighting services.

Section 2.3 addresses the AER's failure to give consideration to whether its complete draft determination provides EnergyAustralia with a reasonable opportunity to recover at least the efficient costs incurred in providing public lighting services and that for this reason the AER has not correctly exercised its discretion.

Section 2.4 addresses why the AER has incorrectly rejected EnergyAustralia's proposed assumptions and inputs with respect to:

- Bulk lamp replacement cycle
- Luminaire maintenance cost recovery
- Spot lamp replacement rate
- RAB allocation
- Economic life of supports and lamps

In most cases the AER has not provided robust analysis or evidence to support its approach.

Section 2.5 addresses issues arising in relation to the AER's proposed approach to the pricing of assets which are replaced early and new assets introduced during the next regulatory control period.

Section 2.6 sets out some minor errors in the AER's March 2009 draft decision which should be addressed during finalisation of this decision.

[&]quot;AER's Complete Draft Determination" is used to refer to the combination of the "AER's November 2008 draft decision" and the "March 2009 draft decision"

2.1 Representation of EnergyAustralia's information

EnergyAustralia has provided a large amount of information to the AER, both in response to the AER's November 2008 draft decision, and in response to subsequent information requests. To date, EnergyAustralia has not revised its June 2008 Regulatory Proposal in relation to alternative control services. We are therefore concerned that the AER's March 2009 draft decision in some places infers, and in other places represents that EnergyAustralia has revised its regulatory proposal. Specifically, the AER requested that EnergyAustralia calculate certain prices using specific modelling assumptions and the AER's March 2009 draft decision incorrectly represents the resulting prices as EnergyAustralia's revised prices.

For example, page 5 of the March 2009 draft decision, states.

This supplementary draft decision considers the charges proposed by the NSW DNSPs for alternative control services for 2009-2010, as well as their proposed price paths for the remaining years.

This statement is misleading. Prices and price paths considered in the March 2009 draft decision were not proposed by EnergyAustralia as part of its regulatory proposal. Those lists of charges and the price paths were prepared by EnergyAustralia in response to the requirements in the AER's November 2008 draft decision and subsequent information requests from the AER. Similarly, page 8 of the March 2009 draft decision indicates that EnergyAustralia has revised its proposal. This is not the case.

Similar issues arise in relation to the limited roll forward model, including the RAB prepared by EnergyAustralia in response to the November 2008 draft decision. ¹² The AER states at page 8 of the March 2009 draft decision that:

EnergyAustralia has determined its closing RAB as at 2008-2009 by applying IPART's opening RAB of \$98 million as at 1 July 2004.

EnergyAustralia has not "determined" a closing RAB value as part of its proposal. The use of a limited roll forward model or

Page 339 of the AER's Draft Determination required that EnergyAustralia calculate a RAB value. RAB are not part of EnergyAustralia's proposal as neither are required when using an annuity approach. Again, the March 2009 draft decision incorrectly represents information provided in response to the AER's requests as being part of EnergyAustralia's proposal. Similar incorrect representations are made at pages 13, 15, 16 and 46. EnergyAustralia requests that these representations be withdrawn and corrected.

2.2 EnergyAustralia's annuity approach

This section addresses why the AER incorrectly rejected EnergyAustralia's proposed control mechanism for assets constructed before 1 July 2009 and why the annuity model should be applied to all assets used to provide public lighting services. This section also illustrates that the AER has not had sufficient regard to the factors set out in clause 6.2.5(d) which it must have regard to when deciding on a control mechanism for alternative control mechanism.

EnergyAustralia developed and proposed an annuity method using a price list, based on replacement cost, to calculate prices for public lighting assets because it:

- was relatively simple to apply,
- avoided the need for detailed asset age information (which is not available),
- results in a single price list for all assets,
- allows easy comparison of services provided by new technology with those provided by older, less efficient technology,
- establishes a platform to move to more energy efficient outcomes for the community
- supports future competition in the provision of public lighting services.

The annuity approach is also relatively simple to apply to a large asset base, and can be applied in the absence of detailed asset age information without the use of broad assumptions to recreate asset age data. This was particularly important as EnergyAustralia's asset systems do not contain full age information. The annuity model enabled EnergyAustralia to generate a detailed price list that we are confident will allow us to recover revenues sufficient to cover our forecast costs.

These costs (capital & operating) were developed using approved forecasting methods. The forecasting method for developing costs is outlined below.

Recovery of efficient operating costs

EnergyAustralia forecast its maintenance costs for public lighting in the same manner it forecast its maintenance for the distribution network, using similar techniques to establish optimum maintenance and asset replacement cycles including FMECA¹³ and RCM¹⁴. These techniques have been accepted by the AER and its consultant Wilson Cook & Co, as being representative of good business practice. SAHA, in their report in relation to EnergyAustralia's standard control services remarked that EnergyAustralia's asset management practices were in line with best practice, that produce efficient maintenance costs over time.

EnergyAustralia observed the costs of public lighting maintenance over time based on the four categories of maintenance cost reporting – inspection, corrective, breakdown and nature induced breakdown – to determine the efficient cost of maintenance going forward. This cost was subject to real cost escalation using the same escalators that were applied to the maintenance cost forecast for standard control services.

Having established the total value of forecast operating cost, EnergyAustralia created a model to allocate those costs to public lighting assets. There are 1.26 million separate asset components that make up the public lighting asset base, and it is not possible to allocate specific tasks and costs to individual assets. Therefore, an allocation of costs is undertaken. Again, this is similar to how costs are allocated to prices for our standard control services.

EnergyAustralia's cost allocation method has been approved by the AER. The method stipulates that costs are to be allocated on a causal basis where possible, and otherwise via non-causal allocation using certain business rules. This same methodology has been applied within EnergyAustralia's public lighting model. EnergyAustralia's pricing lighting model allocates total operating costs by first allocating the cost of the bulk lamp replacement program to each lamp, and then allocates the remaining operating costs, which it attributes to spot replacement.¹⁵

In step 1, the cost of the bulk lamp replacement is allocated evenly across all lamps. In step 2, the remaining operating cost (assumed to be spot lamp replacement) is allocated using the cost of lamps, cost of lamp installation, and the location of the lamps (in residential areas or along traffic route) as weights.

The relative cost of the large scale programs do not necessarily represent the relative cost per unit of a bulk replacement task and a spot replacement task. This is because spot lamp replacements includes all other operating costs including operating cost related to general business overheads. This clouds the comparison of the bulk versus the spot replacement rate. If a comparison was required, other costs would need to be separated out to allow comparison of like with like.

The per unit cost of spot and bulk lamp replacement is considered when establishing the appropriate bulk lamp replacement rate (see section 2.4). Once established, the costs of bulk lamp and spot lamp replacement programs are allocated in the model using weights as described above.

Recovery of efficient capital costs

EnergyAustralia's public lighting model calculates costs for capital expenditure for each asset based on the total installed cost of the asset, plus the return on and of capital over the life of the asset, and divides the total into 20 equal annual payments. The model uses replacement cost for all assets and therefore produces a single price list.

All materials used in construction of public lights are sourced via competitive procurement arrangements. Labour used to construct assets is charged at a labour rate commensurate with labour charges for EnergyAustralia's standard control services. These costs have been separately assessed by the AER's consultant Wilson Cook.

¹³ Failure Modes Effects Critical Analysis.

¹⁴ Reliability Centred Maintenance.

The spot lamp replacement category includes other costs not directly attributed to spot lamp replacement such as vehicle costs

(continued)

The assumptions of time taken to construct assets is based on field observations, and the effective labour rate is cheaper, on average, than other service providers in NSW.

The cost of capital used in the public lighting model is the same as that used for the distribution business.

EnergyAustralia's public lighting annuity model combines the operating and capital costs and allocates it according to the allocation method. It has been built to recover no more than the efficient costs of providing public lighting services to customers within our franchise area.

AER's rejection of annuity model for pre-1 July 2009 assets

The AER accepted EnergyAustralia's annuity method for assets installed after 1 July 2009 but rejected this method for assets installed before that date. The reason put forward to support its rejection of the annuity method was that the model used asset values that were based on replacement cost rather than a depreciated cost.

The AER noted that it was "aware that many of the assets in the DNSP's asset bases were constructed some time ago and therefore have a much lower value than that developed through a replacement cost approach." ¹⁶ The AER therefore based its rejection of an entire annuity model methodology on the basis that it objected to an input used in that methodology, rather than an objection to the methodology itself, which it in fact accepted for all new assets. EnergyAustralia considers that this decision was in error and has led to an incorrect exercise of discretion on the part of the AER.

The AER is limited in its discretion when it refuses to approve a methodology such as that which underpins the control mechanism for alternative control services or a value or amount reflected in that methodology. If the AER refuses to approve a methodology, value or amount, the substitute must be determined on the basis of the current regulatory proposal and amended from that basis only to the extent necessary to enable it to be approved in accordance with the Rules. ¹⁷ By not

addressing itself to the input in the model i.e. the use of replacement cost, and rejecting the model itself, the AER has moved beyond its mandated use of discretion.

The AER's introduction of a new model has brought with it unnecessary complexity and created additional problems that cannot easily be solved without detailed asset and age related information, which the AER is aware does not exist. The AER's approach unnecessarily requires EnergyAustralia to develop a different price list based on a different methodology for the same service. The AER did not have regard to the impact of its decision which demonstrates that the AER has not had sufficient regard to the factors listed in clause 6.2.5 (d) when making its decision. Many of the AER's assumptions that were within the March 2008 draft decision did not regard for actual business practices. For example the AER recommended a bulk lamp replacement programme of 3 years when EnergyAustralia undertakes 2.5 years and has carried out a rigorous analysis to support this programme length 18. This is further discussed in section 2.4.

To implement this new model, the AER has had to make a number of broad assumptions such as the average age of assets. This question is avoided entirely by the use of an annuity approach and was one of the primary drivers of EnergyAustralia's selection of an annuity approach.

Use of replacement cost rather than historic cost

The use of replacement cost for determining investment in the annuity model is entirely appropriate for a public lighting business. The age of the asset is irrelevant to the service, provided that the asset that delivers the service meet certain performance criteria. This means that as long as the asset delivers services that meet those criteria, the age of the asset providing the service is irrelevant.

EnergyAustralia's public lighting annuity model calculates all prices for assets on the basis that the *service* is purchased by customers. The cost of this service is based on the market

¹⁶ AER draft determination, Nov 2008, p330

 $^{^{\}rm 17}$ Clauses 6.12.1 and 6.12.3 of the Transitional Rules.

Other examples includes the AER's assertion that supports and lamps should have a 35 and 3 year economic life respectively.

price of providing new services and is not related to the age of the asset providing the service.

Applying a roll forward of asset values used in the regulation of standard control services does not address the fundamental concept that customers are buying a unit based service. Our customers do not pay for the asset in isolation. The AER's application of a roll forward model in the context of limited asset information creates additional problems discussed in section 2.5 below.

2.3 Reasonable opportunity to recover costs

The AER is required to take into account the revenue and pricing principles, one of which is that a provider of direct control services (such as public lighting services) should be given a reasonable opportunity to recover at least the efficient costs incurred in providing these services. EnergyAustralia considers that the AER's March 2009 decision has failed to consider the efficient costs, and has failed to ensure we have an opportunity to recover such costs.

At no point within the March decision does the AER explicitly consider the concept of efficient cost. In fact, the AER attempts to reduce the cost of providing public lighting services by comparing providers, and selecting parameters from various proposals that delivers the lowest price to customers, without consideration of whether the resulting prices are sufficient to cover the efficient costs of each provider.

It is clear from the AER's own analysis that there is a wide variety of costs faced by each of the three NSW providers. However, the analysis has not been undertaken at a sufficiently detailed level to demonstrate what costs are captured in each category by each provider. By selecting the lowest price in all categories, the AER has effectively removed the ability of providers to recover their own costs which vary for legitimate reasons.

"Cherry picking" assumptions

The AER has materially changed the proposal that EnergyAustralia put forward to calculate public lighting prices. In creating its own framework using two models, the AER has reviewed the costs of the three NSW DNSPs, and has deliberately chosen parameters at the lowest common

denominator (ie that deliver the lowest prices for customers) without sufficient regard to the costs of each provider in providing the service. This selection has been made regardless of whether those parameters are inconsistent with each other when applied to an individual DNSP.

Where an assumption has been used for EnergyAustralia that results in a higher price, the AER has changed the assumption to reduce prices. For example, the cycle of bulk lamp replacements has been extended from 2.5 years to 3 years. However, where EnergyAustralia has used an assumption that gives a lower cost than the proposals from Integral and Country Energy, the AER has not asked that the assumption be changed. In Table 4.3 of its March 2009 draft decision 19, the AER compares the capital costs for a constructed streetlight. EnergyAustralia's component costs are cheaper compared to Country Energy and compare favourably to Integral Energy's costs. In this case, the AER has not allowed EnergyAustralia to increase these costs to be comparable to the other DNSPs.

EnergyAustralia considers the comparisons the AER has undertaken to be relatively unsophisticated and not sufficient to take account of the costing methodologies used between the three providers that drive variations in costs. The AER's selection of the least cost assumptions to drive down public lighting prices does not appear to consider whether those changes impact the ability of providers to recover efficient costs.

This is in direct contrast to the AER's proposed approach set out in its February 2008 Statement on NSW Alternative Control Services, which asserted that it would "determine the initial price levels and the price path with reference to the efficient costs of providing public lighting services." Further, the AER stated in its November 2008 draft decision that "The AER considers it appropriate to allow the NSW DNSPs to charge prices which reflect the efficient costs of providing public lighting services."

EnergyAustralia has undertaken analysis of the assumptions used by the AER, and has calculated the impact of adopting those parameters. While mandating the use of consistent parameters appears to be a good approach, it must be done

¹⁹ Supplementary draft determination, page 37.

(continued)

with an understanding of the different models used by the businesses and the different ways in which these models account for costs.

If EnergyAustralia's parameters for labour rates, the bulk lamp replacement cycle, time taken to install lights, overheads, and reductions in spot replacement are included in EnergyAustralia's public lighting model, the prices recover \$14.8 million in operating costs and \$35.3 million in revenue in FY10. However, these outcomes change if the parameters are changed to those used by the AER or made consistent with the parameters used by Integral Energy. The results of the three scenarios are shown in Table 1.

Table 1 – Scenarios using different parameters in EnergyAustralia's public lighting model (FY10)

Parameters	EnergyAustralia's parameters	AER parameters	Integral Energy parameters
Labour rate	\$93.64	\$93.64	\$127.51
Орех:			
Reduction in SPR due to BLR	1.13%	20%	20%
Target opex	\$15.0m		
Opex recovered	\$14.78m	13.9m	\$16.28m
Capex:			
Overheads on capital	20%	20%	0%
BLR cycle	2.5	3	3
Time to install light - standard - traffic	2 4	2 2	1.39 1.39
EWP rate	-	-	\$44.86
Revenue recovered	\$35.31m	\$33.46m	\$35.33m
Variance	-	-\$1.85m	\$0.02m

Table 1 shows that by changing various assumptions, the AER has materially reduced the amount of revenue received by EnergyAustralia in 2010. However, we note that Integral Energy was not required to make the same changes, despite the fact that, if EnergyAustralia used the parameters that Integral used, the revenue (including operating costs) recovered in prices would be higher than that put forward by EnergyAustralia.

This analysis demonstrates the importance of using assumptions mindful of the way in which the models use those parameters to generate revenue. Failure to take account of this will lead to outcomes where a provider of public lighting services will not be able to recover its costs.

EnergyAustralia does not consider the AER to have made a decision consistent with the National Electricity Objective.

The National Electricity Objective is to promote efficient investment in and efficient operation and use of electricity services for the long term interest of consumers of electricity. The decision does not promote efficient investment in electricity services as it has materially reduced the revenues that will be earned by EnergyAustralia to a point where we do not have a reasonable opportunity to recover efficient costs. Furthermore, it does not provide prices that are cost reflective and that are likely to lead to efficient consumption decisions in future.

The specific assumptions that the AER has proposed are discussed in the Section 2.4. EnergyAustralia strongly asserts that our assumptions from the June 2008 proposal should be reinstated.

Deferred depreciation

Not only has the AER failed to consider actual costs going forward, the AER has failed to take account of the lack of cost reflectivity of past prices. This is a further matter to which the AER must have regard under clause 6.2.5(d) when deciding on a control mechanism.

The AER is aware that IPART, when making its determination for public lighting in 2005, set prices based on a deferral of depreciation charges. IPART rejected EnergyAustralia's original proposal for depreciation and instead accepted a significant downward revision of the depreciation allowance. By doing so, the prices set by IPART were lower than the true cost of

providing the service and would lead to higher prices in future years to recover this cost.

Allen Consulting Group in its 2003 report to IPART on depreciation, stated that "a change to the current depreciation method²⁰ for existing assets (i.e. to back end depreciation) may imply much lower prices than would have occurred under the alternative regime – and higher prices in the future."²¹

IPART itself admitted in its August 2005 public lighting price determination²² that its decision would mean that cross subsidies will still exist between customers in 2009.

EnergyAustralia considers it important that the AER take account of prices for the 2009-2014 period when determining, the deferred depreciation that resulted from IPART's decision in 2004 to back end depreciation.

The AER acknowledged on page 2 of the March 2009 draft decision that prices set by IPART were not cost reflective and did not result in recovery of efficient cost. Despite this acknowledgement, the AER has not taken into account the value of depreciation that was deferred from the 2004-09 period that should be recovered and has set prices for existing assets that do not cover the efficient costs of providing public lighting services over time.

Table 2 shows the RAB as calculated by the AER using straight line depreciation. The decision to establish an asset base using straight line depreciation under values the true value of EnergyAustralia's public lighting asset base, in that it assumes a higher return of capital has been received than has actually been received. Using the AER's March 2009 draft decision, prices for assets installed prior to 1 July 2009 do not reflect the correct RAB value and are inappropriately low.

To correct this, the AER must establish the RAB using actual depreciation over the 2004-09 period rather than use an assumption of straight line depreciation.

Table 3 shows the derivation of the RAB using actual depreciation (as per IPART's decision) for the 2004-09 period²³.

Table 2 AER RAB roll forward (\$ million, nominal)

	FY05	FY06	FY07	FY08	FY09
Opening value	97.8	99.6	102.9	107.4	106.8
Depreciation	10.9	11.8	12.8	14.0	14.9
Capex	9.7	12.1	13.8	11.2	16.9
Indexation	2.9	2.9	3.5	2.1	2.5
Closing value	99.6	102.9	107.4	106.8	111.3

Table 3 RAB consistent with previous IPART approval (\$ million, nominal)

	FY05	FY06	FY07	FY08	FY09
Opening value	97.8	105.0	113.8	124.6	130.8
Depreciation	5.4	6.4	7.0	7.5	8.0
Capex	9.7	12.1	13.8	11.2	16.9
Indexation	2.9	3.1	3.9	2.5	3.1
Closing value	105.0	113.8	124.6	130.8	142.8

When actual depreciation is used in the roll forward model, the regulatory asset base for EnergyAustralia's public lighting business is higher than forecast by the AER in its March 2009 draft decision. Using the AER's roll-forward approach with the actual RAB, revenue for the next regulatory period will increase by an additional \$23 million.

²⁰ Straight line depreciation

Allen Consulting Group, *Principles for determining regulatory* depreciation allowances - Note to the Independent Pricing and Regulatory Tribunal, Sept 2003.

²² IPART Statement of Reasons for Decision EnergyAustralia application for proposed price increase of public lighting charges August 2005 p4

EnergyAustralia provided a simple RAB calculation in its original June 2008 proposal. However, the RAB roll-forward was done at a high level. Subsequent analysis has resulted in a more accurate RAB calculation as shown in Table 3.

(continued)

2.4 Assumptions

The AER has made a number of changes to input assumptions as part of its March 2009 draft decision. These changes lack substantiation and all but one change has the effect of reducing required revenues below that required to meet the efficient costs of providing public lighting services in the 2009-14 period. In most cases the AER has not provided robust analysis or evidence to support its approach.

This section addresses each of the assumptions that the AER has changed and presents arguments and further material in support of EnergyAustralia's original assumptions.

Bulk lamp replacement cycle

In its March 2009 draft decision, the AER determined that EnergyAustralia's bulk lamp replacement programme should be extended from a 2.5 year cycle to a 3 year cycle. The AER provided no technical justification for this change but based its change on a high level comparison of bulk lamp cycle rates applied in other network areas.

EnergyAustralia considers that the AER's decision is unreasonable and is an example of the limitations and errors that can result from reliance on high level benchmarking without any further analysis.

The AER's findings are based on a 2005 report prepared for the Australian Greenhouse Office on energy efficiency. This report states that the majority of lamps in Australia are replaced every four years. However in this report the authors admitted that "Little information about end of life batch changeovers was provided by distribution businesses as input to this project." The report also stated that "Lamp data varies between distributors and manufacturers – and there is a considerable amount of conflicting information in the marketplace." The report relied on by the AER did not cite any cost benefit analyses used by utilities upon which the four year cycle assumption was based. The report therefore cannot be relied upon as a sound technical basis for setting the cycle for bulk lamp replacement.

The report has ignored information provided by EnergyAustralia in its previous submissions that demonstrates the efficiency of the assumption used within our public lighting model.

EnergyAustralia's bulk lamp replacement programme results in efficient costs. The bulk lamp replacement programme is used to reduce the total number of required spot lamp replacements. Instead of changing lamps when they fail on a case by case basis, the bulk lamp replacement programme is designed to optimise costs of replacement by undertaking replacement of all lamps in a location at the same time. By undertaking lamp replacements in bulk, the number of calls to replace assets in a particular location is reduced and the costs associated with travel time and resources is optimised to achieve cost effective replacement of assets within their design life. For bulk lamp replacement to be effective, it is critical that lamps are replaced before they fail. Therefore the cycle of bulk lamp replacement is a critical factor in determining the cost effectiveness of the bulk lamp replacement programme and the efficiency of costs overall.

EnergyAustralia has based its programme cycle of 2.5 years on an extensive technical review of lamp failure rates and costs, conducted using Weibull probability distribution analysis. The conclusion of this detailed analysis (provided as Attachment 1) is that the bulk lamp replacement programme should be conducted over a 2.5 year time frame ²⁵. This conclusion was on the basis that a 2.5 year timeframe provides the most efficient cost outcome between spot lamp replacements and bulk lamp replacements. Any extension of this time frame will increase the frequency with which spot lamp replacements occur, and consequently decrease the cost effectiveness of the bulk lamp replacement program.

The AER's change to the bulk lamp replacement cycle from 2.5 to 3 years will result in less efficient operating costs for public lighting customers in EnergyAustralia's area. Not only will costs increase, the resources required to manage higher rates of spot lamp replacement will also increase. This is not an efficient outcome for EnergyAustralia, its customers, or the

Public Lighting in Australia – Energy Efficiency Challenges and Opportunities Final Report 2005

Network Maintenance Standards - Street Lighting Analysis Report, 9th January 2004

community and will not contribute to the achievement of the national electricity objective.

For these reasons, EnergyAustralia submits that the AER must change its assumption for bulk lamp replacement for EnergyAustralia's network area. If it does not do so, it must increase operating costs to cater for the higher total costs resulting from the longer cycle of bulk lamp replacement and consequent higher spot lamp replacement rate.

EnergyAustralia notes that the replacement cycle appropriate for each network may be different due to the different characteristics of the assets being used, the maintenance policies in place, different operating and performance standards and varying environmental conditions that apply. For example, the Victorian Public Lighting Code (in addition to four year replacements at non-major roads) has a minimum standard that requires the DNSP to "routinely patrol at night to inspect, replace or repair luminaires at least three times a year" 26. This requirement is significantly more stringent than a bulk lamp replacement programme of 2.5 years used by EnergyAustralia.

In making its decision, the AER must consider the operating conditions, asset type and environmental factors relevant to each provider before applying assumptions to other networks. Failure to do so demonstrates a lack of technical understanding of assets and their life cycle costs.

Recovering the costs of bulk lamp replacement

The total cost of the bulk lamp replacement programme is \$3 million per annum. Luminaire maintenance is carried out in conjunction with lamp replacement and includes the labour associated with the cleaning and refitting of luminaires. EnergyAustralia's public lighting economic model allocates this maintenance cost on the basis of the number of luminaires serviced under the bulk lamp replacement programme. The number of luminaires serviced per year decreases as the length of the bulk lamp replacement programme cycle increases.

In its March 2009 draft decision, the AER changed the formula in EnergyAustralia's model that allocates the luminaire

Victorian Public Lighting Code, Office of the Regulator General, September 2001 maintenance cost. We assume that this change has been made to make the allocation basis consistent with the cycle of the bulk lamp replacement programme which the AER considers should be carried out over 3 years. The AER purported that the effect of this change is to decrease total operating costs over the five year period by \$3.8 million. This reduction in expenditure is totally unjustified because a lengthening of the cycle of bulk lamp replacement from an optimal length of 2.5 years to a sub-optimal cycle of 3 years (as discussed above) would lead to an increase in total operating costs driven by a higher number of more expensive spot lamp replacements.

By over-riding the formula in EnergyAustralia's model, the AER has not only misunderstood the model (see section 2.2), but has penalised EnergyAustralia two fold by increasing the overall forecast costs due to the sub-optimal replacement cycle, but has decreased allowed operating expenditure. This means that the gap between forecast efficient costs and allowed costs has increased. This further demonstrates that the AER's decision does not allow EnergyAustralia a reasonable opportunity to recover efficient costs.

The AER's decision demonstrates it has failed to acknowledge that an extension of the bulk lamp replacement cycle will in turn increase the spot lamp replacement rate, and that operating costs will need to increase to cover costs, rather than fall as the AER has proposed.

EnergyAustralia reiterates the fact that the most cost effective and efficient programme length for bulk lamp replacement for EnergyAustralia's network is 2.5 years.

Spot lamp replacement rate

In its March 2009 draft decision, the AER recommended that the spot lamp replacement rate be changed to show the improvement in the spot replacement rate as a result of the bulk lamp replacement being introduced in other networks. The AER considered this would result in prices being more cost reflective.

EnergyAustralia is concerned that this request shows a lack of understanding of what is included in the costs categorised as 'spot replacement' and a lack of understanding of how we have allocated these costs using its public lighting model.

(continued)

There are two key issues that should be understood:

- Spot lamp replacement rate is directly related to the cycle of the bulk lamp replacement program.
- Spot lamp replacement program includes all operating costs other than the costs associated with the bulk lamp replacement program.


Relationship between bulk and spot

The rate of spot lamp replacement is directly related to the presence of a bulk lamp replacement program and the program's cycle.

EnergyAustralia has set its bulk lamp replacement cycle at 2.5 years following detailed assessment of asset types and failure rates. Our analysis has shown a clear relationship between rates of bulk and spot lamp replacement. If the bulk lamp replacement programme cycle is extended, the spot lamp replacement rate will increase.

This is illustrated in Figure 1 below which shows how the spot lamp replacement rate is influenced by a change in the bulk lamp replacement rate. For a SON1*150 the spot lamp rate increases from 6.7% to 6.9% per year as a result of the change from a 2.5 year bulk lamp replacement programme to a 3 year programme.

Figure 1: Spot Lamp Replacement Rate as a result of Bulk Lamp Replacement (for a SON1*150 lamp)



EnergyAustralia introduced its bulk lamp replacement programme for the Sydney region in 2006. The Sydney region, which accounts for the majority of EnergyAustralia public lighting network, has already completed a cycle of bulk lamp replacement. The total maintenance costs therefore already reflect the introduction of the bulk lamp replacement and any savings that have been forthcoming as a result of its introduction. EnergyAustralia has a tender for a similar programme to be established in the Newcastle region in 2009. The forecast costs for the Newcastle region take account of the forecast bulk lamp replacement program and therefore reflect efficient costs.

The relativity of the cost of bulk and spot replacement is important when undertaking the analysis to determine the optimal cycle for bulk replacement. However, once established, the total operating costs that result with a bulk replacement lamp replacement program of optimal length in place can be considered as being efficient. The allocation of the total costs to prices is a separate consideration.

Cost allocation methodology

As set out in section 2.2, EnergyAustralia's public lighting model allocates the efficient operating costs to individual assets by first, allocating the cost of the bulk lamp replacement program equally to each lamp, and then allocates the cost of the spot lamp replacement program (i.e. all other operating expenditure) to lamps based on lamp locations and lamp type. The cost of the spot lamp replacement program has reduced over time as bulk lamp replacement program has been introduced across the network (i.e. costs have moved out of spot lamp replacement and into the bulk lamp replacement program).

EnergyAustralia considers its allocation method to be reasonable as it evenly spreads the costs of the bulk lamp program across all lamps, but attributes a higher proportion of costs of the spot replacement program to lamps that are typically more difficult to access (i.e. on traffic routes) or more expensive.

The spot lamp replacement program includes all non-bulk lamp replacement operating costs, including costs that would normally be called 'other' costs. These costs include reconstruction of a light where a car hits a pole and typically are

do not change as a result of the introduction of the bulk lamp replacement program.

The AER has proposed that the spot lamp replacement cost should fall by 20% as a result of the bulk lamp replacement program being introduced. However, for this to be the case, a comparison must be made between the costs of spot lamp replacement with and without bulk replacement. As EnergyAustralia already has the cost of the bulk replacement incorporated in its actual costs, and therefore in its forecast costs, the comparison is irrelevant. Furthermore, as EnergyAustralia's public lighting model captures all non-bulk replacement operating expenditure in the spot lamp replacement category, the comparison is not valid unless all 'other' operating costs are removed from the category and all spot lamp replacement operating costs vary as a result of the bulk program.

The AER should reconsider its statement that EnergyAustralia's current allocation methodology is not cost reflective, and reconsider its proposal that the spot lamp replacement rate be reduced.

RAB allocation to components

The AER's March 2009 draft determination applies a limited RAB roll forward method to calculate prices for assets installed prior to 1 July 2009. In establishing this model, the AER has set a regulatory assets base (RAB) of \$111 million and requires this to be allocated to public lighting components on the basis of its written down value rather than on a replacement cost basis. The effect of allocating the RAB on a written down basis is that older components (with a shorter than average remaining economic life) will not be allocated as much of the \$111 million asset base. Components that have been installed more recently (which have a longer than average remaining economic life) will be allocated more of the \$111 million than they would under the replacement cost valuation. The effect of this change is that less depreciation (and hence less revenue) is recovered under the limited RAB roll forward approach.

It should be noted that the limited RAB methodology was not proposed by EnergyAustralia but proposed by the AER in its November 2008 draft decision. Despite its significant variation to the annuity method, EnergyAustralia prepared a second set of prices that specifically met the approach detailed in the November 2008 decision. EnergyAustralia considers that the

recommendation to construct a limited RAB price model using written down RAB values has no sound economic basis, but has been proposed as a means by which the AER can lower the revenue that EnergyAustralia is otherwise entitled to recover through prices.

EnergyAustralia considers that the allocation of the RAB on the basis of replacement costs is entirely reasonable, given the widespread use of replacement cost valuations across a range of industries. Furthermore, EnergyAustralia considers that the allocation on the basis of replacement cost is more consistent with an annuity approach proposed by EnergyAustralia in the first instance. Allocation of the RAB using replacement cost means that all assets have an equal share of the RAB attributed to them regardless of the assets age which we argue is appropriate given that those assets provide the same service. EnergyAustralia does not consider the age of the asset to be relevant to the cost of the service provided by that asset if the service meets established performance criteria.

EnergyAustralia considers that the AER has imposed its own methodology of a roll forward approach without addressing itself to the methodology put forward by EnergyAustralia or the basis behind it. EnergyAustralia considers that the AER, by mandating the use of a limited roll forward model and mandating the allocation of the RAB on the basis of a written down value is not providing EnergyAustralia with an opportunity to recover efficient costs of providing public lighting services.

Economic life of supports

In its November 2008 draft decision, the AER noted that 35 years was the appropriate age for public lighting supports on the basis that this was consistent with the lives of similar assets in other jurisdictions. EnergyAustralia considers this decision to be unreasonable and again caused by applying high level benchmarking without an appropriate understanding of the technical issues involved in establishing an asset's life.

EnergyAustralia considers 20 years is the appropriate technical life for supports as this is a widely held industry standard for galvanised steel. The galvanising of support brackets is consumed over time, particularly in coastal areas where salt air wears the galvanisation and then corrodes the steel used for the supports. EnergyAustralia's network area is located along the coast from the Royal National Park in Sydney's south to

(continued)

Nelson Bay north of Newcastle and therefore has a large proportion of assets in coastal areas which are more susceptible to salt corrosion.

The comparison with asset lives in other jurisdictions is not particularly relevant given the factors that drive asset condition are not consistent amongst the jurisdictions (i.e. not all networks are located predominantly on the coast).

Given the likelihood of corrosion, EnergyAustralia considers that supports should have a useful life that aligns with the luminaire (i.e. 20 years) in recognition of the industry standard and so that replacement of the luminaire and the support can be undertaken together.

To further demonstrate that the asset's life is approximately 20 years, EnergyAustralia carried out a bottom up analysis of public lighting capital expenditure over the last 10 years. Two scenarios were carried out for supports; one with an economic life of 20 years, and one with an economic life of 35 years. Capital expenditure under the bottom up analysis more closely matches actual expenditure where supports are assumed to have an economic life of 20 years.

EnergyAustralia maintains that a 20 year economic life on supports will deliver more cost reflective prices than would be generated with a 35 year assumption.

If the life of supports is extended from 20 years to 35 years, further operating expenditure must be added to our proposed operating costs to pay for the costs of maintaining aging galvanised steel supports for an additional 15 years.

As part of its January 2009 interim submission EnergyAustralia prepared prices with supports at a 35 year economic life²⁷. This was in response to the AER's request and should not be viewed as an acceptance of this assumption by EnergyAustralia.

Economic life of lamps

In its March 2009 determination, the AER recommended that economic life of 3 years be assigned to lamps rather than 2.5 years. We assume this change was made to match the economic life of the asset (based on bulk lamp replacement) with its technical life.

EnergyAustralia considers that it is appropriate for the economic life and technical life to be aligned. EnergyAustralia has demonstrated that the technical life of lamps is 2.5 years. It is therefore inappropriate for the economic life to be changed from 2.5 years to 3 years.

EnergyAustralia considers that the economic life should be consistent with the bulk lamp replacement cycle of 2.5 years.

2.5 New problems as a result of AER decision to use asset roll forward

This section identifies issues which arise in relation to AER's proposed approach to the pricing of retrofitted and new assets introduced during the next regulatory control period and demonstrates how these issues are resolved if an annuity approach is applied.

Inconsistent consideration of asset age

The arguments used by the AER in favour of using written down value of assets for allocation of the RAB to assets was that using replacement cost results in the allocation of the RAB being higher on older assets and lower on newer assets than it should.²⁸

For this to be true, the AER must consider that replacement cost would overvalue past investment. This would only occur where prices have risen by more than just CPI over time. If this is the case, and this concern was extended into the future, the AER must also conclude that materials prices will increase in real terms. In a similar fashion, the 2008 replacement cost is likely to undervalue future investment. The AER has addressed its concern about past assets by requiring service providers to

This information was provided to the AER in response to a modelling request, and only took account of the impact of the change on depreciation. It did not incorporate the increase in operating expenditure that would be required if this assumption were applied.

²⁸ March decision, p17.

use the written down value of capital costs. However, the AER has not done enough to ensure the future value of capital is similarly protected.

The AER has not proposed to use a materials escalator within its model, and in fact, by separating out the assets that have been installed before and after 1 July 2009, the AER has effectively reduced the prices paid for past investment at the same time as it has under valued future investment. This inconsistency of approach over time, and the use of different assumptions in each model creates opportunities for real value to be lost or gained. In this decision, the AER's application of two models using different assumptions has led to a loss in value for EnergyAustralia and other NSW public lighting service providers.

If asset age is seen as an important allocating factor of cost for the RAB, it would be consistent for asset age to be is an equally important factor in the allocation of operating expenditure. This would be consistent with the view that older assets are more likely to fail and are typically more expensive to maintain compared to newer assets. Therefore, a higher proportion of maintenance costs should be allocated to older assets than newer assets.

The AER has not proposed that operating costs be allocated on the basis of age, and has instead, agreed to a smearing of operating costs across assets regardless of age. In doing so, the AER has shown its approach to be internally inconsistent in that it has used asset age as a primary driver of capital costs, but has ignored age in the allocation of operating costs. EnergyAustralia does not consider this inconsistency to be appropriate in the context of a roll-forward approach.

In contrast, the annuity approach does not explicitly consider age for either capital or operating costs. Instead, it calculates an equal annual charge for both considering the life cycle cost of the asset.

The AER's introduction of a roll-forward model in parallel to an annuity model is inherently inconsistent and does not consistently address the issue of asset age as an allocating factor for costs.

Use of historic costs within annuity model

The AER did not consider measures that might have been implemented within the annuity model to remedy the problem

it perceived with the use of replacement costs. The AER did not consider using an historic value for assets within the model despite the fact that historic values could be derived in a similar way to developing an asset roll-forward. Instead, the AER rejected the entire model in favour of its own model.

EnergyAustralia considers the use of replacement cost as being appropriate, but we note that historic asset values could be used within an annuity model. The use of historic values for assets already installed would lead to more than one price list – one for assets installed before 1 July 2009, and one for assets installed after this date. While EnergyAustralia does not favour two price lists, two price lists using a similar model (the annuity approach) is preferable to deriving two price lists from two different models, particularly when one is a roll forward model.

The use of an annuity approach for pre- 1 July 2009 assets and one for post- 1 July 2009 assets was not considered by the AER. Had it done so, the number of issues outstanding, the internal inconsistency and the complexity of the outcome would be significantly reduced. EnergyAustralia considers that the use of an annuity approach with historic costs for pre- 1 July 2009 assets would be more likely to represent a legitimate exercise of discretion on the basis of concern about replacement cost. The outright rejection of an annuity approach and substitution of a roll-forward model is not.

Historic cost prevents competition

EnergyAustralia considers that the use of depreciated costs and an asset roll forward approach ensures that the cost of public lighting services provided by existing assets will always be lower than the cost of services provided by new assets (assuming costs of service increase over time). This means that customers have an incentive to stay with the current provider of public lighting services and effectively prevents competition for services in areas where public lighting assets already exist.

If prices for public lighting services were set using replacement cost, the cost to the customer of choosing another lighting provider would be equivalent, and is therefore more likely to encourage wider competition in the market for public lighting services

EnergyAustralia notes that the Rules require the AER to explicitly consider the scope for competition in the market for alternate control services. The draft decision made by the AER

(continued)

actively discourages competition in the market for public lighting services, and also reduces incentives for customers to move to energy efficient lighting. This issue is discussed further in section 2.2.

Retrofit rate

In its January 2009 revised proposal EnergyAustralia reviewed its calculation of the retrofit rate, tariff class 6 (now tariff class 5). This is the rate that would be charged to customers that require components to be replaced before the end of their economic life. In the March 2009 draft decision the AER provided a response to this revised calculation. The AER rejected the method proposed by EnergyAustralia on the basis that using a replacement cost valuation would not encourage customers to select an alternative component before the end of the existing component's useful life.

EnergyAustralia has considered the AER's arguments and believes that it has some merit in the context of a framework that results in two price lists, one for assets installed before 1 July 2009, and those that are installed after that date. However, if all public lighting components are priced under the annuity method using the replacement cost as proposed by EnergyAustralia, this problem would not occur. Customers would be able to select new components (such as energy efficient lights) without seeing a significant price differential between existing prices and the corresponding retrofit price. A single price list based on replacement cost creates the right incentives for customers to choose public lighting assets that are more energy efficient.

The March 2009 draft decision proposes that retrofit prices will be approved on a case by case basis by the AER, which states that "these tariffs should be calculated at the time of the agreement with the customer based on an agreed method for determining residual asset value." ²⁹

EnergyAustralia does not consider a case by case assessment of retrofit prices to be consistent with the Rules, which requires a form of control to be specified, nor is it generally consistent form of regulation contemplated for alternative control services.

EnergyAustralia has raised concerns about the AER not having established a form of control in its November 2008 draft decision, which have now been largely remedied in its supplementary draft decision released in March 2009. The exception is for retrofit prices which have not been established either by way of a price schedule or a cap on the price of the service.

While the exact price may not be able to be established because new assets/technologies may not be available yet, we consider the AER could meet its obligations with respect to imposing a control mechanism by establishing a formula by which retrofit rates could be calculated in future. A formula would result in a clear mechanism by which customers could determine the value of retrofitting assets. Without an established mechanism, the retrofit value proposition is unknown to customers and is subject to dispute. EnergyAustralia considers the lack of guidance to be likely to lead to difficult negotiations and delays as has been seen during 2008/09.

If EnergyAustralia cannot reach agreement directly with customers for retrofit rates, we assume that the matter will be referred to the AER and that customers will be required to wait for a formal process to take place. The AER stated that its process for approving new components would take up to 6 months³⁰ and we therefore expect a similar length process to determine retrofit prices given the relationship to new products. EnergyAustralia does not consider the proposed process to be an efficient form of regulation that will result in timely outcomes for EnergyAustralia or its customers. We are concerned that in the absence of a control mechanism or an agreed timeframe within which the AER will make its case by case assessment, customers will avoid replacing equipment early even where there are energy efficiency benefits of doing so. This will essentially delay the uptake of new technologies at the expense of rate payers who seek energy and financial

²⁹ Draft Distribution Determination 2009-10 to 2013-14 Alternative control (public lighting) services p46

³⁰ Supplementary draft determination for alternative control services, p53.

efficiency. EnergyAustralia seeks clarification of the process with which the AER proposes to monitor the application of retrofit prices to customers who request the early removal of public lighting components.

The AER has further complicated matters by requiring that customers being charged the retrofit rate (tariff class 5) will revert to the corresponding residual free rate (tariff class 3 or 4) "once the residual value of the asset has been returned to the DNSP". EnergyAustralia also seeks clarification from the AER as to how it considers DNSPs will be able to determine that a customer has paid the residual value of a component removed before the end of its economic life given the limitations of current asset systems and the lack of asset age information. EnergyAustralia considers that this requirement relies on a detailed asset base for public lighting including asset age, and requires prices to be calculated for each asset to determine the retrofit prices specific to the date of installation and replacement of each asset. Such a system does not currently exist within EnergyAustralia. A system like this would be administratively complex and expensive to develop and would be used to calculate prices for a relatively small number of assets, particularly if the AER set prices that did not have sufficient incentive to encourage retrofitting.

The costs of developing pricing capability of producing these prices, as well as an asset system that records detailed age information for each component has not been factored in to EnergyAustralia's future operating costs for the 2009-14 regulatory period. Given the time available to comment on the AER's draft decision, EnergyAustralia has not been able to forecast the costs of making these system changes. However, the AER must consider the scope and detailed costing of such system changes if it intends to mandate these requirements in its final determination. Failure to do so will result in the AER not providing EnergyAustralia with sufficient opportunity to recover efficient costs as the Rules require.

EnergyAustralia does not consider the costs of these system changes to be outweighed by the benefits of asset specific retrofit prices. Furthermore, EnergyAustralia regards this issue as one of several problems that has been created by the AER's decision to change the framework to a asset roll forward model away from an annuity approach using replacement cost (as proposed by EnergyAustralia) in which these issues are avoided.

2.6 Inconsistencies and errors

This section briefly sets out inconsistencies and errors that have been identified within the AER's March 2009 draft decision. The purpose of raising these matters is to enable them to be addressed during the finalisation of this decision.

Allocation of capital costs

EnergyAustralia has reviewed the AER's model used in its March 2009 draft decision and has identified a modelling error in the allocation of capital costs to components for the purpose of generating prices under the roll forward method.

Prices under this method are generated by allocating allowable revenue across components by using a weighting of capital and operating costs. These weightings are taken from the annuity model. However EnergyAustralia believes that the weightings used by the AER for capital costs come from an out of date version of model.

As the AER has revised other assumptions relating to capital costs in the annuity model, the AER must also recalculate the prices in the draft decision for the limited RAB roll forward price list using the correct weightings for capital and operating costs.

Total cost of bulk lamp replacement

Figures in Table 3.7 on page 26 of the March 2009 Draft Decision do not show the total cost of a bulk lamp replacement. The \$31.46 figure corresponds to the cost of servicing a lamp and luminaire during a bulk lamp replacement programme of 2.5 years, and therefore only relates to the capital cost (i.e. does not include the capital cost of the lamp). Similarly, the AER appears to have derived the "cost of bulk replacement per lamp per annum" of \$12.58 by dividing \$31.46 (as above) by the cycle of the bulk lamp replacement programme (i.e by 2.5). Again, EnergyAustralia notes that the capital cost of the lamp is not included in this figure.

If the AER is seeking to compare the cost of the bulk lamp replacement program per lamp with other providers, it must include the capital and operating costs associated with the program to ensure a like for like comparison.

2. EnergyAustralia's response (continued)

Price change for FY2010

The AER calculated that prices for public lighting services in EnergyAustralia's area will decrease by 6% in FY 2010. This calculation is based on a simple average of price movements and does not consider the relative volumes of assets of each

type. EnergyAustralia considers the AER's simple average to misrepresent the outcome of its decision to customers. EnergyAustralia has reviewed the impact of the AER's decision and has calculated that the average price increase for next year will be -1.2% under the new draft decision (or -0.8% when the AER's error relating to price weighting under the limited RAB roll forward is removed).

Attachments

Attachments

Attachment 1: Network Maintenance Standards, Street Lighting Analysis Report, prepared by J. Hardwick & G. Winsor

(9 January 2004)

Attachment 2: Letter from EnergyAustralia dated 26 March 2009 (CONFIDENTIAL document)

Attachment 3: Update EnergyAustralia annuity model (CONFIDENTIAL document)

570 George Street Sydney NSW 2000 Telephone 12 15 35 Facsimile 02 9269 2830

Postal Address: GPO Box 4009 Sydney NSW 2001

EnergyAustralia offices are open between 8.30am and 5.00pm Monday to Friday

Emergency Services are available 24 hours a day Telephone 13 13 88

Internet Address: www.energy.com.au



Network Maintenance Standards

Street Lighting Analysis Report

Prepared and presented by John Hardwick & Gary Winsor

Revision: 04

Date: 09 January 2004

Contents

BACKGROUND	3
APPROACH	3
LAMP LIFE ANALYSIS	4
STREET LIGHTING STRATEGIES	6
RECOMMENDATION	8
APPENDIX 1 – WEIBULL ANALYSIS	9
APPENDIX 2 – SUMMARY DATA AND WEIBULL DISTRIBUTION PLOTS	22
APPENDIX 3 – COST CURVES	26
APPENDIX 4 – MAINTENANCE REQUIREMENTS ANALYSIS REPORT	34

Maintenance Standards - Street Lighting

Background

A maintenance requirements analysis has been undertaken as part of the Maintenance Standards Project to review the current disparate street lighting maintenance strategies existing across the energy Australia.

The analysis was undertaken using the current procedures documented in the Maintenance Requirements Analysis Manual and implemented using the MIMIR software.

The Newcastle/Maitland and Chatswood areas were selected to participate in the analysis as dedicated street lighting teams existed in these areas. In addition the Chatswood team operated with a Bulk lamp Replacement strategy and the Newcastle team operated with a spot replacement strategy which allowed the two different approaches to be considered.

The Analysis Team comprised a mixture of engineering and field staff included:

Keith Newland, Don Wijayasinghe, John Hardwick, Peter Power

Part Time - Peter Edwards, Bob Sloan

Newcastle: Cindy Newman, Robert, Dale

Chatswood: Col, Col, Craig Gary Winsor (Facilitator)

Approach

The street lighting FMECA and RCM analysis was performed by the team to identify failure modes and used to capture data against the failure modes to identify valid maintenance tasks using the MIMIR software.

The failure modes associated with the lamp includes a presumption of an age related degradation characteristic for both lamp failure and light output.

The selection of a proposed maintenance task to manage *lamp failure due to age degradation* and *reduction of lumen output to less than 70% of design due to age degradation* as assumed to be a scheduled discard of the lamp.

To determine the validity of a scheduled discard task, failure data from the start of life for each lamp type would be required. The benefit of the Newcastle area having a spot replacement strategy only operating was that the data from start of life was available and would lend itself to a Weibull analysis to determine the wear out characteristic of the various lamp types.

The Weibull analysis was performed using the Isograph AVSIM+ software. Over 70,000 lamp failure and replacement records from the Newcastle data would be analysed to establish if there is a clear wearout characteristic associated with the lamps age degradation failure mode and where it occurs. This would then be compared with the manufacturer's data to establish whether the lamp mortality or the reduction of lumen output was the replacement driver. The task costs of lamp replacement using the two strategies would then be compared to determine if a theoretical optimum bulk lamp replacement period existed. A NPV would then be performed to compare the total value of the task costs and any additional supporting tasks required to make each into a strategy viable from and engineering and performance perspective.

Lamp life Analysis

The lamp life data was collected from the NAMS Public Lighting Database for the Newcastle region with a start date of 1/1/98. This data was sorted by lamp type and in ascending order of failure dates. Failures of lamps at a life of shorter than 10 days were removed from the analysis as these were considered to be due to installation / handling / transport issues and not associated with the inherent reliability of the lamp.

The results of the Weibull analysis for each lamp type are attached in Appendix 1 – Weibull Analysis. The summary of Weibull distributions for the various sized lamps within a technological family are attached in Appendix 2 – Summary Data and Weibull Distribution Plots.

This is summarised in the table 1 below.

			η	β	γ		
Lamp Type	Population	Comment	Characteristic Life (days)	1=Random, >1 wearout	location parameter	Days to 10% of units failed	Days to 15% of units failed
INC1*50	1	Insufficent Failure Data	-	-	0	-	-
INC1*300	1	Insufficent Failure Data	-	-	0	-	-
MBF1*50	28738		5,144.3	1.345	0	965.7	1,332.8
MBF1*80	11303		4,178.5	1.404	0	840.9	1,145.1
MBF1*125	112		5,985.5	1.055	0	709.0	
MBF1*250	1544		3,701.7	1.310	0	664.5	925.0
MBF1*400	1270		3,372.2	1.635	0	851.8	1,110.2
MBF1*500	21	Insufficent Failure Data	-	-	0	-	-
MBF1*700	4	Insufficent Failure Data	-	-	0	-	-
MBF1*800	2	Insufficent Failure Data	-	-	0	-	-
MBF3*250			1,645.7	0.492	0	17.0	41.1
MBI1*1000	1	Insufficent Failure Data	-	-	0	-	-
MBI1*150	4	Insufficent Failure Data	-	-	0	-	-
MBI1*250	9	2 failures only	16,892.4	0.488	0	167.5	407.4
MBI1*70	1	Insufficent Failure Data	-	-	0	-	-
SON1*100	1	Insufficent Failure Data	-	-	0	-	-
SON1*150	4567		3,448.3	1.275	0	590.2	829.1
SON1*220	29		2,498.5	1.091	0	317.8	472.7
SON1*250	6240		2,422.1	1.437	0	505.7	683.8
SON1*310	154		2,204.5	2.751	0	972.9	1,138.9
SON1*360	13	Insufficent Failure Data	-	-	0	-	-
SON1*400	172		2,763.6	1.300	0	489.7	683.4
SON1*1000	3		-	-	0	-	-
SON1*50	10	2 failures only	822.6	37.201	0	774.3	783.3
SON1*70	504		2,167.0	1.440	0	454.1	613.5
SON2*250	7	Insufficent Failure Data	-	-	0	-	-
SON4*250	12	4 failures only	2,521.3	0.965	0	244.9	383.7
SON4*600	14	•	889.0	1.141	0	123.6	180.7
SOX1*135	663		1,811.2	3.338	0	922.9	1,050.8
SOX1*180	4	Insufficent Failure Data	-	-	0	-	-
SOX1*90	253		1,686.2	3.374	0	865.4	984.0
TF1*20	12	3 failures only	1,458.0	3.524	0	769.9	870.6
TF1*40	4070	-	2,318.0	1.512	0	523.0	696.7
TF1*80	2413		2,032.2	1.561	0	480.6	634.4
TF2*20	8490		2,069.7	2.303	0	778.8	940.2
TF2*40	23	5 failures only	1,865.3	2.047	0	621.2	767.7
TF4*20	7	Insufficent Failure Data	-	-	0	-	-
TF4*40	10	Insufficent Failure Data	-	-	0	-	-
TH1*1000	8	3 failures only	766.4	2.059	0	256.9	317.1
TH1*1500	2	Insufficent Failure Data	-	-	0	-	-
TH1*500	11	3 failures only	1,602.7	1.587	0	388.2	510.1
TH1*750	41		1,059.7	1.153	0	150.4	219.1

Table 1 – Full Weibull Results

This data was then reduced by the analysis team for further analysis to lamp types which had a population of 100 or more lamps in the sample.

The reduced set of lamps was then analysed against cost of BLR and spot replacement strategies to evaluate if there was a valid bulk lamp replacement period associated with the lamp type. The results of this analysis is included at Appendix 3 – Cost Curves.

The lamp life with calculated as documented in table 1 above at the 10 and 15% of population failed period is included on the graphs in Appendix 3 for comparison against the minimum cost.

The manufacturer data for the lumen output depreciation and periods to 10 and 15% of population failed period is summarised in Table 2 – Manufacturer lamp data summary below. This was produced from Charts and Datasheets provided to Energy Australia by the manufacturers, but the data was incomplete for a number of manufacturers.

Lumen Depreciation:

Manufacturer Data Sheet Extracts

Lao Do	Manaratari Bata Griott Extraoto								
Lamp Type	Manufacturer	Model	Initial Lumens	Calculated 70%	Estimated Hrs to 70 %	Estimated days to 10% failed	Estimated days to 15% Failed		
MBF1*50	Osram	HQL50W	1,800	1,260		-	-		
MBF1*80	Osram	HQL80W	3,800	2,660		-	-		
MBF1*125	Sylvania	HSL-BW125	6,300	4,410	10,250	1,062.50	1,312.50		
MBF1*250	Osram	HQL250W	22,000	15,400		-	-		
MBF1*400	Osram	HQL400W	40,000	28,000		-	-		
SON1*70	Philips	SON70WI	5,600	3,920	23,500	1,125.00	1,416.67		
SON1*150	Osram	NAV-E150W	14,000	9,800		-	-		
SON1*250	Osram	NAV-T250W	27,000	18,900		-	-		
SON1*310				-		-	-		
SON1*400	Osram	NAV-T400	48,000	33,600		-	-		
SOX1*90	Osram	SOX90W	13,500	9,450		-	-		
SOX1*135	Osram	SOX135W	22,500	15,750		-	-		
TF1*40	Osram	L36W/20	2,900	2,030	<8000	666.67	-		
TF1*80	Osram	1.65W/20	48 500	33 950	<8000		-		

Table 2 - Manufacturer lamp data summary

When comparing the manufacturer's estimated time to 10% of the population failed (table 2 above) against that generated by the Newcastle statistics in Table 1 there is evidence that the manufacturer mortality data is significantly more optimistic than the actual field performance data.

The comparison of available manufacturer lumen depreciation against the Newcastle area generated data on lamp mortality and approximate cost optimum periods are summarised in table 3 below. This appears to indicate that lumen depreciation may not be the driver for lamp replacement, but rather the costs associated with replacement of lamps.

Lamp Type	Manufacturer days to 70% Lumen output	BLR Cost Optimum (~Days)	Days to 10% of units failed
MBF1*50	-	900	966
MBF1*80	-	720	841
MBF1*125	932	800	709
MBF1*250	-	800	664
MBF1*400	-	850	852
SON1*150	2,136	990	590
SON1*250	-	750	506
SON1*310		800	973
SON1*400	-	720	490
SON1*70	-	630	454
SOX1*135	-	800	923
SOX1*90	-	800	865
TF1*40		600	523
TF1*80		540	481

Table 3 – Manufacturer lamp data and analysis data summary

One of the anomalies identified as part of the analysis is the higher failure rate of the fluorescent tubes in the Newcastle sample area compared to the preliminary data from the Mosman street lighting trial. The data from the Mosman trial is as yet incomplete and needs to be further investigated with respect to the failure rates of the fluorescent tube installations.

Street Lighting Tasks and Strategies

average

411 25

The bundling of the proposed maintenance tasks on other street lighting components identified as part of the FMECA/RCM will be dependant upon the strategies developed to handle the lamp life.

The FMECA/RCM condition monitoring data algorithm (using the available data) was able to determine valid task intervals for one task, with two intervals depending upon the method used to execute the task. These are

installations). (Visual – 50% task effectiveness) or

511days +/- 100 days Examine SLP contactor connections for overheating using

Thermography (Kiosk SS installations). (Task effectiveness 80%)

The FMECA has identified the following one off examination task to identify and remove a type of defective lighting assembly.

Within 1 yr Examine Sylvania B2229/B3000 fitting for cracks.

To ensure that the availability of the street lighting system remained above 95% as per AS/NZS 1158.1.3:1997 Road lighting - Vehicular traffic (Category V) lighting - Guide to design, installation, operation and maintenance, a strategy of BLR alone at the optimum periods identified in table 3 would not meet the requirements of the standard. The introduction of a condition monitoring and failure finding patrol would be required to increase the availability of the street lighting through the detection and resulting removal of defects. This system would be required to operate in addition to the current system where the public advise of defects, as analysis team advised the public appear to only report about 1/3 of the lamp failures.

The reliability of the various lamp types is included at Table 4 below. A potential annual patrol appears possible to maintain the number of failed lamps at less than 5%. These periods are based on using a bulk lamp strategy. If a Continuous Spot Replacement (CSR) strategy is adopted a higher patrol frequency will be required as the effective rate of failure of the population of lamps will be higher.

Lamp Type	Days to 3 % failed	Days to 5 % failed	Days to 7 % failed	Days to 10 % failed	Days to 12 % failed	Days to 15 % failed
MBF1*50	383.9	565.5	731.9	965.7	1114.9	1,332.8
MBF1*80	347.3	503.5	644.7	840.9	965.1	1,145.1
MBF1*125	218.6	358.3	497.9	709.0	851.6	1,069.2
MBF1*250	257.5	383.6	499.9	664.5	770.1	925.0
MBF1*400	398.8	548.5	678.1	851.8	958.7	1,110.2
SON1*150	222.9	335.5	440.5	590.2	686.8	829.1
SON1*250	213.2	306.4	390.1	505.7	578.6	683.8
SON1*310	619.7	748.9	849.6	972.9	1043.8	1,138.9
SON1*400	188.6	281.5	367.6	489.7	568.2	683.4
SON1*70	191.8	275.4	350.4	454.1	519.3	613.5
TF1*40	230.1	324.9	408.7	523.0	594.4	696.7
TF1*80	217	303	378.5	480.6	544	634.4

Table 4 – Patrol interval to achieve 95% availability.

In order to select the appropriate strategy, the choice of the Bulk Lamping strategy or the Continuous Spot Replacement strategy will be based on which solution presents the best

NPV. This has been assessed based on a 4500 day cycle, with a discount rate of 7%. The result of this NPV analysis is shown at table 5 below. The costs have been calculated based on the entire Energy Australia populations of each lamp type, using mortality rates calculated from Weibull parameters generated from the data sets, and Energy Australia unit rates for BRL and CSR activity.

Lamp type	EA Total Population	BLR NPV	CSR NPV	Recommended Strategy
MBF1*50	22,279	\$923,435	\$1,102,113	BLR
MBF1*80	29,000	\$1,207,060	\$1,469,278	BLR
MBF1*125	6,050	\$386,363	\$326,806	CSR
MBF1*250	30,600	\$2,005,769	\$2,349,392	BLR
MBF1*400	16,163	\$1,067,248	\$1,023,878	BLR
SON1*150	474	\$55,164	\$55,595	either
SON1*250	14,989	\$1,802,483	\$2,484,774	BLR
SON1*400	1,690	\$202,546	\$232,369	BLR
SON1*70	2,921	\$297,355	\$485,510	BLR
TF1*40	8,755	\$539,626	\$1,000,410	BLR
TF1*80	749	\$49,604	103,728	BLR

Table 5 - NPV Calculation Results

The difficulty in reaching a final strategy for the management of street lighting is due to the variety of street lights currently in service, and the fact that these do not exist in large areas of homogeneous populations, except possibly at intersections and along portions of the Traffic Route Lighting (TRL). At March 2003 Energy Australia has 53,724 lamps designated as TRL and 186,320 lamps designated as non TRL, each with a large variety of types.

This is further complicated by the variety of 'optimum' BLR periods based on the analysis of each lamp type. However all the data suggests that the current BLR cycle, where used, of 18months (approx 550 days) is too short. The possibility of using a common BLR period may be considered. If all types are considered, then an average of the optimum periods around 760 days results. If the SON 1x70 and TF types are excluded than the average of the optimums is extended out to around 815 days results.

Failures of photocells were also identified in the analysis as a component of concern. Some problems were easily attributable, such as photocells manufactured in the northern hemisphere had instructions on the box stating install facing north. For use in Australia this must be changed to install facing south to prevent early failure of the photocell. Another concern was that the modern photocell housings are plastic rather than metal, and anecdotal responses indicated that these housings were degrading over time. The provision of a BLR strategy would potentially allow the scheduled discard of the photocell at every second BLR action, although the analysis group had not firm objective data to support this conclusion.

Recommendation


The following recommendations are made with respect to the analysis performed on the street lighting system.


- Bulk Lamp Replacement is a viable maintenance strategy, and the programme should be executed on a cycle period of 30 months.
- An annual lighting failure finding patrol is required to manage random lamp outages and corrective action in the form of spot replacements will be essential to maintain the 95% average availability as required by AS/NZS 1158.1.3:1997.
- Photocell replacements every 2nd BLR cycle (ie at 60 Months).
- Implement Design Change: Replace mechanical timer for lighting on the Stockton side of the Stockton Bridge with a photo-electrically operated scheme.
- Examine SLP contactor connections for overheating using Thermography (Kiosk SS installations) every 18 months.
- Examine Sylvania B2229/B3000 fitting for cracks to identify and remove defective fittings as a one off task.


Appendix 1 - Weibull Analysis


Notes


- Data for lamps with status of censored or in service from Newcastle database are considered as 'suspended' for the Weibull analysis
- B10 = days by which 10% of the population is expected to have failed
 - β = 1 = Random Failure
 - $\beta \sim 1.3 we arout$
 - β ~ 2.5 or more rapid wearout
- Some distributions may be closer to normal than weibull. In these cases two graphs for the same data set are presented on the same page










































































109.336

522.82

2500


22.8653


Time


4.78176


0.1


Appendix 2 - Summary Data and Weibull Distribution Plots





















Appendix 3 - Cost Curves








































Maintenance Requirements Analysis Detailed Report

				v	•		
System							
	pment Function						
	Function Failure]	Proposed Task /	Decision Basis
	Failure Mod	e	Effect	E SE O - L OC SR	SD - CB FF RD	Corrective Task	MTBF Basis
Street Ligh	hting						
_		g Control Equipment					
52 0	· ·	ching of lighting assemblies based	on davlight				
	levels.	verming or anguitable massermonaes wastern	on unjugne				
	Lighting not switch	ned when required.					
						N C M	
	11 AF Relays does not swi received.	itch off due to AF Signal not	Wasted energy, shortened globe life.	N N Y - N N N	N – N N	N.S.M.	
			Customer complaints.				
			Customer complaints.				Excessive capacitance
							from customer equipment
							(lighting or UPS Units).
							Estimate from North area
							 1 per week. Nctle 4000, Nth 100 population.
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failure	es MTBF Population	n CF Interval Oj	otimal Scheduled TMP	Actual
rinnary	N/A	0 0.00	100.00 100.00	14,965 4,100	$0 \qquad 0$		Actual
.							
Examination	n Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Cal 0	l Out, Secondary Damage \$ 0	Unplanned Failure Cost 0	Redundancy System	
						System	
Protective	Failures Population	MTBF No Prot. S Repair Co.					
	0 0	0 0 0	0				
	13 AF Relays does not swi	itch off due to bypass (external	Wasted energy,	N N Y -N N N	n – n n	N.S.M.	
	bridge fitted).		shortened globe life.				
			Customer complaints.				
						Remove external bridge when	
						found and repair location.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failure	1	-	otimal Scheduled TMP	Actual
	N/A	0.00	22.00 22.00	68,023 4,100	0 0		
Examination	n Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$ Cal	l Out, Secondary Damage \$	Unplanned Failure Cost	Redundancy	
		0 0	0	0	0	System	
Protective	Failures Population	MTBF No Prot. S Repair Co.	st \$ Double Failure Cost \$				
110000110	0 Population	$\begin{array}{cccc} m_{IBF} & no rrot. s & kepair Co. \\ 0 & 0 & 0 \end{array}$	Double Failure Cost \$ 0				
							_

Maintenance Requirements Analysis Detailed Report

			TVIUITICIIUTICC	rioquii ciiicii	os randijsi	<i>5</i> 2 c c c c c c c c c c c c c c c c c c	a report				
System Equipm Fu	ent inction Function Failure							Proposed 7	Pack /	Decision Basis	
	Function Failure Failure Mode	e	Effect	F	SE O - L	OC SR SD	- CR FF RD	=		MTBF Basis	
Street Lighti				<u> </u>	SE C E	oc sit ==	CD II RD				
SL 01 0	_	g Control Equipment									
	To provide automatic swite		nblies based on daylight								
	Lighting not switch	ed when required.									
	31 AF Relays does not swit	tch off due to electrical sur	ge.	N	N Y -N	N N N	- N N	N.S.M.			
Primary	Operation Loss Description N/A	Operatonal Loss \$	Cond Fail Funct Fail 0.00 86.00	Total Failures 86.00	MTBF 17,401	Population 4,100	CF Interval	Optimal 0	Scheduled TMP	Actual	
Examination	Examination Crew	Time (m) Success 9	% Setup \$ Planned Repair	ir Cost \$ Call Ou	t, Secondary Damo 0	ige\$ Un	nplanned Failure 0	Cost	Redundanc System	у	
Protective	Failures Population 0 0	MTBF No Prot.	S Repair Cost \$ Dou	ble Failure Cost \$							
	14 AF Relays does not swit boxed).	tch off due to internal fault	(black Wasted ener shortened gl Customer co	obe life.	N Y -N	N N N	- N N	N.S.M.			
Primary	Operation Loss Description N/A	Operatonal Loss \$	Cond Fail Funct Fail 0.00 76.00	Total Failures 76.00	MTBF 19,691	Population 4,100	CF Interval	Optimal 0	Scheduled TMP	Actual	
Examination	Examination Crew	Time (m) Success 9			t, Secondary Dame	,	nplanned Failure		Redundanc	y	

9/1/2004

0

System

0

No Prot. S

0

MTBF

0

Population 0

Failures

Protective

0

Repair Cost \$

0

0

Double Failure Cost \$

0

Maintenance Requirements Analysis Detailed Report

System											
Equipmen Fund											
	Function Failure							Proposed	l Task /		Decision Basis
	Failure Mode	e	Effect	E	SE O -	L OC SR	SD - CB FF RE	Correctiv	ve Task		MTBF Basis
Street Lighting	3										
SL 01 00 (00 Street Lighting	g Control Equipment									
To j	-	ching of lighting assemblies b	ased on daylight								
	Lighting not switch	ed when required.									
1	2 AF Relays does not swit received.	tch on due to AF Signal not	Lighting will on. Customer complaints. F safety and see impacts wher of lights are r operating.	Cossible curity re a group	Y Y - N	NNN	N - N Y	N.S.M			Patrol ?
									e AF installat lled SLP.	ion with PE	Excessive capacitance from customer equipment (lighting or UPS Units).
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000 0.00	219.00	219.00	6,833	4,100	0	0			
Examination	Examination Crew	Time (m) Success % Setu	p \$ Planned Repair	Cost \$ Call Ou	t, Secondary D	amage \$	Unplanned Failure	Cost	R	edundancy	
		0 0	0		0		250,000			System	
Protective	Failures Population 0 0		tir Cost \$ Doub	le Failure Cost \$							

9/1/2004 3

Maintenance Requirements Analysis Detailed Report

System		
Equipment		
Function		
Function Failure		Proposed Task /
Failure Mode	Effect	E SE O - L OC SR SD - CB FF RD Corrective Task
Street Lighting		

Street Lighting

Street Lighting Control Equipment SL 01 00 00

> To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

Patrol? Lighting will not turn N.S.M. N Y Y -N N N N -18 AF Relays does not switch on due to circuit fuse (30A) blown. on. Customer complaints. Possible safety and security

impacts where a group of lights are not operating.

Primary	Operation L	oss Description	Operatonal L	oss \$ C	ond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Pi	ublic Injury	250,000		0.00	130.00	130.00	11,512	4,100	0	0			
Examination	Examinatio	on Crew	Time (m)	Success % 0	Setup \$	Planned Repair Cos 0	st \$ Call Out,	Secondary Da	mage \$	Unplanned Failure 250,000	Cost	R	edundancy System	
Protective	Failures 0	Population 0	MTBF	No Prot. S	Repair Cost	t \$ Double F	ailure Cost \$							

9/1/2004

Decision Basis MTBF Basis

Maintenance Requirements Analysis Detailed Report

System					
Equipment					
Function				D 177.17	
	Function Failure			Proposed Task /	Decision Basis
	Failure Mode	Effect	E SE O - L OC SR SD - CB FF RD	Corrective Task	MTBF Basis
Street Lighting					
SL 01 00 00	Street Lighting Control Equipment				
To pr levels	ovide automatic switching of lighting assemblies ba	ased on daylight			
	Lighting not switched when required.				
32	AF Relays does not switch on due to electrical surge.	Lighting will not turn on. Customer complaints. Possible safety and security	N Y Y -N N N N -	N.S.M.	Patrol ?

Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail Too	tal Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	91.00	91.00	16,445	4,100	0	0			
Examination	Examination Crew	. ,	ccess % Setup \$	Planned Repair Cost \$ 0	Call Out,	, Secondary Da 0	mage \$	Unplanned Failure 250,000	Cost	Ro	edundancy System	
Protective	Failures Population	MTBF No	Prot. S Repair Cost	\$ Double Failu	re Cost \$							

impacts where a group of lights are not operating.

Maintenance Requirements Analysis Detailed Report

<u></u>												
System Equipme	ent											
	nction											
	Function Failure								Proposed	Task /		Decision Basis
	Failure Mode	e		Effect	E	SE O - L	OC SR S	D - CB FF RD	Correctiv	e Task		MTBF Basis
Street Lightin	ng											
SL 01 00	00 Street Lighting	g Control Equipme	nt									
	o provide automatic swite	ching of lighting as	semblies based	on daylight								
le	vels.											
	Lighting not switch	ed when required.										
	17 AF Relays does not swit boxed).	tch on due to internal fa	ult (black	Lighting will on. Customer complaints. Posafety and sec impacts where of lights are no operating.	ossible urity e a group	Y Y - N	N N N	- N Y	N.S.M.			Replace AF installation with PE Controlled SLP in long term?
									Replace	e defective A	F unit	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	65.00	65.00	23,023	4,100	0	0			
Examination	Examination Crew	Time (m) Succe.	ss % Setup \$	Planned Repair 0	Cost \$ Call O	ut, Secondary Dai 0	nage \$	Unplanned Failure (250,000	Cost	F	Redundancy System	

Double Failure Cost \$

Failures 0

Protective

Population 0 $_{0}^{MTBF}$

Repair Cost \$

No Prot. S

Maintenance Requirements Analysis Detailed Report

System Equipm	ent											
Fu	nction Function Failure								Proposed	Tack /		Decision Basis
	Function Failure Failure Mod	e		Effect	E	SE 0 - 1	L OC SR S	SD - CB FF RD	-			MTBF Basis
Street Lightin		-				52 0	2 00 51	05 11 10				
SL 01 00	_	g Control Equ	ipment									
T	o provide automatic swit			on daylight								
	Lighting not switch	ned when requi	red.									
	33 AF Relays does not swi connection overheated.	-	circuit neutral	Lighting will not on. Customer complaints. Poss safety and securi impacts where a of lights are not operating.	ible ty	Y Y - N	I N N N	- N Y	N.S.M.			Ex McKellar area problem mainly due to type of installation.
Primary	Operation Loss Description Staff/Public Injury	Operatonal Los. 250,000	s \$ Cond Fail 0.00	Funct Fail 12.00	Total Failures	MTBF 124,708	Population 4,100	CF Interval 0	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew	Time (m)	Success % Setup \$	Planned Repair Cos.	t \$ Call Ou	at, Secondary Do	amage \$	Unplanned Failure 250,000	Cost		Redundancy System	

Failures 0

Protective

Population 0 $_{0}^{MTBF}$

Repair Cost \$

Double Failure Cost \$

No Prot. S

Maintenance Requirements Analysis Detailed Report

System	pment						
	Function						
	Function Failure					Proposed Task /	Decision Basis
	Failure Mod	e	Effect	E SE O - L OC SR	SD - CB FF RD	Corrective Task	MTBF Basis
Street Ligh	hting						
SL 01	1 00 00 Street Lightin	g Control Equipment					
2- 0-		ching of lighting assemblies based	l on davlight				
	levels.		, g				
	Lighting not switch	ed when required.					
		-					
	15 AF Relays false operati frequency.	on due to wrong channel /	Light turns on or off	N Y Y -N N N	N -	N.S.M.	Commissioning Testing
	n equency.		when not expected. Customer complaints.				
			Possible safety and				
			security impacts where				
			a group of lights are				
			not operating.				
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Fai	ilures MTBF Population	n CF Interval O	ptimal Scheduled TMP	Actual
	Staff/Public Injury	250,000 0.00	18.00 18.0	00 83,139 4,100	0)	
Examination	n Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$	Call Out, Secondary Damage \$	Unplanned Failure Cost	Redundancy	
		0 0	0	0	250,000	System	
Protective	Failures Population	MTBF No Prot. S Repair C	ort \$ Death Failes Co				
Trotective	0 0	0 0 0 Repair C	ost \$ Double Failure Cos	\$1 \$			
	20 Contactor does not ope	rate due to manufacturing defect.	Failure evident when	Y N Y -N N N	N – N	N.S.M.	
			commissioning,				
			requires immediate				
			replacement.			Replace unit and re-commission.	
D	On anythin Land Description	On and and I am & Condition	Form Coll Total For	MTDF December	CF Lux	-	Accord
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail 0 0.00	Funct Fail Total Fail 7.00 7.00	•	n CF Interval O	•	Actual
	N/A						
Examination	n Examination Crew	Time (m) Success % Setup \$ 0 0 0		Call Out, Secondary Damage \$	Unplanned Failure Cost 0	Trout many	
		0 0 0	0	0	U	System	
Protective	Failures Population	MTBF No Prot. S Repair C	ost \$ Double Failure Cos	st \$			
	0 0	0 0 0					

Maintenance Requirements Analysis Detailed Report

ystem Equipm Fu	ent Inction											
	Function Failure								Proposed	Task /		Decision Basis
	Failure Mode	9		Effect	E	SE 0 -	L OC SR S	D - CB FF RI	Correctiv	e Task		MTBF Basis
treet Lighti	ng											
SL 01 00	0 00 Street Lighting	g Control Equipme	nt									
	o provide automatic swit	ching of lighting as	semblies based	on daylight								
le	evels.											
	Lighting not switch	ed when required.										
	47 Contactor noisy due to	internal fault (black bo	red).	customer com	plaints. N	N N - N	N N N	- N N	N.S.M Replac	e Contactor		
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	N/A	0	12.00	0.00	12.00	36,500	1,200	0	0			
Examination	Examination Crew	Time (m) Success	-	Planned Repair	Cost \$ Call Ou	t, Secondary Do	amage \$	Unplanned Failure	Cost		Redundancy	
		0 0	0	0		0		0			System	
Protective	Failures Population 0	MTBF No Pr	ot. S Repair Co 0	est \$ Double	e Failure Cost \$							
	21 Contactor operating coinsulation.	il burnt out due to aged		May cause cir to blow. Light not turn on. C complaints. Po safety and sec impacts where of lights are no operating.	ing will ustomer ossible urity a group	Y Y - N	I N N N	- N Y	N.S.M New d	esigns are no	t include	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	60.00	60.00	7,300	1,200	0	0			
Examination	Examination Crew	Time (m) Success	ss % Setup \$	Planned Repair (Cost \$ Call Ou	t, Secondary Do	amage \$	Unplanned Failure 250,000	Cost		Redundancy System	
Protective	Failures Population 0 0	MTBF No Pr	ot. S Repair Co 0	est \$ Double	e Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System Equipm Fu	nent unction Function Failure Failure Mod	e		Effect		E SE O -	L OC SR S	D - CB FF RI	Proposed Correcti			Decision Basis MTBF Basis
Street Lighti	ing											
SL 01 0	00 00 Street Lighting	g Control Equipme	ent									
T	To provide automatic swit	ching of lighting as	semblies based	on daylight								
le	evels.											
	Lighting not switch	ed when required.										
	22 Contactor operating co based).	il burnt out due to corro	osion (salt	Lighting will on. Customer complaints. I safety and se impacts wher of lights are r operating.	r Possible curity re a group	N Y Y -N	N N N N	- N Y	N.S.M			High failure rates indicate consideration of redesign.
									Replac	ce Contactor		Nth estimate 2% of 1000 in salt effected areas
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	12.00	12.00	608	20	0	0			
Examination	Examination Crew	Time (m) Success 0 0	ss % Setup \$	Planned Repair 0	r Cost \$ Call	Out, Secondary Do	amage\$	Unplanned Failure 250,000	Cost	F	Redundancy System	

Double Failure Cost \$

Population 0

MTBF

0

No Prot. S

0

Repair Cost \$

0

Failures

Protective

Maintenance Requirements Analysis Detailed Report

System	
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	

Equipment

Function

Function Failure

Failure Mode

Proposed Task / Decision Basis

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

19 Contactor operating coil burnt out due to electrical

Replace Contactor

Primary	Operation L	oss Description	Operatonal L	oss \$ Co.	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/P	ublic Injury	250,000	(0.00	20.00	20.00	21,900	1,200	0	0			
Examination	Examinatio	on Crew	Time (m)	Success %	Setup \$	Planned Repair Co 0	ost \$ Call Out	, Secondary Do	amage \$	Unplanned Failure 250,000	Cost	R	edundancy System	
Protective	Failures 0	Population 0	MTBF	No Prot. S	Repair Cost	Double 2	Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System Equipme Fur	nction													
	Function Failure								Propose			Decision Basis		
Failure Mode				Effect E SE O - L OC SR SD - CB FF RD						ve Task		MTBF Basis	MTBF Basis	
Street Lightin	ıg													
SL 01 00	00 Street Lightin	g Control Equipme	nt											
	provide automatic swit	ching of lighting ass	semblies based	on daylight										
	Lighting not switch	ned when required.												
35 Contactor overheated connections due to loose.				Loss of phase to lighting. L typically 1/3 lighting (dep- installed configuration Customer con Possible safe impacts.	oss of of the end on 1). mplaints.	NYY ·	- N Y	-	conne	ine SLP contactions for over a lography (Kio- ations).	rheating using	Part of Kiosk SS M	Itce	
										ce Contactor		CF Interval to be ch	hecked.	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures		•	CF Interval	Optimal	Scheduled	TMP	Actual		
	Minor Injury	25,000	10.00	63.00	73.00	6,000	1,200	1,460	511	18 mth				
Examination	Examination Crew Mains Crew (2)	Time (m) Succes 2 80	s % Setup \$ 100	Planned Repain 300	Cost \$ Call	Out, Secondary 1,500	Damage \$	Unplanned Failure 26,800	Cost	F	Redundancy System			

Failures 0

Protective

Population 0

 $_0^{MTBF}$

No Prot. S

Repair Cost \$

Double Failure Cost \$

Maintenance Requirements Analysis Detailed Report

System Equipme	ent nction											
Tui	Function Failure								Proposed	Task /		Decision Basis
	Failure Mod	e		Effect	E	se o -	L OC SR S	SD - CB FF RD	Corrective	e Task		MTBF Basis
Street Lightin	ng											
SL 01 00	000 Street Lightin	g Control Equipme	nt									
	o provide automatic swit vels.	ching of lighting ass	semblies based	on daylight								
	Lighting not switch	ned when required.										
36 Contactor overheated connections due to over current.				Loss of phase to lighting. L typically 1/3 lighting (dep installed configuration Customer corpossible safe impacts.	ooss of of the end on n).	Y Y - 1	NNNN	I - N Y	N.S.M.			Review of practices involving 'joining circuits' required.
									_	Contactor a ghting load.	nd redistribu	ıte
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000	0.00	67.00	67.00	6,537	1,200	0	0			
Examination	Examination Crew	Time (m) Succes	s % Setup \$	Planned Repair 0	r Cost \$ Call O	ut, Secondary D 0	amage \$	Unplanned Failure 25,000	Cost	F	Redundancy System	

9/1/2004

Population 0

Failures

Protective

 $_{0}^{\mathit{MTBF}}$

Repair Cost \$

Double Failure Cost \$

No Prot. S

0

Maintenance Requirements Analysis Detailed Report

lystem Equipm	nent							
Fu	unction Function Failure Failure Mode	P	Effect	F SF 0 - 1	L OC SR SD - CB FF	Proposed		Decision Basis MTBF Basis
treet Lighti		<u> </u>		E SE O	L OC SK SD CB FF	KD corrective		
SL 01 00	_	g Control Equipment						
	,	ching of lighting assemblies base	d on davlight					
	evels.							
	Lighting not switch	ed when required.						
	48 Contactor slow operation boxed).	on due to internal fault (black	Delays in pickup/release resu customer complain	ılt in	N N N - N I	N N.S.M.		Needs further investigation
						Replac	e Contactor	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail To	otal Failures MTBF	Population CF Interva	l Optimal	Scheduled TMP	Actual
	N/A	0 3.00	0.00	3.00 146,000	1,200 0	0		
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Do	umage \$ Unplanned Fail 0	ure Cost	Redundancy System	
Protective	Failures Population 0 0	MTBF No Prot. S Repair (Cost \$ Double Fails					
	50 PE Cell does not switch type)	off due to age degradation (D2	Wasted energy, shortened globe life Customer complain	e.	N N Y -	Replac	e D2 tpye PE cell	when replacing lamp??? offline Weibull required.
			·			Replac	e PE Cell	Total stores usage of D2 PE cells in Nctle and Chatswood ifor the last year is 3400 units
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail To	otal Failures MTBF	Population CF Interva	l Optimal	Scheduled TMP	Actual
	N/A	0 1,360.00	2,040.00	3,400.00 1,181	11,000 0	0	2 x bulk l	
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Do	umage \$ Unplanned Fail	ure Cost	Redundancy System	
Protective	Failures Population 0	MTBF No Prot. S Repair C	Cost \$ Double Failu	ure Cost \$				

Maintenance Requirements Analysis Detailed Report

System Equipment Functi	ion Function Failure Failure Mode	e		Effect	E	c se o - 1	L OC SR S	SD - CB FF RD	Propose Correcti			Decision Basis MTBF Basis
Street Lighting SL 01 00 00 To property	rovide automatic switc		assemblies based	on daylight								
10	PE Cell does not switch (Nema).	off due to age degrad	lation	Wasted energy shortened glo Customer con	be life.	N Y - N	INNY	-	Replac	ce PE Cell		Align with every second bulk lamp replacement of larger lamp types????? offline Weibull required.
									Replac	ce PE cell		Spot replacement counts only with no bulk changeout. Est PE cell life is 5 years. Total stores usage of Nema PE cells in Nctle and Chatswood ifor the last year is 3000 units
Primary O	peration Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	N/A	0	800.00	2,200.00	3,000.00	2,555	21,000	0	0	2 x bulk l		
Examination 1	Examination Crew	Time (m) Succ	cess % Setup \$	Planned Repair 10	· Cost \$ Call G	Out, Secondary Do O	amage \$	Unplanned Failure (Cost	1	Redundancy System	
	uilures Population 0 0		Prot. S Repair Co.	st \$ Doub	le Failure Cost \$							

9/1/2004 15

Maintenance Requirements Analysis Detailed Report

System					
Equipn	nent				
	unction				
	Function Failure			Proposed	d Task / Decision Basis
	Failure Mod	e	Effect E SE O	- L OC SR SD - CB FF RD Correction	ve Task MTBF Basis
Street Light	ing				
SL 01 (00 00 Street Lightin	g Control Equipment			
	•	ching of lighting assemblies based	on daylight		
ı	evels.				
	Lighting not switch	ned when required.			
	8 PE Cell does not switch (overcurrent).	n off due to contacts welded	Wasted energy, N N Y shortened globe life. Customer complaints.	- N N N N - N Y N.S.M	i.
			-	Replac	ee PE Cell
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failures MTB		Scheduled TMP Actual
·	N/A	0 0.00	10.00 10.00 1,168,00	•	
Examination	Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$ Call Out, Secondar	y Damage \$ Unplanned Failure Cost	D 1 1
Examination	Examination Crew	$0 \qquad 0 \qquad 0$	0 0	y Damage 5 Onplained I dilare Cosi 0	Redundancy System
Protective	Failures Population	MTBF No Prot. S Repair Co			
	0 0		0		
	39 PE Cell does not switch (hail/storm).	a off due to impact damage	Wasted energy, N N Y shortened globe life. Customer complaints.	- N N N N - N N N.S.M	[.
				Replac	ee PE Cell
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failures MTBI	-	Scheduled TMP Actual
-	N/A	0 0.00	50.00 50.00 233,600	32,000 0 0	
T	F	m () G () G ()	N. ID. C. C. C. C. IO. C. I.	y Damage \$ Unplanned Failure Cost	
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Call Out, Secondar 0 0	y Damage \$	Redundancy System
		-			sysiem
Protective	Failures Population 0	MTBF No Prot. S Repair Co	sst \$ Double Failure Cost \$ 0		

Maintenance Requirements Analysis Detailed Report

System Equipn	nent						
	unction						
	Function Failure				Propose	d Task /	Decision Basis
	Failure Mod	le	Effect	E SE O - L OC SI	R SD - CB FF RD Correcti	ive Task	MTBF Basis
Street Lighti	ing						
SL 01 0	00 00 Street Lightin	ng Control Equipment					
T	Γο provide automatic swit	tching of lighting assemblies based	on daylight				
le	evels.						
	Lighting not switch	hed when required.					
	49 PE Cell does not switch (D2 type)	h off due to manfacturing defects	Wasted energy, shortened globe life. Customer complaints.	N N Y - N N N	N - N Y N.S.M	I.	High failure rates not long after installation. Sensitivity to high ambient light?
					Replac	ce PE Cell	Estimate in Nctle & Nth is 25% of PE cells are D2 types. Failures are about 30% of the total uasge 1001 used in 1 yr in Nth, ?? in Nctle
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Fai	ilures MTBF Populat	ion CF Interval Optimal	Scheduled TMP	Actual
	N/A	0.00	1,001.00 1,001.	.00 4,011 11,000	0 0		
Examination	Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$	Call Out, Secondary Damage \$	Unplanned Failure Cost	Redundancy	
		0 0	0	0	0	System	
Protective	Failures Population 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cos 0	st \$			
	6 PE Cell does not switch	h off due to spider web / insects.	Wasted energy, shortened globe life. Customer complaints.	N N Y -N N N	N - N N N.S.M	I.	
					Remo	ve web / insects.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Fai	•		Scheduled TMP	Actual
	N/A	0.00	50.00 50.0	233,600 32,000	0 0		
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Damage \$	Unplanned Failure Cost 0	Redundancy System	
Protective	Failures Population 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cos 0	st \$			

Maintenance Requirements Analysis Detailed Report

System Equipm Fu	nent unction											
	Function Failure								Proposed	l Task /		Decision Basis
	Failure Mode	e		Effect	E	E SE O -	L OC SR S	SD - CB FF RD	Correcti	ve Task		MTBF Basis
Street Lighti	ing											
SL 01 0	00 00 Street Lighting	g Control Equipme	ent									
Т	To provide automatic swit	ching of lighting as	semblies based	l on daylight								
	evels.			• 0								
	Lighting not switch	ed when required.										
	Lighting not switched when required. PE Cell does not switch off due to UV exposure (cell facing north?).			Wasted ener shortened gle Customer co	obe life.	N Y -1	N N N N	- N Y	N.S.M			Manufactured in nth Hemisphere, and box indicates to face cell north. Should be South?
									Refit F	E Cell to face	South.	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	N/A	0	3.00	15.00	18.00	648,889	32,000	0	0			
Examination	Examination Crew	Time (m) Succe	ss % Setup \$	Planned Repai 0	r Cost \$ Call G	Out, Secondary D 0	amage \$	Unplanned Failure 0	Cost	R	Redundancy System	

Double Failure Cost \$

 $_{0}^{MTBF}$

Population 0

Failures

Protective

No Prot. S

Repair Cost \$

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Proposed Task / Decision Basis

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00

Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

5 PE Cell does not switch on due to age degradation.

Lighting will not turn NYYYNNNNN —
on. Customer
complaints. Possible
safety and security
impacts where a group
of lights are not
operating.

Chatswood 200/700 est in 21000 units

Actual

Replace PE Cell

Primary Operation Loss Description Operatonal Loss \$ Cond Fail Funct Fail Total Failures MTBFPopulation CF Interval Optimal Scheduled TMPStaff/Public Injury 250,000 320.00 1,120.00 1,440.00 8.111 32,000 0 2 x bulk l Unplanned Failure Cost Examination Examination Crew Planned Repair Cost \$ Call Out, Secondary Damage \$ Time (m) Success % Setup \$ Redundancy 0 0 250,000 System

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Proposed Task / Decision Basis

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

2 PE Cell does not switch on due to burnout from overcurrent (system design error).

Lighting will not turn N Y Y -N N N N N - N Y N.S.M. on. Customer complaints. Possible safety and security impacts where a group of lights are not operating.

Replace PE Cell and redistribute

load.

Primary Cond Fail Funct Fail Total Failures MTBFCF Interval Optimal Scheduled TMPOperation Loss Description Operatonal Loss \$ Population Actual Staff/Public Injury 250,000 0.00 16.00 16.00 730,000 32,000 0 Call Out, Secondary Damage \$ Unplanned Failure Cost Examination Examination Crew Planned Repair Cost \$ Time (m) Success % Setup \$ Redundancy 0 0 250,000 System Protective No Prot. S Failures Population MTBFRepair Cost \$ Double Failure Cost \$ 0 0 0 0

9/1/2004 20

Maintenance Requirements Analysis Detailed Report

٦.		
٠,	vstem	
,	SICIL	

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

40 PE Cell does not switch on due to contacts operate but open circuit.

Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	0.00	0.00	7,300,000	20,000	0	0			
Examination	Examination Crew	Time (m) Su	ccess % Setup \$	Planned Repair Co.	st \$ Call Ou	t, Secondary Do	amage \$	Unplanned Failure	Cost	Re	edundancy	
	Mains Crew (2)	0	0 0	0		0		250,000			System	
Protective	Failures Population	MTBF No	Prot. S Repair Co	st \$ Double F	Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure
Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

3 PE Cell does not switch on due to electrical surge (lightning / mains clash). .

Primary	Operation L	oss Description	Operatonal L	oss \$ Co.	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Pi	ublic Injury	250,000	(0.00	160.00	160.00	73,000	32,000	0	0			
Examination			Time (m)	Success %	Setup \$	Planned Repair Co 0	ost \$ Call Out,	Secondary Do	amage \$	Unplanned Failure 250,000	Cost	R	edundancy System	
Protective	Failures 0	Population 0	MTBF	No Prot. S	Repair Cost	t \$ Double I	Failure Cost \$							

operating.

Maintenance Requirements Analysis Detailed Report

System Equipme	nt													
	nction													
	Function Failure										Proposed	Task /		Decision Basis
	Failure Mod	e			Effect		E SE O - L OC SR SD -		SD - CB FF RD Corrective Task			MTBF Basis		
Street Lightin	ıg													
SL 01 00	00 Street Lightin	g Control Eq	uipment											
	provide automatic swit	ching of light	ing assen	ıblies based	on daylight									
	Lighting not switch	ed when requ	iired.											
	37 PE Cell does not switch on due to installation error - not rotated fully when replaced.		- not	Wasted energ shortened glo Customer co	be life.	N Y Y	- N	N N N		N.S.M.			this needs a check at time of installation - High rate appears to be associated with BLR contract work. Chatswood figures - based on followup action on bulk lamp replacement Contractors.	
Primary	Operation Loss Description Staff/Public Injury	Operatonal Lo 250,000	oss\$	Cond Fail 0.00	Funct Fail 202.00	Total Failur 202.00	es MT 36,13		Population 20,000	CF Interval 0	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew	Time (m)	Success %	Setup \$	Planned Repair 0	· Cost \$ Ca	ll Out, Second	lary Dame	age \$	Unplanned Failure 250,000	Cost		Redundancy System	

 $_{0}^{\mathit{MTBF}}$

No Prot. S

Repair Cost \$

Double Failure Cost \$

Population 0

Protective

Failures 0

Maintenance Requirements Analysis Detailed Report

System							
Equip							
j	Function Function Failure				Pı	roposed Task /	Decision Basis
	Failure Mode	e	Effect	E SE O - L OC SR S	SD - CB FF RD C	orrective Task	MTBF Basis
Street Ligh	ting						
SL 01	00 00 Street Lighting	g Control Equipment					
	To provide automatic swite	ching of lighting assemblies based	on daylight				
	levels.						
	Lighting not switch	ed when required.					
	4 PE Cell does not switch	on due to UV exposure.	Lighting will not turn on. Customer complaints. Possible safety and security impacts where a group of lights are not operating.	N Y Y -N N N Y	<i>,</i> — Б	Replace PE Cell	
Primary	Operation Loss Description Staff/Public Injury	Operatonal Loss \$ Cond Fail 250,000 48.00	Funct Fail Total Failu 52.00 100.00	•	CF Interval Opt	imal Scheduled TMP 2 x bulk l	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ C	Call Out, Secondary Damage \$	Unplanned Failure Cost 250,000	Redundancy System	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cost	\$			
	9 PE Cell does not switch cell.	on due to vandalism - taped over	Wasted energy, shortened globe life. Customer complaints.	N Y Y -N N N N	1 - N N	N.S.M.	
Primary	Operation Loss Description Staff/Public Injury	Operatonal Loss \$ Cond Fail 250,000 0.00	Funct Fail Total Failu 0.00 0.00	ures MTBF Population 0 0	CF Interval Opt	imal Scheduled TMP	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ C	Call Out, Secondary Damage \$	Unplanned Failure Cost 250,000	Redundancy System	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cost 0	\$			

Maintenance Requirements Analysis Detailed Report

System							
Equipr							
F	Function Function Failure				Propose	d Task /	Decision Basis
	Failure Mode	e	Effect	E SE O - L OC SR	SD - CB FF RD Correcti	ve Task	MTBF Basis
Street Light	ting						
SL 01 (00 00 Street Lighting	g Control Equipment					
,	To provide automatic swite	ching of lighting assemblies based	on daylight				
1	levels.						
	Lighting not switch	ed when required.					
	16 PE Cell false operation	due to age degradation (drift).	Cell operates earlier or later than expected. Lighting not available when required or operate when not required.	N Y Y - N N N	Y - Replac	ce PE Cell	
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 8.00	Funct Fail Total Fail	•	n CF Interval Optimal 0 0	Scheduled TMP 2 x bulk l	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$	Call Out, Secondary Damage \$	Unplanned Failure Cost 25,000	Redundancy System	
Protective	Failures Population 0	MTBF No Prot. S Repair Co 0 0 0	st \$ Double Failure Cost 0	r \$			
	30 PE Cell false operation	due to birds attack.	Fails when it next rains. Cell does not operate as expected.	N N Y -N N N	n — n n N.S.M	í.	
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 8.00	Funct Fail Total Fail 160.00 168.00	•	n CF Interval Optimal 0 0	Scheduled TMP	Actual
Examination	Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$ 0	Call Out, Secondary Damage \$ 0	Unplanned Failure Cost 25,000	Redundancy System	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co 0 0 0	st \$ Double Failure Cost 0	<i>*</i> \$			

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

1 PE Cell false operation due to external light source. Light turns off when N Y Y - N N N N - N Y N.S.M.

still required.

Customer complaints.

Possible safety and security impacts where a group of lights are not operating.

Realign PE Cell or fit cover/shield.

Primary	Operation L	oss Description	Operatonal L	oss \$ Con	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Mine	or Injury	25,000	(0.00	61.00	61.00	191,475	32,000	0	0			
Examination	Examinatio	n Crew	Time (m)	Success %	Setup \$	Planned Repair Co	ost \$ Call Ou	t, Secondary D	amage \$	Unplanned Failure	Cost	R	edundancy	
			0	0	0	0		0		25,000			System	
Protective	Failures 0	Population 0	MTBF 0	No Prot. S	Repair Cost 0	Double .	Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System	
	Equipment
	Eumoti

Function

Function Failure

Effect Failure Mode

Proposed Task / E SE O - L OC SR SD - CB FF RD

Corrective Task

N.S.M.

Decision Basis MTBF Basis

Actual

Street Lighting

SL 01 00 00

Failures

Population

MTBF

0

Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

PE Cell base broken due to excessive installation force. (GEC Astra Types)

Works initially, but fails after any vibration causes internal base to drop. Local reduced lighting level. Customer complaints. Possible safety/security

impacts.

Repair Cost \$

0

Y N N -N N N N -

Replace PE cell base unit.

Primary Operation Loss Description Operatonal Loss \$ Cond Fail Funct Fail Total Failures MTBFPopulation CF Interval Optimal Scheduled TMP25,000 10.00 100.00 110.00 20,000 0 0 Minor Injury 66,364 Unplanned Failure Cost Planned Repair Cost \$ Examination Examination Crew Time (m) Success % Setup \$ Call Out, Secondary Damage \$ Redundancy 0 0 25,000 System Protective No Prot. S

Double Failure Cost \$

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

29 PE Cell base cracked insulation due to UV exposure. Corrosion of N Y Y - N N N Y - Replace PE Cell

conductor. Possible electric shock hazard. Possible short circuit may burn down conductor.

Primary	,	oss Description ublic Injury	Operatonal Lo		nd Fail 2.00	Funct Fail 37.00	Total Failures 39.00	MTBF 299,487	Population 32,000	CF Interval	Optimal 0	Scheduled 2 x bulk l	TMP	Actual
Examination	Examinatio	on Crew	Time (m)	Success % 0	Setup \$	Planned Repair Co. 0	st \$ Call Ou	, Secondary De	amage\$	Unplanned Failure 250,000	Cost	1	Redundancy System	
Protective	Failures 0	Population 0	MTBF	No Prot. S	Repair Cost	\$ Double F	Cailure Cost \$							

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

46 SL Circuit Fuses blown due to numerous random external events (trees, storms etc).

> est 300 in Nctle/Hunter, Est 6000 in Nth

> > 29

Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail T	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000	0.00	6,300.00	6,300.00	87	1,500	0	0			
Examination	Examination Crew	Time (m) Succe	ess % Setup \$	Planned Repair Cost \$	\$ Call Out, S	Secondary Da	mage \$	Unplanned Failure	Cost	Re	edundancy	
		0 0	0	0		0		25,000			System	
Protective	Failures Population 0	MTBF No P		est \$ Double Fail	ilure Cost \$							

Maintenance Requirements Analysis Detailed Report

System Equipme	ant											
	nction											
ru	Function Failure								Proposed	d Task /		Decision Basis
	Failure Mod	e		Effect	I	E SE O - 1	OC SR SE	O - CB FF RD	Correctiv	ve Task		MTBF Basis
Street Lightin	ng											
SL 01 00	00 Street Lightin	g Control Equipm	ent									
To	o provide automatic swit	ching of lighting a	ssemblies based	l on daylight								
	vels.	0 0 0		• 0								
	Lighting not switch	ed when required	•									
												D 11 31
	43 SL Wiring (excluding t saddles missing.	nains) conduit strikes i	mains due to	Local fuse b group of ligh operational. complaints. security imp	nting not Customer Safety and	N Y -N	N N N	- N Y	N.S.M			Problems with fastenings falling out as sapwood decays. Old poles have hard timber which are almost impossible to drive longer nails. Needs a longer stronger self driving fastener
									Replac	e missing sac	ldles / clouts.	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000	55.00	30.00	85.00	253,353	59,000	0	0			
Examination	Examination Crew	Time (m) Succ	ress % Setup \$	Planned Repai	r Cost \$ Call C	Out, Secondary Do	mage\$ U	Unplanned Failure	Cost	1	Redundancy	

25,000

System

0

No Prot. S

0

Repair Cost \$

Double Failure Cost \$

 $_{0}^{\mathit{MTBF}}$

Population 0

Protective

Failures

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Proposed Task / Decision Basis

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

 $N \quad Y \quad Y \quad -N \quad N \quad N \quad N \quad - \quad N \quad Y$

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

41 SL Wiring (excluding mains) corroded connection to aluminium cable due to electrolytic action.

Lighting may not operate. Lighting standard may become energised.

Repair to new standard configuration upon failure.

31

N.S.M.

Primary Operation Loss Description Operatonal Loss \$ Cond Fail Funct Fail Total Failures MTBFCF Interval Optimal Scheduled TMPPopulation Actual 25,000 20.00 50.00 70.00 Minor Injury 307,643 59,000 Examination Examination Crew $Time\ (m)$ Success % Setup \$ Planned Repair Cost \$ Call Out, Secondary Damage \$ Unplanned Failure Cost Redundancy 0 0 25,000 System Protective MTBFNo Prot. S Population Repair Cost \$ Failures Double Failure Cost \$

Maintenance Requirements Analysis Detailed Report

System Equipmen	nt										
Fund	ction Function Failure Failure Mode	e	Effect	E	SE 0 - 1	L OC SR S	SD - CB FF RD	Proposeo			Decision Basis MTBF Basis
Street Lighting	g										
SL 01 00 (To) leve	provide automatic swit	g Control Equipment ching of lighting assembl	ies based on daylight								
ieve	Lighting not switch	ned when required.									
2	23 SL Wiring (excluding n UV exposure.	nains) cracked insulation due to	Corrosion of conductor. Po electric shock Possible shor may burn dov conductor.	ossible c hazard. t circuit	Y Y - N	Y	-		ne wiring insu		Perform when making any corrective action on pole/ lighting circuit
											Est Nctle 8000 Standard and 32000 Overhead., Nth 6500 Standard and 52500 Overhead.
Primary	Operation Loss Description	Operatonal Loss \$ Con-	d Fail Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000 40	.00 229.00	269.00	115,335	85,000	0	0	Lamp re		
Examination	Examination Crew	Time (m) Success % 0 0	Setup \$ Planned Repair 0 0	Cost \$ Call Ou	t, Secondary Da 0	ımage \$	Unplanned Failure 250,000	Cost	R	Redundancy System	
Protective	Failures Population 0 0	MTBF No Prot. S 0 0	Repair Cost \$ Doub.	le Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System Equipme	ent											
	nction											
	Function Failure								Proposed	l Task /		Decision Basis
	Failure Mode	e		Effect	E	se o -	L OC SR S	D - CB FF RI	Correcti	ve Task		MTBF Basis
Street Lightin	ng											
SL 01 00	0 00 Street Lighting	g Control Equipme	nt									
	o provide automatic swite vels.	ching of lighting ass	semblies based	on daylight								
	Lighting not switch	ed when required.										
	45 SL Wiring (excluding n insulation within hollow	mains) damaged due to b w spun concrete poles.	virds strip	Local light do operate. Cust complaints. Safety/securi impacts.	omer	Y Y -1	N N N N	- N Y	N.S.M			Needs more permanent solution to seal entry point into pole.
									Fill un	used access p		
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	52.00	52.00	2,106	300	0	0			
Examination	Examination Crew	Time (m) Succes	ss % Setup \$	Planned Repair	Cost \$ Call O	ıt, Secondary D	Damage \$	Unplanned Failure	Cost	F	Redundancy	
		0 0	0	0		0		250,000			System	

Double Failure Cost \$

 $_{0}^{MTBF}$

No Prot. S

Population 0

Protective

Failures 0 Repair Cost \$

Maintenance Requirements Analysis Detailed Report

Sv	ste	m

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

 $N \quad Y \quad Y \quad -N \quad N \quad N \quad N \quad - \quad N \quad Y$

Street Lighting

SL 01 00 00 Street Lighting Control Equipment

To provide automatic switching of lighting assemblies based on daylight levels.

Lighting not switched when required.

26 SL Wiring (excluding mains) damaged due to excavations / pegs /stakes.

Light turns on or off when not expected. Customer complaints. Possible safety and security impacts where a group of lights are not operating. Advertise the "Dial Before You

Dig service"

Primary	Operation L	oss Description	Operatonal L	oss \$ Co	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/P	ublic Injury	250,000	•	0.00	32.00	32.00	159,688	14,000	0	0			
Examination	Examinatio	on Crew	Time (m)	Success % 0	Setup \$	Planned Repair Co 0	ost \$ Call Ou	t, Secondary Do	amage\$	Unplanned Failure 250,000	Cost	R	edundancy System	
Protective	Failures 0	Population 0	MTBF 0	No Prot. S	Repair Cost	t \$ Double F	Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

stem							
Equip							
J	Function Function Failure					Proposed Task /	Decision Basis
	Failure Mod	e	Effect	E SE O - L OC SR	SD - CB FF RD	Corrective Task	MTBF Basis
eet Ligh	ating						
SL 01	=	g Control Equipment					
	=	ching of lighting assemblies based	on daylight				
	levels.						
	Lighting not switch	ed when required.					
	27 SL Wiring (excluding r lighting column struck.	mains) damaged due to MVA -	Wiring insulation damaged. Fault on lighting circuit even after the lighting standard is replaced.	N Y Y - N N N	N – N	N.S.M.	Repaired after notification of accident and inspection of pole/lighting standard.
imary	Operation Loss Description Staff/Public Injury	Operatonal Loss \$ Cond Fail 250,000 0.00	Funct Fail Total Failure 50.00 50.00	es MTBF Population 102,200 14,000		Optimal Scheduled TMP	Actual
amination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Cal	ll Out, Secondary Damage \$ 0	Unplanned Failure Co 250,000	st Redundancy System	
rotective	Failures Population 0	MTBF No Prot. S Repair Co.	ost \$ Double Failure Cost \$				
	42 SL Wiring (excluding r corrosion of steel condu	nains) damaged insulation due to nit.	Local fuse blows, and group of lighting not operational. Customer complaints. Safety and security impacts	N Y Y -N Y	-	See Overhead Line MRA	Covered by line examination. See Overhead Line MRA
			security impacts				No Steel conduit in Newcastle
imary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 10.00	Funct Fail Total Failure 30.00 40.00	es MTBF Population 273,750 30,000		Optimal Scheduled TMP	Actual
xamination		Time (m) Success % Setup \$ 0 0 0		ll Out, Secondary Damage \$	Unplanned Failure Co 25,000		
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co.	st \$ Double Failure Cost \$				

Maintenance Requirements Analysis Detailed Report

System Equipmen	t												
Func	tion												
	Function Failure									Proposed	Task /		Decision Basis
	Failure Mod	e			Effect	F	E SE O -	L OC SR S	SD - CB FF RD	Correctiv	e Task		MTBF Basis
Street Lighting	;												
SL 01 00 0	0 Street Lightin	g Control Eq	uipment										
To _l leve	provide automatic swit ls.	ching of light	ing asseml	blies based	on daylight								
	Lighting not switch	ed when requ	iired.										
4	4 SL Wiring (excluding r (Dee Why area) due to	, ,		ns	Local light doc operate. Light assembly make become active neutral broken Customer com Public safety/s impacts.	head e if . plaints.	Y Y - N	NNNN	1 - N Y	N.S.M.		nt standard	
											riring to curre uminairre is r		
Primary	Operation Loss Description	Operatonal La	oss \$ Co	ond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	-	50.00	200.00	250.00	14,600	10,000	0	0			
Examination	Examination Crew	Time (m)	Success % 0	Setup \$ 0	Planned Repair (0	Cost \$ Call C	Out, Secondary D 0	amage \$	Unplanned Failure (250,000	Cost	F	Redundancy System	

9/1/2004

 $_{0}^{MTBF}$

Population 0

Protective

Failures

No Prot. S

0

Repair Cost \$

Double Failure Cost \$

Maintenance Requirements Analysis Detailed Report

ystem								
Equip	ment							
]	Function Function Failure					Proposed Task /		Decision Basis
	Function Failure Failure Mode	e	Effect	E SE O - L	OC SR SD - CB FF RD	•		MTBF Basis
treet Ligh	ting	-			00 01 1 10			
SL 01	_	g Control Equipment						
	σ,	ching of lighting assemblies ba	sed on daylight					
	levels.	••••••••••••••••••••••••••••••••••••••	200 011 uuj 11g110					
	Lighting not switch	ed when required.						
	24 SL Wiring (excluding n strike.	nains) service broken due to bird	Local light does not operate. Customer complaints. Safety/security impacts.	N Y Y -N	N N N -	N.S.M.		
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 0.00	Funct Fail Tot. 11.00	al Failures MTBF 11.00 1,758,636	Population CF Interval 53,000 0	Optimal Scheduled	! TMP	Actual
Examination	Examination Crew	Time (m) Success % Setu 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Dan 0	nage \$ Unplanned Failure 25,000	Cost	Redundancy System	
Protective	Failures Population 0 0		ir Cost \$ Double Failur 0	re Cost \$				
	25 SL Wiring (excluding n wiring - fixing clout wo	nains) service broken due to loose rks loose.	Local light does not operate. Customer complaints. Safety/security impacts.	N Y Y -N	N N N - N Y	N.S.M.		New design required for fasteners. Self drilling galvanised metal(?) screws? See code 43
						TBA		
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail		al Failures MTBF	Population CF Interval	Optimal Scheduled	! TMP	Actual
	N/A	0 3,655.00	490.00	4,145.00 7,485	85,000 0	0		
Examination	Examination Crew	Time (m) Success % Setu 0 0 0	p \$ Planned Repair Cost \$ 0	Call Out, Secondary Dan 0	age \$ Unplanned Failure 0	Cost	Redundancy System	
Protective	Failures Population 0 0		ir Cost \$ Double Failur 0 0	re Cost \$				

Maintenance Requirements Analysis Detailed Report

ystem Equipm Fu	nent unction Function Failure								Proposed	Task /		Decision Basis
	Failure Mode	e		Effect	E	SE O - I	OC SR S	SD - CB FF RD	Correctiv	e Task		MTBF Basis
reet Lighti	ing											
SL 01 00	0 00 Street Lighting	g Control Equipme	ent									
	To provide automatic swit	ching of lighting as	semblies based	on daylight								
le	evels.											
	Lighting not switch	ed when required.										
	28 SL Wiring (excluding n to installation / repair e		hasing due	Lighting may noperate. Lighting standard may be energised.	ng	Y Y - N	N N N	- N Y	N.S.M.			
									_	ommissionin	to be tested g/repairing	est 6 Nth, 12 N'ctle
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Staff/Public Injury	250,000	0.00	18.00	18.00	2,007,500	99,000	0	0			
Examination	Examination Crew	Time (m) Succe 0 0	ss % Setup \$	Planned Repair C 0	ost \$ Call O	ut, Secondary Da 0	mage \$	Unplanned Failure 250,000	Cost	1	Redundancy System	
Protective	Failures Population 0 0	MTBF No Pr		ot \$ Double	Failure Cost \$							
	51 Time clock (1 unit only analysis) maloperation	· •	rther	Unit to be repla		Y Y - N	N N N	- N Y	N.S.M.			
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail 0.00	Funct Fail	Total Failures 0.00	MTBF 0	Population 0	CF Interval	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew	Time (m) Succe	ss % Setup \$	Planned Repair C 0	ost \$ Call O	ut, Secondary Da 0	mage \$	Unplanned Failure 0	Cost	1	Redundancy System	
Protective	Failures Population 0	MTBF No Pr		st \$ Double	Failure Cost \$							

Maintenance Requirements Analysis Detailed Report

System Equipme	ont												
	nction												
Tu	Function Failure								Proposed	ł Task /		Decision Basis	
	Failure Mod	e		Effect	E	se o - i	L OC SR SD	- CB FF RD	Correctiv	ve Task		MTBF Basis	
Street Lightin	ng												
SL 01 00	0 00 Street Lightin	g Control Equipm	ent										
SL 02 00	=												
	treet lighting availability												
5.	Availability of light												
	11 validating of light	ing is less than ye	, 00										
	21 Choke (separate unit)	damaged due to door to	choke box	Allows water	into N	N Y - N	N N N	- N N	N.S.M.	•			
	not secured.			choke box, da									
				components.	-								
				working. Re									
				local light lev									
				possible safet issues.	y/security								
				issues.					Pa-sac	ure choke bo	v door		
D'	On and in Land Description	O	Con I Foll	E E. 1	T-1-1 F-11	MTDE	D I	CE Internal				A . co I	
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual	
			2.00	91.00	93.00	80,065	20,400	0	0				
Examination	Examination Crew	(/	ess % Setup \$	Planned Repair	Cost \$ Call O	ut, Secondary Do	ımage \$ U	Inplanned Failure	Cost		Redundancy		
		0 0	0	0		0		0			Equipment		

Population 0

MTBF

0

No Prot. S

0

Repair Cost \$

Double Failure Cost \$

Failures

Protective

Maintenance Requirements Analysis Detailed Report

System								
System Equipm	nent							
Fu	unction							
	Function Failure Failure Mode		Effect			Proposed Task / Corrective Task		Decision Basis MTBF Basis
G T . 1.4			Litet	E SE O - L OC SR S	SD - CR FF RD	Corrective Task		MIDI DUNG
Street Lighti	0							
SL 02 0	-							
S	Street lighting availability							
	Availability of light	ing is less than 95%.						
	20 Choke (separate unit) d open - vehicle clips pole	amaged due to door to choke box	Allows water into choke box, damaging components. Lamp not working. Reduced local light level with possible safety/security issues.	N N Y -N N N N	N - N N	N.S.M.		
						Re-secure choke bo	ox door.	
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 0.00	Funct Fail Total Failures 30.00 30.00	MTBF Population 248,200 20,400		Optimal Scheduled 0	TMP	Actual
Examination	Examination Crew	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	Planned Repair Cost \$ Call	Out, Secondary Damage \$	Unplanned Failure Co. 25,000	st	Redundancy Equipment	
Protective	Failures Population 0	MTBF No Prot. S Repair Co.	st \$ Double Failure Cost \$ 0					
	19 Choke (separate unit) fularge vehicle vibration/i	ise dislodged from carrier due to mpacts.	Local light does not operate. Customer complaints. Safety/security impacts.	N N Y -N N N N	N - N N	N.S.M.		
						Re-secure choke bo	ox door.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail 0.00	Funct Fail Total Failures 74.00 74.00	MTBF Population 111,966 22,700		Optimal Scheduled 0	TMP	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Call	Out, Secondary Damage \$	Unplanned Failure Co	est	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co.	st \$ Double Failure Cost \$ 0					

Maintenance Requirements Analysis Detailed Report

System							
Equipm	nent						
Fu	unction						
	Function Failure		T-00		Propose		Decision Basis
	Failure Mod	e	Effect	E SE O - L OC SR	SD - CB FF RD Correcti	ve Task	MTBF Basis
Street Lighti	ing						
SL 02 0	00 00 Lamp Assemb	olies					
S	Street lighting availability	to be at least 95%.					
	Availability of light	ting is less than 95%.					
	12 Choke (separate unit) s	shorted due to water damage.	Lamp not working. Reduced local light level with possible safety/security issues.	N N Y -N N N	N - N N N.S.M	ī.	
					Replac	ce choke box.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failure	es MTBF Populatio	n CF Interval Optimal	Scheduled TMP	Actual
	Minor Injury	25,000 0.00	37.00 37.00	223,932 22,700	0 0		
Examination	Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$ Cal.	ll Out, Secondary Damage \$	Unplanned Failure Cost	Redundancy	
		0 0	0	0	25,000	Equipment	
Protective	Failures Population 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cost \$ 0				
	23 Choke / integral contro secured.	ol gear access door open due to not	Increased aging of internal components. Customer complaints.	N N Y -N N N	n – n n N.S.M	ſ.	
			•		Re-sec	cure choke box door.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failure	es MTBF Populatio	n CF Interval Optimal	Scheduled TMP	Actual
	N/A	0 172.00	24.00 196.00	22,347 12,000	0 0		
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Cal.	ll Out, Secondary Damage \$ 0	Unplanned Failure Cost 0	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	Double Failure Cost \$				

Maintenance Requirements Analysis Detailed Report

System								
Equipm	nent unction							
Fu	Function Failure					Proposed Task /		Decision Basis
	Failure Mode	e	Effect	E SE O - L OC	SR SD - CB FF RD	Corrective Task		MTBF Basis
Street Lighti	ing							
SL 02 0	00 00 Lamp Assemb	lies						
S	Street lighting availability	to be at least 95%.						
	Availability of light	ing is less than 95%.						
	22 Choke / integral control - excessive connections	l gear shorted due to design error in terminals.	Overheating of terminals. Wiring fails and lamp does not work.	N N Y -N N	N N - N Y	N.S.M.		Reduction in excess wire counts in terminals to reduce failure rate.
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 0.00	Funct Fail Total Fail.	•	ulation CF Interval	Optimal Scheduled 0	TMP	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Damage \$ 0	Unplanned Failure Co 25,000	ost	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cost 0	\$				
	11 Choke / integral control damage.	l gear shorted due to water	Lamp not working. Reduced local light level with possible safety/security issues.	N N Y -N N	N N - N N	N.S.M.		
						Replace luminaire		
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Fail	ures MTBF Pope	ulation CF Interval	Optimal Scheduled	TMP	Actual
	Minor Injury	25,000 4.00	141.00 145.00	0 30,207 12,0	000 0	0		
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$	Call Out, Secondary Damage \$ 0	Unplanned Failure Co 25,000	ost	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	ost \$ Double Failure Cost 0	\$				

Maintenance Requirements Analysis Detailed Report

ystem Equipm							
Fu	unction Function Failure Failure Mode	e	Effect	E SE O - L	OC SR SD - CB FF RD	Proposed Task / Corrective Task	Decision Basis MTBF Basis
treet Lighti	ing						
SL 02 0	00 00 Lamp Assembl	lies					
S	Street lighting availability Availability of light	to be at least 95%. ing is less than 95%.					
	18 Internal wiring shorted	due to heat damages insulation.	Lamp not working. Reduced local light level with possible safety/security issues. Head may become live	N N Y - N	N N N - N N	N.S.M.	
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 121.00		Failures MTBF 2.00 12,807	Population CF Interval 12,000 0	Optimal Scheduled	TMP Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Dam 0	age \$ Unplanned Failure (25,000	Cost	Redundancy Equipment
Protective	Failures Population 0	MTBF No Prot. S Repair Co	ost \$ Double Failure C	Cost \$			
	28 Lamp no light output d	ue to age degradation.	Local light does not operate. Customer complaints. Safety/security impacts.	N Y Y -N	N N Y -	Replace Lamp	See Offline Weibull analysis
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail 0.00		Failures MTBF .00 0	Population CF Interval 0 0	Optimal Scheduled 0 30 mth b	TMP Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$	Call Out, Secondary Dam 0	age \$ Unplanned Failure 0	Cost	Redundancy Equipment
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	ost \$ Double Failure C	Cost \$			

Maintenance Requirements Analysis Detailed Report

System Equipme	ent											
	nction											
ru	Function Failure								Proposed	l Task /		Decision Basis
	Failure Mod	e		Effect	E	SE O -	L OC SR S	SD - CB FF RE	Correctiv	ve Task		MTBF Basis
Street Lightin	ng											
SL 02 00	0 00 Lamp Assemb	olies										
	treet lighting availability											
5.	Availability of light											
	Availability of light	ing is less than 75 /	u.									
	26 Lamp no light output d	lue to electrical surge.		Local light doperate. Cus	ioes not	N Y -1	N N N	- N N	N.S.M			
				complaints.								
				Safety/secur	ity							
				impacts.								
									Replac	e Lamp		
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000	0.00	1,800.00	1,800.00	20,075	99,000	0	0			
Examination	Examination Crew	Time (m) Succes	ss % Setup \$	Planned Repai	r Cost \$ Call O	ut, Secondary D	amage \$	Unplanned Failure	Cost		Redundancy	
		0 0	0	0		0		25,000			Equipment	

Double Failure Cost \$

0

Failures 0

Protective

 $_{0}^{\mathit{MTBF}}$

No Prot. S

0

Population 0

Repair Cost \$

Maintenance Requirements Analysis Detailed Report

System											
Equipm											
rı	unction Function Failure							Proposed T	ask /		Decision Basis
	Failure Mode	e	Effect	E 5	SE O - L	OC SR S	D - CB FF RD	Corrective '	Task		MTBF Basis
Street Lighti	ing										
SL 02 0	0 00 Lamp Assemb	lies									
S	Street lighting availability	to be at least 95%.									
	Availability of light	ting is less than 95%.									
	30 Lamp no light output d	ue to installation / repair error.	Local light does operate. Custon complaints. Safety/security impacts.		Y - N	N N N	-	N.S.M.			Needs a timely post work quality check?
								Replace 1	Lamp		Problem evident in areas where bulk lamp replacement occurs. BLR Cycles 18mth/30mth.
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fa 25,000 0.00	il Funct Fail 1,000.00	Total Failures 1,000.00	MTBF 21,535	Population 59,000	CF Interval 0	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew		tup \$ Planned Repair Co	ost \$ Call Out, S	Secondary Dan 0	nage\$	Unplanned Failure 0 25,000	Cost		Redundancy Equipment	
Protective	Failures Population 0	MTBF No Prot. S Re	pair Cost \$ Double .	Failure Cost \$							
	27 Lamp no light output d	ue to manufacturing error.	Short life requireplacements in lamp life.	-	Y - N	N N N	-	N.S.M.			Check at time of installation
								Replace 1	Lamp		Batch related problems?
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fa 25,000 0.00	il Funct Fail 256.00	Total Failures 256.00	MTBF 141,152	Population 99,000	CF Interval 0	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew	, ,	tup \$ Planned Repair Co	ost \$ Call Out, S	Secondary Dan 0	nage \$	Unplanned Failure (25,000	Cost		Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Re.	pair Cost \$ Double . 0	Failure Cost \$							

9/1/2004

45

Maintenance Requirements Analysis Detailed Report

System Equipm	nent nection									
	Function Failure						Proposed	l Task /		Decision Basis
	Failure Mod	le	Effect	E SE C	O - L OC SR S	D - CB FF RD	Correctiv	ve Task		MTBF Basis
Street Lighti	ng									
SL 02 00	0 00 Lamp Assemb	blies								
S	treet lighting availability	to be at least 95%.								
		ting is less than 95%.								
	25 Lamp no light output o	due to random failure.	Local light does no operate. Custome complaints. Safety/security impacts.		-N N N Y	-	Replac	e Lamp		See Offline Weibull Replacement.
										Only applicable to Nth as this area has bulk lamp replacement.
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail	Total Failures M	TBF Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000 0.00	500.00	500.00 43,0	70 59,000	0	0	30 mth b		
Examination	Examination Crew	Time (m) Success % Setu 0 0 0	o \$ Planned Repair Cost 0	*\$ Call Out, Second 0	dary Damage \$	Unplanned Failure 25,000	Cost	i	Redundancy Equipment	
Protective	Failures Population 0		ir Cost \$ Double Fa	ilure Cost \$						

Maintenance Requirements Analysis Detailed Report

System Equipm	ant						
	unction Function Failure Failure Mode	,	Effect	E SE O - L OC SR S		Proposed Task / Corrective Task	Decision Basis MTBF Basis
Street Lighti				E SE O E OC SK	OZ CB II KD		
SL 02 00	9	lies					
	treet lighting availability						
	Availability of light						
	14 Lamp holder broken du	e to age/heat degradation.	Unable to replace lamps and replacement of unit required. Reduced local light level with possible safety/security issues.	N Y Y -N N N Y	· -	Replace Lamp holder (when required) in conjunction with BLR.	
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 340.00	Funct Fail Total Failu 200.00 540.00	1		Optimal Scheduled TMP 0 Lamp re	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Damage \$ 0	Unplanned Failure Cost 25,000	t Redundancy Equipment	
Protective	Failures Population 0	MTBF No Prot. S Repair Co	st \$ Double Failure Cost	\$			
	32 Luminairre broken due	to MVA - lighting column struck.	Fitting may fall or be left hanging after impact. Repair as callout action.	Y N Y -N N N N	N - N	N.S.M.	
						Repair/Replace Upon notificati	on
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail 0.00	Funct Fail Total Fail 0.00 0.00	•		Optimal Scheduled TMP 0	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Damage \$ 0	Unplanned Failure Cost 0	t Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co	st \$ Double Failure Cost	\$			

Maintenance Requirements Analysis Detailed Report

System_												
Equipm	nent unction											
rı	unction Function Failure								Proposed '	Γask /		Decision Basis
	Failure Mode			Effect	E S	е о - г	OC SR S	D - CB FF RD	Corrective	Task		MTBF Basis
Street Lighti	ing											
SL 02 0	_	lies										
	Street lighting availability		6.									
	Availability of light											
	8 Luminairre broken due	to vandalism.		Lamp not working. Reduced local light level with possible safety/security issu		N - N	N N Y	-	N.S.M.			
									Repair/I	Replace Up	on notification	1
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail 264.00	Funct Fail To 228.00	tal Failures 492.00	MTBF 73,445	Population 99,000	CF Interval 0	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew		cess % Setup \$	Planned Repair Cost \$	Call Out, S	econdary Dam 0	age \$	Unplanned Failure	Cost		Redundancy Equipment	
Protective	Failures Population 0 0		Prot. S Repair Cos	t \$ Double Failu	re Cost \$							
	9 Luminairre not working	g due to age degradat	ion.	Lamp not working. Reduced local light level with possible safety/security issu		_		-				
												Generic. Needs to be split into types.
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail		tal Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Minor Injury	25,000	200.00	1,460.00	1,660.00	21,768	99,000	0	0			
Examination	Examination Crew	(.)	cess % Setup \$ 0 0	Planned Repair Cost \$ 0	Call Out, S	econdary Dam 0	age \$	Unplanned Failure 25,000	Cost		Redundancy Equipment	
Protective	Failures Population 0 0		Prot. S Repair Cos	t \$ Double Failu	tre Cost \$							

Maintenance Requirements Analysis Detailed Report

ystem Equipn												
Fı	unction Function Failure Failure Mode	e	E	Effect	E	SE O - L	OC SR S	SD - CB FF RD	Proposed 7			Decision Basis MTBF Basis
treet Lighti	ing											
SL 02 0	00 00 Lamp Assemb	lies										
S	Street lighting availability Availability of light	to be at least 95%. ing is less than 95%.										
	10 Luminairre not workin missing/misaligned/dan	0		Luminairre fills v water and shorts lamps or ballast. of lighting with possible safety/se issues.	out Loss	-		-				
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail 301.00	Funct Fail 605.00	Total Failures 906.00	MTBF 39,884	Population 99,000	CF Interval	Optimal	Scheduled	TMP	Actual
Examination	Examination Crew	Time (m) Success 9	% Setup \$ 0	Planned Repair Cost 0	\$ Call Ou	t, Secondary Dar 0	nage \$	Unplanned Failure C	Cost		Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot.	S Repair Cost	\$ Double Fa	ilure Cost \$							
	33 Luminairre not workin	g due to local fuse blown.		Local light does no operate. Custome complaints. Safety/security impacts.		-		-	N.S.M.			
				impueus:								9000 nth, 1400 Nctle.
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ 25,000	Cond Fail 0.00	Funct Fail 10,400.00	Total Failures 10,400.00	MTBF 3,510	Population 100,000	CF Interval	Optimal 0	Scheduled	TMP	Actual
Examination	Examination Crew	Time (m) Success 9	% Setup \$ 0	Planned Repair Cost	\$ Call Ou	t, Secondary Dan 0	nage \$	Unplanned Failure C 25,000	Cost		Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot.	S Repair Cost	\$ Double Fa	ilure Cost \$							

Maintenance Requirements Analysis Detailed Report

ystem Equipi	ment Function						
Г	Function Failure				Proposed	Task /	Decision Basis
	Failure Mod	e	Effect	E SE O - L OC SR S	D - CB FF RD Corrective	e Task	MTBF Basis
treet Light	ting						
SL 02	00 00 Lamp Assemb	olies					
:	Street lighting availability	to be at least 95%.					
	Availability of light	ting is less than 95%.					
	13 Luminairre not workin deformed.	ng due to PE Cell base contacts	Lamp remains illuminated after PE cell re-inserted. Wasted energy, shortened globe life. Customer complaints.	N Y Y -N N N N	– n N.S.M.		
Primary Examination	Operation Loss Description Staff/Public Injury Examination Crew	Operatonal Loss \$ Cond Fail 250,000 0.00 Time (m) Success % Setup \$	Funct Fail Total Failu 40.00 40.00 Planned Repair Cost \$ Co	res MTBF Population 182,500 20,000 all Out, Secondary Damage \$	CF Interval Optimal 0 0 Unplanned Failure Cost	Scheduled TMP Redundancy	Actual
		0 0 0	0	0	250,000	Equipment	
Protective	Failures Population 0	MTBF No Prot. S Repair Cos	t \$ Double Failure Cost \$	\$			
	15 Starter broken due to a	nge/heat degradation.	Lamp not working. Reduced local light level with possible safety/security issues.	N N Y -N N N N	– N N N.S.M.		Should starters be replace in conjunction with BLR?
D.:	On anything Lange Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failus	MTDE Dletter	CE Internal Order	Scheduled TMP	Nth only
Primary	Operation Loss Description Staff/Public Injury	250,000 150.00	200.00 350.00	•	CF Interval Optimal 0 0	Scheduled TWF	Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Co	all Out, Secondary Damage \$	Unplanned Failure Cost 250,000	Redundancy Equipment	
Protective	Failures Population 0	MTBF No Prot. S Repair Cos	t \$ Double Failure Cost \$	\$			

Maintenance Requirements Analysis Detailed Report

System	4						
Equipm Fu	ınction						
	Function Failure					Proposed Task /	Decision Basis
	Failure Mode	e	Effect	E SE O -	L OC SR SD - CB FF RD	Corrective Task	MTBF Basis
Street Lightin	ng						
SL 02 00	0 00 Lamp Assemb	olies					
St	treet lighting availability	to be at least 95%.					
	Availability of light	ting is less than 95%.					
	29 Starter maloperation de	ue to installation / repair error.	Lamp not wo Reduced loca level with po safety/securi	al light ssible	N N N N - N N	N.S.M.	Needs a timely post work quality check
Primary	Operation Loss Description	Operatonal Loss \$ Cond	Fail Funct Fail	Total Failures MTBF	Population CF Interval	Optimal Scheduled TMP	Actual
		200.0	0 800.00	1,000.00 7,300	20,000 0	0	
Examination	Examination Crew	Time (m) Success %	Setup \$ Planned Repair	r Cost \$ Call Out, Secondary D	amage \$ Unplanned Failure	Cost Redundancy	
		0 0	0 0	0	0	Equipment	
Protective	Failures Population 0 0	MTBF No Prot. S 0 0	Repair Cost \$ Doub	ole Failure Cost \$ 0			

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Proposed Task / Decision Basis

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

Street Lighting

SL 02 00 00 Lamp Assemblies

The average lumen output to be not less than 70% of the original design output.

Average lumen output is less that 70% of original design output.

24 Lamp low output due to age degradation.

Reduced local light output. Possible customer complaints.

N N Y - N N Y -

Replace Lamp

See Offline Weibull

analysis.

All lamps. data does not include BLR. See Street lighting database extracts for individual lamp data.

Primary	Operation Loss Description	Operatonal Loss \$	Cona Faii	Funct Faii	1 otat Fattures	MIBF	Роришатоп	CF Interval	Орптаі	Scneauiea	IMP
	Minor Injury	25,000	100.00	300.00	400.00	90,338	99,000	0	0	30 mth b	
Examination	Examination Crew	Time (m) Succ	cess % Setup \$	Planned Repair Cos 0	st \$ Call Out,	, Secondary Do	amage \$	Unplanned Failure 25,000	Cost		Redundancy Equipment

re Cost \$

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD

Corrective Task

MTBF Basis

Street Lighting

SL 02 00 00 Lamp Assemblies

The average lumen output to be not less than 70% of the original design output.

Average lumen output is less that 70% of original design output.

4 Light Bracket misaligned due to coach screw missing. Wind allows arm to N N Y - N N N N - N N.S.M.

rotate, light now no longer focused on roadway. Possible safety/security issues and customer complaints.

Primary	Operation L	oss Description	Operatonal L	oss \$ Co	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP	Actual
	Mine	or Injury	25,000		4.00	10.00	14.00	1,173,214	45,000	0	0			
Examination	Examination	on Crew	Time (m)	Success %	Setup \$	Planned Repair Co	est \$ Call Ou	ıt, Secondary Do	ımage \$	Unplanned Failure	Cost	Re	edundancy	
			0	0	0	0		0		25,000		H	Equipment	
Protective	Failures 0	Population 0	MTBF	No Prot. S	Repair Cos	t \$ Double F	Failure Cost \$							

9/1/2004 53

Maintenance Requirements Analysis Detailed Report

System Equipn						
Fi	unction Function Failure				Proposed Task /	Decision Basis
	Failure Mode	ę	Effect F SF	E O - L OC SR SD - CB FF R	_	MTBF Basis
Street Light			1 51	e de sk = e di i		
_	0	P				
SL 02 0	=					
		to be not less than 70% of the orig	ginal design			
· ·	output.	put is less that 70% of original des	ian output			
	Average fullien out	put is less that 70% of original des	ւցո օսւրսւ.			
	34 Light Bracket misaligne	ed due to fasteners/bolts loose.	Light now no longer N Y focused on roadway. Possible safety/security issues and customer complaints.	Y - N N N N - N	N.S.M.	
						Nctle/Maitland use bolts. Majority are missing nuts
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 800.00	Funct Fail Total Failures 12.00 812.00	MTBF Population CF Interval 17,980 40,000 0	Optimal Scheduled TM. 0	P Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	•	condary Damage \$ Unplanned Failur 0 25,000	re Cost Redundar Equipme	•
Protective	Failures Population 0	MTBF No Prot. S Repair Co.	Double Failure Cost \$ 0			
	3 Light Bracket misaligne	ed due to moved for high load.	Light now no longer Y Y focused on roadway. Possible safety/security issues and customer complaints.	Y - N N N N - Y	N.S.M.	Ensure work procedure restores and secures bracket after moving for high load passage.
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ Cond Fail 25,000 0.00	Funct Fail Total Failures 1.00 1.00 14,	MTBF Population CF Interval ,600,000 40,000 0	Optimal Scheduled TM.	P Actual
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	•	ocondary Damage \$ Unplanned Failur 0 25,000	re Cost Redundar Equipme	•
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co.	rt \$ Double Failure Cost \$			

Maintenance Requirements Analysis Detailed Report

N N Y -N N N N - N Y

System			
Equipment			
Function			
Function Failure			Proposed Task /
Failure Mode	Effect	E SE O - L OC SR SD - CB FF RD	Corrective Task

Street Lighting

SL 02 00 00 Lamp Assemblies

17

Failures

Population

The average lumen output to be not less than 70% of the original design output.

Average lumen output is less that 70% of original design output.

Luminairre cracked casing (2x20W plastic body) due to	Hangs by wiring,
UV degradation.	lighting not over road.
	Lighting may drop,
	with injury/property
	damage.

0

Repair Cost \$

0

Replace if any repair work

Decision Basis MTBF Basis

No more plastic body

units to be purchased

required.

N.S.M.

Primary Operation Loss Description Operatonal Loss \$ Cond Fail Funct Fail Total Failures MTBFPopulation CF Interval Optimal Scheduled TMPActual 0.00 0.00 0.00 0 Examination Examination Crew Success % Planned Repair Cost \$ Call Out, Secondary Damage \$ Unplanned Failure Cost Time (m) Setup \$ Redundancy Equipment Protective MTBFNo Prot. S

Double Failure Cost \$

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Effect

E SE O - L OC SR SD - CB FF RD Corrective Task

MTBF Basis

Street Lighting

SL 02 00 00 Lamp Assemblies

The average lumen output to be not less than 70% of the original design output.

Average lumen output is less that 70% of original design output.

16 Luminairre cracked casing (B2229 type) fatigued due to vibration.

Casing drops to ground. Injury to public and/or property.

N Y Y -N Y -

Examine Slyvania B2229/B3000

fitting for cracks.

Replace Luminairre

Perform one off in initial inspection to prioritise replacement.

Removed from north. Est pop for Nctle/Hunter 1200. 0.3% found cracked

in sample examination.
Guess of CF is < 30 mths

Actual

Primary	Operation Loss Description	Operatonal Lo	ss \$ Cor	nd Fail	Funct Fail	Total Failures	MTBF	Population	CF Interval	Optimal	Scheduled	TMP
	Minor Injury	25,000	0	0.00	24.00	24.00	18,250	1,200	365	405		
Examination	Examination Crew	Time (m)	Success %	Setup \$	Planned Repair C	Cost \$ Call O	ıt, Secondary De	amage \$	Unplanned Failure	Cost		Redundancy
	Mains Crew (2)	Ι	93	100	700		500		26,200			Equipment

Maintenance Requirements Analysis Detailed Report

	oment Function								
	Function Failure						Proposed Task /		Decision Basis
	Failure Mode	e	Effect	E	SE O - L O	C SR SD - CB FF R	D Corrective Task		MTBF Basis
Street Ligh	nting								
	2 00 00 Lamp Assemb	lies							
	The average lumen output		% of the original design						
	output.		8 8						
	Average lumen out	put is less that 70% of	original design output.						
	6 Luminairre obstructed	due to trees.	Creation of areas. Re lighting - safety/sec and custo complaint	duced possible urity issues mer	-	-			Covered by task in Overhead Line analysis - Vegetation Mgmt programme
Primary	Operation Loss Description	Operatonal Loss \$	Cond Fail Funct Fail 0.00 30.00	Total Failures 30.00		opulation CF Interval	Optimal Schedulea	TMP	Actual
Examination	n Examination Crew	Time (m) Success % 0 0	6 Setup \$ Planned Re 0 0	pair Cost \$ Call Ou	t, Secondary Damage 0	y \$ Unplanned Failur 0	e Cost	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot.	S Repair Cost \$ 1	Oouble Failure Cost \$					
	5 Luminairre rotated due (wind/vibration).	e to fastening screw lossene	focused o Possible s	n roadway. afety/security I customer	Y Y - N N	N N -	N.S.M.		
Primary	Operation Loss Description Minor Injury	Operatonal Loss \$ 25,000	Cond Fail Funct Fail 6.00 100.00	Total Failures 106.00		opulation CF Interval 9,000 0	Optimal Schedulea	TMP	Actual
Examination	n Examination Crew	Time (m) Success 9	6 Setup \$ Planned Re 0 0	pair Cost \$ Call Ou	t, Secondary Damage 0	Unplanned Failur 25,000	e Cost	Redundancy Equipment	
Protective	Failures Population 0 0	MTBF No Prot.	S Repair Cost \$ 1.	Oouble Failure Cost \$					

Maintenance Requirements Analysis Detailed Report

System							
Equip							
F	Function Function Failure					Proposed Task /	Decision Basis
	Failure Mode	e	Effect	E SE O - L	OC SR SD - CB FF RD	Corrective Task	MTBF Basis
Street Light	ting						
SL 02	00 00 Lamp Assemb	lies					
,	The average lumen output	to be not less than 70% of the or	iginal design				
•	output.						
	Average lumen out	put is less that 70% of original d	esign output.				
	7 Twin Flourescent Lamps low output due to one tube failed.		Reduced local light output. Possible customer complaints.	N Y Y - N	N N N - Y	Examine Street Lighting adequate light level	for Patrol Task
						Repair/Replace based on preference.	n local Gov Total failure estimate based on Weibull parameter calculations for population Beta=2.3, neta=2070
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total	Failures MTBF	Population CF Interval	Optimal Scheduled T	TMP Actual
	Minor Injury	25,000 100.00	1,764.00	5.00 1,825,000	25,000 0	767 365 Patr	
Examination	Examination Crew Mains Crew (2)	Time (m) Success % Setup \$ 1 99 2	Planned Repair Cost \$ 300	Call Out, Secondary Dam 0	age \$ Unplanned Failure C 25,300	1104000	ndancy pment
Protective	Failures Population 1,864 25,000	MTBF No Prot. S Repair C 4,895 0 300	Cost \$ Double Failure 25,600	Cost \$			
	31 Visors hanging down do	ue to various.	Lamp not protected.	N N N - N	N N N - N N	N.S.M.	
Primary	Operation Loss Description N/A	Operatonal Loss \$ Cond Fail 0 100.00		Failures MTBF 20.00 69,490	Population CF Interval 99,000 0	Optimal Scheduled 1	TMP Actual
T				,	,		
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ 0	Call Out, Secondary Dam 0	age \$ Unplanned Failure C 0	1104000	pment
Protective	Failures Population 0	MTBF No Prot. S Repair C	Cost \$ Double Failure 0	Cost \$			

Maintenance Requirements Analysis Detailed Report

System Equipm	nent				
	unction				
	Function Failure			Proposed Task	
	Failure Mode	e	Effect E SE O - L	OC SR SD - CB FF RD Corrective Tas	k MTBF Basis
Street Lighti	ing				
SL 02 0	00 00 Lamp Assemb	lies			
	•	to be not less than 70% of the orig	ginal design		
0	output.				
	Average lumen out	put is less that 70% of original des	sign output.		
	2 Visors obstructed due t	o dirt/dust buildup.	Reduced local light N Y Y - Y output. Possible customer complaints.	- Clean visor.	(in conjunction with other work)
			•	Replace vis	or if aged.
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failures MTBF	Population CF Interval Optimal Sc	heduled TMP Actual
	Minor Injury	25,000 10.00	686.00 696.00 51,918	99,000 0 Lan	np re
Examination	Examination Crew	Time (m) Success % Setup \$	Planned Repair Cost \$ Call Out, Secondary Damaş	ge \$ Unplanned Failure Cost	Redundancy
		0 0	0	25,000	Equipment
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co. 0 0 0	ost \$ Double Failure Cost \$		
	1 Visors obstructed due t	o insects.	Reduced local light N Y Y - Y output. Possible customer complaints.	- Clean visor.	
Primary	Operation Loss Description	Operatonal Loss \$ Cond Fail	Funct Fail Total Failures MTBF	Population CF Interval Optimal Sc	heduled TMP Actual
	Minor Injury	25,000 2.00	696.00 698.00 51,769	99,000 0	
Examination	Examination Crew	Time (m) Success % Setup \$ 0 0 0	Planned Repair Cost \$ Call Out, Secondary Damag 0 0	ge \$ Unplanned Failure Cost 25,000	Redundancy Equipment
Protective	Failures Population 0 0	MTBF No Prot. S Repair Co.	sst \$ Double Failure Cost \$		

Maintenance Requirements Analysis Detailed Report

System

Equipment

Function

Function Failure

Failure Mode

Figure Mode

Street Lighting

SL 02 00 00 Lamp Assemblies