

TEMPLATE EXPLANATION



This template must be used by the TNSP to report service performance information for the previous calendar year.

Yellow worksheets ('**Inputs - Performance**' and '**Inputs - Exclusions**') are for inputs, including performance and exclusion information. The TNSP only needs to enter data on these worksheets.

Purple worksheets '**S1**' to '**S6**' are the s-factor results based on the performance inputs from the 'Inputs - Performance' worksheet.

Blue worksheet '**Revenue Calculation**' quantifies the appropriate revenue to be applied to the s-factor results adjusted for CPI.

Red worksheet '**Outcomes**' shows the total performance, s-factor and financial incentive results based on the TNSP's performance in 'Inputs-Performance' and 'Revenue Calculation' worksheets.

Orange worksheet '**Exclusion Definitions**' are the defined exclusions for each TNSP which should form the basis of exclusion requests under 'Inputs-Exclusions' worksheet.

TransGrid - Proposed exclusions

| CIRCUIT AVAILABILITY | Event proposed for exclusion | Description of the event and its impact on the network and performance | Cause of the event | Start date | Start time | End date | End time | Circuits affected | Reactive plant or transformer | Quantitative impact | Reasons for exclusion request | Further references |
|---|------------------------------|--|---|------------------------------|----------------------------|------------------------------------|--------------------------------|---|---|--|---|--|
| Name of any circuit availability parameters | Name of the event | Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted. | A description of the cause of the event | Start date and time of event | End date and time of event | Name of circuits or plant affected | Name of any equipment affected | Impact of exclusion event on availability sub-parameter | Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event. | A TNSP may provide further details of an exclusion event. TNSP to provide reference. | | |
| | 101709 | Line 96Y is part Transgrid and Ausgrid owned. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 4/01/12 | 06:46:00 | 4/01/12 | 0/01/00 | 96Y | | -0.0002227% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 101706 | TL M1 isolated for work on direct connected SHL's Murray PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 10/01/12 | 06:31:00 | 11/01/12 | 0/01/00 | M1 | | -0.0018779% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 101977 | TL 97L isolated for work on direct connected SHL's Jindabyne PS 132kV installation. | Verbal request from Snowy Hydro. | 10/01/12 | 11:13:00 | 10/01/12 | 0/01/00 | 97L | | -0.0002554% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | Package38460 RFA 2012-200 |
| | 102206 | SHL advise work being carried out on No.2 Pump at Jindabyne Pumping Station and Intertrip inadvertently initiated on 97L Guthega protection. | Intertrip sent by SHL installation. | 19/01/12 | 08:00:00 | 19/01/12 | 0/01/00 | 97L | | -0.0001296% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-F-0046 |
| | 102313 | TL M11 isolated for work on direct connected SHL's Murray PS Units 11-12 330kV installation. | Request from Snowy Hydro. | 25/01/12 | 06:28:00 | 25/01/12 | 0/01/00 | M11 | | -0.0003245% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 100362 | Line 963 is part TransGrid and Ausgrid owned. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 5/02/12 | 09:10:00 | 5/02/12 | 0/01/00 | 963 | | -0.0002112% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 102956 | TL 97L isolated for work on direct connected SHL's Jindabyne PS 132kV installation. | Request from Snowy Hydro. | 8/02/12 | 06:39:00 | 8/02/12 | 0/01/00 | 97L | | -0.0004311% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 102988 | TL L3 isolated for work on direct connected SHL's Lower Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 10/02/12 | 13:01:00 | 13/02/12 | 0/01/00 | L3 | | -0.0039268% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 101708 | TL U3 isolated for work on direct connected SHL's Upper Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 11/02/12 | 07:27:00 | 11/02/12 | 0/01/00 | U3 | | -0.0004445% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 103159 | TL 97L isolated for work on direct connected SHL's Jindabyne PS 132kV installation. | Request from Snowy Hydro. | 13/02/12 | 12:09:00 | 13/02/12 | 0/01/00 | 97L | | -0.0001123% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 103929 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 25/02/12 | 05:19:00 | 26/02/12 | 0/01/00 | U1 | | -0.0020613% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 103931 | TL U3 isolated for work on direct connected SHL's Upper Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 25/02/12 | 05:44:00 | 27/02/12 | 0/01/00 | U3 | | -0.0034045% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 104477 | TL L1 isolated for work on direct connected SHL's Lower Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 2/03/12 | 12:24:00 | 3/03/12 | 0/01/00 | L1 | | -0.0013153% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105696 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 14/03/12 | 05:44:00 | 15/03/12 | 0/01/00 | U1 | | -0.0018683% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105777 | Line 96Y is part Transgrid and Ausgrid owned. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 17/03/12 | 05:15:00 | 17/03/12 | 0/01/00 | 96Y | | -0.0003197% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105881 | Black start test at Murray | Request from Snowy Hydro. | 17/03/12 | 07:47:00 | 17/03/12 | 0/01/00 | 97L | | -0.0002727% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105888 | Black start test at Murray | Request from Snowy Hydro. | 17/03/12 | 08:45:00 | 17/03/12 | 0/01/00 | M1 | | -0.0001882% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 106748 | Black start test at Murray | Request from Snowy Hydro. | 17/03/12 | 08:45:00 | 17/03/12 | 0/01/00 | 96G | | -0.0001882% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105861 | Black start test at Murray | Request from Snowy Hydro. | 18/03/12 | 06:41:00 | 18/03/12 | 0/01/00 | M3 | | -0.0004071% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 105952 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 21/03/12 | 05:01:00 | 22/03/12 | 0/01/00 | U1 | | -0.0015822% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 106142 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 31/03/12 | 04:57:00 | 1/04/12 | 0/01/00 | U1 | | -0.0020997% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 106143 | TL U5 isolated for work on direct connected SHL's Upper Tumut PS Units 5-6 330kV installation. | Request from Snowy Hydro. | 1/04/12 | 09:47:00 | 5/05/12 | 0/01/00 | U5 | | -0.0472731% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 106821 | Blackstart Test of Colongra & Vales Point | Request from Delta Electricity | 13/04/12 | 10:19:00 | 13/04/12 | 0/01/00 | 23 | | -0.0005837% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107606 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 21/04/12 | 06:03:00 | 21/04/12 | 0/01/00 | U1 | | -0.0006701% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107681 | TransGrid received an intertrip initiated from SHL's Lower Tumut PS Units 5-6 330kV installation. SML then advised it wished the installation be kept isolated to carry out investigation work | Intertrip sent by SHL installation. | 24/04/12 | 03:32:00 | 26/04/12 | 0/01/00 | L5 | | -0.0026911% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107855 | Black start test at Murray | Request from Snowy Hydro. | 28/04/12 | 07:04:00 | 28/04/12 | 0/01/00 | M1 | | -0.0003293% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107884 | Black start test at Murray | Request from Snowy Hydro. | 28/04/12 | 07:04:00 | 28/04/12 | 0/01/00 | M7 | | -0.0003552% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107260 | Black start test at Murray | Request from Snowy Hydro. | 28/04/12 | 07:04:00 | 28/04/12 | 0/01/00 | M13 | | -0.0003552% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-F-0228 |
| | 107857 | Black start test at Murray | Request from Snowy Hydro. | 28/04/12 | 09:16:00 | 28/04/12 | 0/01/00 | 97L | | -0.0002055% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107980 | Black start test at Murray | Request from Snowy Hydro. | 28/04/12 | 09:16:00 | 28/04/12 | 0/01/00 | 97G | | -0.0002055% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | 107968 | TL L1 isolated for work on direct connected SHL's Lower Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 5/05/12 | 07:32:00 | 8/05/12 | 0/01/00 | L1 | | -0.0043982% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |

| | | | | | | | | | | | | |
|--------|--|---------------------------|--|-------------------------------------|----------|----------|----------|-------------|---|-------------|---|--|
| S1 | Transmission line availability | 108032 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 19/05/12 | 06:07:00 | 20/05/12 | 0/01/00 | U1 | -0.0017464% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 108036 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 26/05/12 | 06:23:00 | 28/05/12 | 0/01/00 | U1 | -0.0033901% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 110227 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 2/06/12 | 07:29:00 | 3/06/12 | 0/01/00 | U1 | -0.0017320% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111106 | Guthega substation 132kV Busbars 1 & 2 isolated for CVT synchronising checks by SHL. Transgrid staff required to isolate at Guthega 132kV S/S. This required that TL 979 Guthega - Munyang be isolated. | Request from Snowy Hydro. | 12/06/12 | 15:24:00 | 12/06/12 | 0/01/00 | 979 | -0.0001162% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111331 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 16/06/12 | 06:58:00 | 17/06/12 | 0/01/00 | U1 | -0.0015266% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111622 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 23/06/12 | 06:41:00 | 24/06/12 | 0/01/00 | U1 | -0.0018155% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111091 | TL U3 isolated for work on direct connected SHL's Upper Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 24/06/12 | 07:10:00 | 24/06/12 | 0/01/00 | U3 | -0.0004052% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111374 | Line 932 is part Transgrid and Endeavour Energy owned. Line was isolated & earthed for work by Endeavour Energy. | Request from Endeavour Energy. | 26/06/12 | 10:03:00 | 26/06/12 | 0/01/00 | 932 | -0.0004704% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111598 | TL U5 isolated for work on direct connected SHL's Upper Tumut PS Units 5-6 330kV installation. | Request from Snowy Hydro. | 27/06/12 | 07:33:00 | 27/06/12 | 0/01/00 | U5 | -0.0005377% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111056 | Line 96F is part Transgrid and Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 30/06/12 | 06:19:00 | 30/06/12 | 0/01/00 | 96F | -0.0003802% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 112031 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 7/07/12 | 07:39:00 | 7/07/12 | 0/01/00 | U1 | -0.0003130% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 113035 | Advised by SHL that an earth fault caused by a fault in the recorder connected to the 11kV earth fault protection at Jindabyne sent an intertrip signal to TransGrid at Guthega. Recorder disconnected and line returned to service. | Intertrip sent by SHL installation. | 11/07/12 | 16:21:00 | 11/07/12 | 0/01/00 | 97L | -0.0000509% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 113189 | Advised by SHL that an earth fault caused by a fault in the recorder connected to the 11kV earth fault protection at Jindabyne sent an intertrip signal to TransGrid at Guthega. Recorder disconnected and line returned to service. | Intertrip sent by SHL installation. | 11/07/12 | 17:14:00 | 11/07/12 | 0/01/00 | 97L | -0.0000605% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 112332 | Line 96P is part Transgrid and Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 14/07/12 | 06:39:00 | 14/07/12 | 0/01/00 | 96P | -0.0003264% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 113188 | Line 939 is part Transgrid and Endeavour Energy owned. Line was isolated & earthed for work by Endeavour Energy. | Request from Endeavour Energy. | 26/07/12 | 07:55:00 | 26/07/12 | 0/01/00 | 939 | -0.0006961% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 112742 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 26/07/12 | 20:05:00 | 29/07/12 | 0/01/00 | U1 | -0.0039085% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 112333 | Line 96F is part Transgrid and Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 28/07/12 | 06:31:00 | 28/07/12 | 0/01/00 | 96F | -0.0003034% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-F-0295 |
| | | 114405 | Guthega substation 132kV Busbars 1 & 2 isolated for protection checks by SHL. Transgrid staff required to isolate at Guthega 132kV S/S. This required that TL 979 Guthega - Munyang be isolated. | Request from Snowy Hydro. | 31/07/12 | 08:39:00 | 31/07/12 | 0/01/00 | 979 | -0.0006673% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-F-0303 |
| | | 114406 | Guthega substation 132kV Busbars 1 & 2 isolated for protection checks by SHL. Transgrid staff required to isolate at Guthega 132kV S/S. This required that TL 97L Guthega - Jindabyne be isolated. | Request from Snowy Hydro. | 31/07/12 | 08:39:00 | 31/07/12 | 0/01/00 | 97L | -0.0006673% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| | | 111706 | TL M11 isolated for work on direct connected SHL's Murray PS Units 11-12 330kV installation. | Request from Snowy Hydro. | 4/08/12 | 07:14:00 | 4/08/12 | 0/01/00 | M11 | -0.0006404% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 114335 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 4/08/12 | 07:45:00 | 6/08/12 | 0/01/00 | U1 | -0.0032826% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | | | |
| 114950 | TL M1 isolated for work on direct connected SHL's Murray PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 13/08/12 | 08:00:00 | 23/08/12 | 0/01/00 | M1 | -0.0143438% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | | | |

| | | | | | | | | | | | |
|--------|--|--|----------|----------|----------|---------|-----|--|-------------|---|--|
| 116358 | TL M7 isolated for work on direct connected SHL's Murray PS Units 7-8 330kV installation. | Request from Snowy Hydro. | 25/08/12 | 07:59:00 | 26/08/12 | 0/01/00 | M7 | | -0.0018655% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 116086 | Line 2M is Transgrid owned and is adjacent to Ausgrid owned line 957 which was being worked on. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 31/08/12 | 08:02:00 | 31/08/12 | 0/01/00 | 2M | | -0.0004848% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 116087 | Line 2M is Transgrid owned and is adjacent to Ausgrid owned line 957 which was being worked on. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 1/09/12 | 07:58:00 | 1/09/12 | 0/01/00 | 2M | | -0.0004455% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 116290 | Line 96F is part Transgrid and Ausgrid owned. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 3/09/12 | 07:13:00 | 3/09/12 | 0/01/00 | 96F | | -0.0005501% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 117120 | Guthega substation 132kV Busbars 1 & 2 isolated for protection checks by SHL. Transgrid staff required to isolate at Guthega 132kV S/S. This required that TL 97L Guthega - Jindabyne be isolated. | Request from Snowy Hydro. | 10/09/12 | 08:30:00 | 10/09/12 | 0/01/00 | 97L | | -0.0006404% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 117119 | TL L3 isolated for work on direct connected SHL's Lower Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 14/09/12 | 07:08:00 | 18/09/12 | 0/01/00 | L3 | | -0.0060544% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118120 | Units 7-8 CCP intertrip received by TransGrid, Units 7-8 trip relay operated. SHL advised, cause of trip over temperature on generator transformer | Intertrip sent by SHL installation. Repair period extended by SHL. | 15/09/12 | 15:54:00 | 14/11/12 | 0/01/00 | M7 | | -0.0828494% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118199 | The tee from Line 947 Orange North T Wellington T Burrendong is Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 18/09/12 | 08:33:00 | 18/09/12 | 0/01/00 | 947 | | -0.0000336% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 106440 | Line 963 is part Transgrid and Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 19/09/12 | 06:46:00 | 19/09/12 | 0/01/00 | 963 | | -0.0006164% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118375 | The tee from Line 947 Orange North T Wellington T Burrendong is Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 20/09/12 | 08:54:00 | 20/09/12 | 0/01/00 | 947 | | -0.0000442% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118119 | TL L3 isolated for work on direct connected SHL's Lower Tumut PS Units 3-4 330kV installation. | Request from Snowy Hydro. | 20/09/12 | 14:35:00 | 21/09/12 | 0/01/00 | L3 | | -0.0015803% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 117830 | Line 963 is part Transgrid and Essential Energy owned. Line was isolated & earthed for work by Essential Energy. | Request from Essential Energy. | 21/09/12 | 09:48:00 | 21/09/12 | 0/01/00 | 963 | | -0.0001517% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-F-0379 |
| 117365 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 22/09/12 | 07:06:00 | 23/09/12 | 0/01/00 | U1 | | -0.0016744% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118694 | TL L5 isolated for work on direct connected SHL's Lower Tumut PS Units 5-7 330kV installation. | Request from Snowy Hydro. | 5/10/12 | 07:42:00 | 9/10/12 | 0/01/00 | L5 | | -0.0059276% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 118326 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 6/10/12 | 07:19:00 | 7/10/12 | 0/01/00 | U1 | | -0.0019384% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119697 | No.1 Transformer failed explosively at Hume Power Station. 995 Hume - Albury 132kV TL taken out of service at Albury to allow Fire Brigade access at Hume Power Station and repair to equipment. | Request from Eraring Energy. Period extended by need for access to repair. | 14/10/12 | 15:13:00 | 20/12/12 | 0/01/00 | 995 | | -0.0928008% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119804 | TL M5 isolated for work on direct connected SHL's Murray PS Units 5-6 330kV installation. | Request from Snowy Hydro. | 20/10/12 | 06:07:00 | 21/10/12 | 0/01/00 | M5 | | -0.0018885% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119773 | Line 96F is part Transgrid and Ausgrid owned. Line was isolated & earthed for work by Ausgrid. | Request from Ausgrid. | 20/10/12 | 06:42:00 | 20/10/12 | 0/01/00 | 96F | | -0.0005588% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119979 | TL M11 isolated for work on direct connected SHL's Murray PS Units 9-10 330kV installation. | Request from Snowy Hydro. | 21/10/12 | 07:39:00 | 21/10/12 | 0/01/00 | M5 | | -0.0002477% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119980 | TL M5 isolated for work on direct connected SHL's Murray PS Units 5-6 330kV installation. | Request from Snowy Hydro. | 21/10/12 | 07:39:00 | 21/10/12 | 0/01/00 | M9 | | -0.0002477% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 119462 | TL U1 isolated for work on direct connected SHL's Upper Tumut PS Units 1-2 330kV installation. | Request from Snowy Hydro. | 27/10/12 | 06:04:00 | 28/10/12 | 0/01/00 | U1 | | -0.0018415% | Exclusion 1.2 - 3rd Party Outage Caused by customer. | Transgrid Forced & Emergency Outage Report 2012-E-0027 |
| 120377 | TL M9 isolated for work on direct connected SHL's Murray PS Units 9-10 330kV installation. | Request from Snowy Hydro. | 1/11/12 | 06:37:00 | 2/11/12 | 0/01/00 | M9 | | -0.0018568% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 120978 | TL M5 isolated for work on direct connected SHL's Murray PS Units 5-6 330kV installation. | Request from Snowy Hydro. | 2/11/12 | 06:06:00 | 2/11/12 | 0/01/00 | M5 | | -0.0003408% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |
| 120979 | TL M9 isolated for work on direct connected SHL's Murray PS Units 9-10 330kV installation. | Request from Snowy Hydro. | 2/11/12 | 06:06:00 | 2/11/12 | 0/01/00 | M9 | | -0.0003408% | Exclusion 1.2 - 3rd Party Outage Requested by customer. | |

| | | | | | | | | | | | | | | |
|----|-----------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|
| S3 | Reactive plant availability | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |

| LOSS OF SUPPLY EVENT FREQUENCY | Event proposed for exclusion | Description of the event and its impact on the network and performance | Cause of the event | Start date | Start time | End date | End time | Circuits affected | Maximum system demand | Demand shed and time | Quantitative impact | Reasons for exclusion request | Further references | |
|---------------------------------------|---|--|--|------------------------------------|------------|----------------------------|----------|------------------------------------|--|--|--|--|---|---|
| Name of any loss of supply parameters | Name of the event | Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted. | A description of the cause of the event | Start date and time of event | Start time | End date and time of event | End time | Name of circuits or plant affected | The max system demand that occurred up until the time of the event | The (MW) demand shed and the duration it was shed for. | Impact of exclusion event on LOS Parameter | Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event | A TNSP may provide further details of an exclusion event. TNSP to provide reference. | |
| S4 | Loss of supply event frequency >0.05 system minutes | 110115 | At Tuggerah 330/132kV S/S on the 27th May 2012 at 11:27hrs No.1 Transformer tripped due to intermittent AC voltage on the DC supply. No.2 Transformer was out of service due to a previous trip and Ausgrid had opened their feeder No.97E Charmhaven - Munmorah at Charmhaven in spite of TransGrid's advice that they reconsider. Consequentially supply was lost to 110,000 Ausgrid Central Coast customers. Supply to most customers was restored 9 minutes later at 1135hrs when Ausgrid's feeder was closed, then the remaining load was restored 9 minutes later. | Other event on third party system. | 27/05/12 | 11:27:00 | 27/05/12 | 15:31:00 | Tx No.1 Tuggerah | 12,121 | 4:04 | 18.13MW for 0.13hrs = 16MWh as shown on load graphs | Exclusion 4.3 - Any outages shown to be caused by a fault or other event on a 'third party system'-e.g. intertrip signal, generator outage, customer installation | Documents 110115 - AEMO report on Tuggerah trip and 110115 - Additional notes on Tuggerah trip. |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| S5 | Loss of supply event frequency >0.25 system minutes | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |

| AVERAGE OUTAGE DURATION | Event proposed for exclusion | Description of the event and its impact on the network and performance | Cause of the event | Start date | Start time | End date | End time | Circuits affected | Quantitative impact | Capped impact (if applicable) | Reasons for exclusion request | Further references | |
|--|------------------------------|--|---|--|------------|----------------------------|----------|------------------------------------|--|---|--|--|--|
| Name of any average outage duration parameters | Name of the event | Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted. | A description of the cause of the event | Start date and time of event | Start time | End date and time of event | End time | Name of circuits or plant affected | Impact of exclusion event on AOD Parameter | Impact of capped exclusion event on AOD parameter | Full details of the reason for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event | A TNSP may provide further details of an exclusion event. TNSP to provide reference. | |
| | | 102206 | SHL advise work being carried out on No.2 Pump at Jindabyne Pumping Station and Intertrip inadvertently initiated on 97L Guthega protection. | Intertrip sent by SHL installation. | 19/01/12 | 08:00:00 | 19/01/12 | 10:15:00 | 97L | 2:15 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-F-0046 |
| | | 107681 | TransGrid received an intertrip initiated from SHL's Lower Tumut PS Units 5-6 330kV installation. SML then advised it wished the installation be kept isolated to carry out investigation work | Intertrip sent by SHL installation. | 24/04/12 | 03:32:00 | 26/04/12 | 02:15:00 | L5 | 46:43 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-F-0228 |
| | | 113035 | Advised by SHL that an earth fault caused by a fault in the recorder connected to the 11kV earth fault protection at Jindabyne sent an intertrip signal to TransGrid at Guthega. Recorder disconnected and Line returned to service | Intertrip sent by SHL installation. | 11/07/12 | 16:21:00 | 11/07/12 | 17:14:00 | 97L | 0:53 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-F-0295 |
| | | 113189 | Advised by SHL that an earth fault caused by a fault in the recorder connected to the 11kV earth fault protection at Jindabyne sent an intertrip signal to TransGrid at Guthega. Recorder disconnected and Line returned to service | Intertrip sent by SHL installation. | 11/07/12 | 17:14:00 | 11/07/12 | 18:17:00 | 97L | 1:03 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-F-0303 |
| | | 118120 | Units 7-8 CCP intertrip received by TransGrid, Units 7-8 trip relay operated. SHL advised, cause of trip over temperature on generator transformer. | Intertrip sent by SHL installation. Repair period extended by SHL. | 15/09/12 | 15:54:00 | 14/11/12 | 14:07:00 | M7 | 1438:13 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-F-0379 |

| | | | | | | | | | | | | | | |
|----|-------------------------|--------|--|---|----------|----------|-----------|----------|-----------------------|--|-----------|---------|--|--|
| S6 | Average outage duration | 119697 | No.1 Transformer failed explosively at Hume Power Station. 995 Hume - Albury 132kV TL taken out of service at Albury to allow Fire Brigade access at Hume Power Station and repair to equipment | Request from Eraring Energy. Period extended by need for access to repair. | 14/10/12 | 15:13:00 | 20/12/12 | 18:11:00 | 995 | | 1610:58 | Nil | Exclusion 6.4 - 3rd Party Outage Caused by customer equipment. | Transgrid Forced & Emergency Outage Report 2012-E-0027 |
| | | 106277 | No.1 Reactor was taken out of service due to Buchholz alarm. CB 5922 also developed pole discrepancy condition when attempting to open. The pole discrepancy in CB5922 caused overloading of the Neutral Earthing Reactor and resulted in the buchholz alarm. The red phase pole of CB5922 was replaced. | A time lag developed due to the repair of equipment. | 26/03/12 | 07:17:00 | 15/04/12 | 15:21:00 | Rx No.2 Armidale | | 488:04 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-F-0178/2 |
| | | 106974 | Staff at Deniliquin had advised that 99L Coleambally to Deniliquin 132kV transmission line had a trip and reclose on 29/03/12. On investigation loadings on the SCADA indicated that 99L CB at Coleambally substation could still be open . Essential Energy were requested to send staff to check and found 99L CB open at Coleambally. After inspection 99L CB was closed at 10:32hrs. Auto reclose did not occur at Coleambally although set to AUTO. A patrol confirmed the trip was caused by stuble burn off and TG communicated the likely nature of this cause to the relevant property owner. | A time lag developed due to the lack of communications at Coleambally and non operation of control equipment. | 29/03/12 | 17:48:00 | 12/04/12 | 10:32:00 | 99L | | 328:44 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-F-0204/2 |
| | | 109541 | No.1 Capacitor at Sydney South 330kV Substation tripped on attempt to close. . CB 4712 inspected and found broken rod on No.1 Trip coil. CB not available until repaired. | A time lag developed due to the repair of equipment. | 17/05/12 | 06:09:00 | 5/06/12 | 14:48:00 | Cap No.1 Sydney South | | 464:39 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report Not available |
| | | 105899 | During switching to return to service 330kV B Bus No.1 Section at Sydney West substation, Red Phase of No.7 Capacitor Bus Disconnecter 5773 was unable to fully close . Bus Disconnecter was left Locked Open to allow repair | A time lag developed due to the repair of equipment. | 17/03/12 | 16:34:00 | 25/06/12 | 16:30:00 | Cap No.7 Sydney West | | 2399:56 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-E-0005/2 |
| | | 115668 | The inspection did not reveal any issues with the bank. On the same day, measurements were taken of the capacitance of each leg of the bank, along with measurements of the capacitance of each individual can. The results calculated from these measurements indicated that the capacitor bank was balanced. A 415V AC injection test was finally carried out to allow a more accurate balance to be carried out. | A time lag developed due to the repair of equipment. | 9/08/12 | 23:58:00 | 17/08/12 | 11:47:00 | Cap No.2 Newcastle | | 179:49 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-F-0320/2 |
| | | 115978 | The inspection did not reveal any issues with the bank. On the same day, measurements were taken of the capacitance of each leg of the bank, along with measurements of the capacitance of each individual can. The results calculated from these measurements indicated that the capacitor bank was balanced. A 415V AC injection test was finally carried out to allow a more accurate balance to be carried out. Capacitor tripped | A time lag developed due to the repair of equipment. | 17/08/12 | 11:47:00 | Still Out | | Cap No.2 Newcastle | | Still Out | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-F-0330/3 |
| | | 110566 | Advised that Bus Disconnecter No. 5753 will not close while doing switching HVPRI 37952 (Bus Outage).Bus Disconnecter No. 5753 Locked Open until repairs to be done. Capacitor will not be available. | A time lag developed due to the repair of equipment. | 3/06/12 | 14:19:00 | 25/06/12 | 08:13:00 | Cap No.5 Sydney North | | 521:54 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-F-0265 |
| | | 121694 | Transformer bushing tested and being replaced. | A time lag developed due to the repair of equipment. | 15/11/12 | 13:12:00 | 25/11/12 | 13:43:00 | Tx No.3 Wagga 132 | | 240:31 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-E-0031 |

| | | | | | | | | | | | | | |
|--|--|--------|--|--|---------|----------|----------|----------|-------------------|--------|---------|--|--|
| | | 115118 | No.2 330kV Transformer at Newcastle Substation was removed from service due to the initiation of a buchholz alarm. No.2 330kV Transformer at Newcastle Substation was removed from service due to the initiation of a buchholz alarm. Oil samples were taken from the blue phase tank, and the results indicated that the issue was related to the tapchanger on blue phase. The transformer's oil contains corrosive sulfur, which is believed to react with the silver plated contacts of the tapchanger. As the transformer is no longer required for service, no further action is required to address the tapchanger issue. | A time lag developed due to the time lag in obtaining a decision not to replace the transformer as it is now not required for the network. | 4/08/12 | 22:14:00 | 28/08/12 | 17:29:00 | Tx No 2 Newcastle | 571:15 | 168.000 | Capped in accordance with parameter 3 of definitions | Transgrid Forced & Emergency Outage Report 2012-E-0015/2 |
|--|--|--------|--|--|---------|----------|----------|----------|-------------------|--------|---------|--|--|

NOTE:

This worksheet should include a list all events that are proposed for exclusion.

Each proposed exclusion should include a description of the event, a description of the impact and quantification of the impact on the network and performance. The descriptive elements should also include reasons for the exclusion request making reference to the "Exclusion Definitions" worksheet.

Each exclusion should be entered onto one row for each parameter. Where one exclusion event applies to more than one parameter, the relevant details of the event should be entered under each of the measure headings.

The TNSP must provide details for all events requested for exclusion in this template. In the event that the TNSP wishes to provide further details of an exclusion, this should be provided with the TNSP's performance report. The source of information should be referenced in this template.

TransGrid - S1 - Transmission line availability

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|--------------------------------|-------------|--------|--------|--------|-----------|
| Transmission line availability | 98.90% | 99.05% | 99.26% | 99.36% | 99.60% |
| Weighting | -0.20% | -0.20% | 0.00% | 0.20% | 0.20% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 |
|----------------------|----------|-----------|---|--------------|----------------------------------|-----------|-----------|
| Performance | = | -0.002000 | | | Availability < 99.05% | -0.002000 | -0.002000 |
| | = | 0.952381 | x | Availability | + 99.05% ≤ Availability ≤ 99.26% | -0.005468 | -0.001670 |
| | = | 2.000000 | x | Availability | + 99.26% ≤ Availability ≤ 99.36% | -0.011482 | -0.003507 |
| | = | 0.002000 | | | 99.36% < Availability | 0.002000 | 0.002000 |

| Performance Outcomes | Performance (Without Exclusions) | Performance (Exclusions) |
|--------------------------------|----------------------------------|--------------------------|
| Transmission line availability | = 98.685909% | 99.084672% |
| S-Factor | = -0.200000% | -0.166979% |

NOTE:


This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - S2 - Transformer availability

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|--------------------------|-------------|--------|--------|--------|-----------|
| Transformer availability | 97.10% | 97.33% | 98.61% | 98.89% | 99.10% |
| Weighting | -0.15% | -0.15% | 0.00% | 0.15% | 0.15% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 |
|----------------------|----------|-----------|---|--------------|----------------------------------|-----------|-----------|
| Performance | = | -0.001500 | | | When: Availability < 97.33% | -0.001500 | -0.001500 |
| | = | 0.117188 | x | Availability | + 97.33% ≤ Availability ≤ 98.61% | -0.001474 | -0.001470 |
| | = | 0.535714 | x | Availability | + 98.61% ≤ Availability ≤ 98.89% | -0.006736 | -0.006721 |
| | = | 0.001500 | | | 98.89% < Availability | 0.001500 | 0.001500 |

| Performance Outcomes | Performance (Without Exclusions) | Performance (Exclusions) |
|--------------------------|----------------------------------|--------------------------|
| Transformer availability | = 97.352521% | 97.355420% |
| S-Factor | = -0.147361% | -0.147021% |

NOTE:


This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - S3 - Reactive plant availability

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|-----------------------------|-------------|--------|--------|--------|-----------|
| Reactive plant availability | 98.50% | 98.65% | 99.12% | 99.33% | 99.50% |
| Weighting | -0.10% | -0.10% | 0.00% | 0.10% | 0.10% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 |
|----------------------|----------|-----------|---|--------------|--------------------------------|-----------|-----------|
| Performance | = | -0.001000 | | | When: Availability < 98.65% | -0.001000 | -0.001000 |
| | = | 0.212766 | x | Availability | 98.65% ≤ Availability ≤ 99.12% | -0.008332 | -0.008332 |
| | = | 0.476190 | x | Availability | 99.12% ≤ Availability ≤ 99.33% | -0.018649 | -0.018649 |
| | = | 0.001000 | | | 99.33% < Availability | 0.001000 | 0.001000 |

| Performance Outcomes | Performance (Without Exclusions) | Performance (Exclusions) |
|-----------------------------|----------------------------------|--------------------------|
| Reactive plant availability | = 95.203785% | 95.203785% |
| S-Factor | = -0.100000% | -0.100000% |

NOTE:


This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - S4 - Loss of supply event frequency >0.05 system minutes

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|---|-------------|---------|--------|--------|-----------|
| Loss of supply event frequency >0.05 system minutes | 9 | 7 | 4 | 2 | - |
| Weighting | -0.25% | -0.250% | 0.00% | 0.250% | 0.25% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 | |
|----------------------|----------|-----------|---|---------------|-------------------|-----------------------|-----------|----------|
| Performance | = | -0.002500 | | | 7 < No. of events | -0.002500 | -0.002500 | |
| | = | -0.000833 | x | No. of events | + 0.003333 | 4 ≤ No. of events ≤ 7 | 0.000833 | 0.000833 |
| | = | -0.001250 | x | No. of events | + 0.005000 | 2 ≤ No. of events ≤ 4 | 0.001250 | 0.001250 |
| | = | 0.002500 | | | | No. of events < 2 | 0.002500 | 0.002500 |

| Loss of supply event frequency >0.05 system minutes | = | Performance (Without Exclusions) | Performance (Exclusions) |
|---|---|----------------------------------|--------------------------|
| Loss of supply event frequency >0.05 system minutes | = | 3 | 3 |
| S-Factor | = | 0.125000% | 0.125000% |


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - S5 - Loss of supply event frequency >0.25 system minutes

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|---|-------------|---------|--------|--------|-----------|
| Loss of supply event frequency >0.25 system minutes | 4 | 2 | 1 | 0 | 0 |
| Weighting | -0.10% | -0.100% | 0.00% | 0.100% | 0.10% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 |
|----------------------|----------|-----------|---|---------------|-----------------------|-----------|-----------|
| Performance | = | -0.001000 | | | 2 < No. of events | -0.001000 | -0.001000 |
| | = | -0.001000 | x | No. of events | 1 ≤ No. of events ≤ 2 | 0.000000 | 0.000000 |
| | = | -0.001000 | x | No. of events | 0 ≤ No. of events ≤ 1 | 0.000000 | 0.000000 |
| | = | 0.001000 | | | No. of events = 0 | 0.001000 | 0.001000 |

| Loss of supply event frequency >0.25 system minutes | = | Performance (Without Exclusions) | Performance (Exclusions) |
|---|---|----------------------------------|--------------------------|
| Loss of supply event frequency >0.25 system minutes | = | 1 | 1 |
| S-Factor | | 0.000000% | 0.000000% |


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - S6 - Average outage duration

| Performance Targets | Graph start | Collar | Target | Cap | Graph end |
|-------------------------|-------------|---------|--------|--------|-----------|
| Average outage duration | 1,199 | 999 | 824 | 649 | - |
| Weighting | -0.20% | -0.200% | 0.00% | 0.200% | 0.20% |

| Performance Formulae | Formulae | | | | Conditions | S- Calc 1 | S- Calc 2 |
|----------------------|----------|-----------|---|---------------------|----------------------|-----------|-----------|
| Performance | = | -0.002000 | | | 999 < Duration | -0.002000 | -0.002000 |
| | = | -0.000011 | x | Duration + 0.009417 | 824 ≤ Duration ≤ 999 | -0.012444 | -0.010170 |
| | = | -0.000011 | x | Duration + 0.009417 | 649 ≤ Duration ≤ 824 | -0.012444 | -0.010170 |
| | = | 0.002000 | | | Duration < 649 | 0.002000 | 0.002000 |

| Average outage duration | = | Performance (Without Exclusions) | Performance (Exclusions) |
|-------------------------|---|----------------------------------|--------------------------|
| Average outage duration | = | 1912.808411 | 1713.906542 |
| S-Factor | = | -0.200000% | -0.200000% |

NOTE:


This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



TransGrid - Revenue Calculation

| <i>Revenue cap information</i> | |
|-----------------------------------|---------------|
| Base year allowed revenue | \$678,400,000 |
| Base year | 2009-10 |
| X-factor | -5.61% |
| Commencement of regulatory period | 1-Jul-09 |

| <i>Annual revenue adjusted for CPI</i> | Mar-09 | Mar-10 | Mar-11 | Mar-12 | Mar-13 | Mar-14 |
|--|--------|--------|--------|--------|--------|--------|
| CPI | 166.2 | 171.0 | 176.7 | 179.5 | - | - |

| Nominal annual revenue | 2009-10 | 2010-11 | 2011-12 | 2012-13 | 2013-14 |
|------------------------|---------------|---------------|---------------|---------------|---------|
| Allowed Revenue | \$678,400,000 | \$737,150,175 | \$804,454,443 | \$863,046,907 | |

| <i>Calendar year revenue</i> | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 |
|------------------------------|---------------|---------------|---------------|---------------|------|------|
| Revenue | \$339,200,000 | \$707,775,087 | \$770,802,309 | \$833,750,675 | | |

NOTE:

This sheet will automatically update based on data on input sheets.

Grey cells show calendar year revenue

Green cells are for formula

TransGrid - Performance outcomes

Revenue calendar year

\$833,750,675

| S | Performance parameter | Target | Performance without exclusions | | | Performance with exclusions | | | Impact of exclusions |
|---------------|---|--------|--------------------------------|------------|-----------------|-----------------------------|------------|-----------------|----------------------|
| | | | Performance | S-Factor | Final Incentive | Performance | S-Factor | Final Incentive | |
| S1 | Transmission line availability | 99.26% | 98.685909% | -0.200000% | -\$1,667,501 | 99.084672% | -0.166979% | -\$1,392,191 | 0.033021% |
| S2 | Transformer availability | 98.61% | 97.352521% | -0.147361% | -\$1,228,622 | 97.355420% | -0.147021% | -\$1,225,789 | 0.000340% |
| S3 | Reactive plant availability | 99.12% | 95.203785% | -0.100000% | -\$833,751 | 95.203785% | -0.100000% | -\$833,751 | 0.000000% |
| S4 | Loss of supply event frequency >0.05 system minutes | 4 | 3 | 0.125000% | \$1,042,188 | 3 | 0.125000% | \$1,042,188 | 0.000000% |
| S5 | Loss of supply event frequency >0.25 system minutes | 1 | 1 | 0.000000% | \$0 | 1 | 0.000000% | \$0 | 0.000000% |
| S6 | Average outage duration | 824 | 1913 | -0.200000% | -\$1,667,501 | 1714 | -0.200000% | -\$1,667,501 | 0.000000% |
| TOTALS | | | | -0.522361% | -\$4,355,187 | | -0.489000% | -\$4,077,045 | 0.033360% |

NOTE:

This sheet will automatically update based on data in input sheets.

Grey cell shows relevant calendar year revenue

Green cells show performance measure targets

Pink cells show performance, s-factor results and financial incentive without exclusions

Orange cells show performance, s-factor results and financial incentive with exclusions

| Aggregate outcome | |
|--|--------------|
| S-factor | -0.489000% |
| Financial Incentive | -\$4,077,045 |
| Financial year affected by financial incentive | 2013/14 |

TransGrid - Defined exclusions

| Parameter 1- Transmission Line Availability | | | |
|--|---|--|--|
| No. | Defined exclusions | Further description of exclusion | Reference |
| 1.1 | Outages on assets that are not providing prescribed transmission services. | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 1.2 | 3rd party outage | Any outages shown to be caused by a fault or other event on a 'third party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list). | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 1.3 | Outages to control fault levels | Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required) | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 1.4 | Force majeure events | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 1.5 | Transient interruptions less than one (1) minute | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 1.6 | The opening of one end of a transmission circuit | The opening of only one end of a transmission circuit (eg where the transmission circuit remains energised and available to carry power with immediate manual or automatic return to service) | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| 1.7 | Underground cable damaged by an external party | Outages for remedial repairs to an underground power cable damaged by an external party are capped at 14 days if: - the external party did not enquire with 'dial before you dig' or - the external party enquired, received accurate information and did not follow this information. | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| Parameter 2- Transformer Availability | | | |
| No. | Defined exclusions | Further description of exclusion | Reference |
| 2.1 | Outages on assets that are not providing prescribed transmission services. | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 2.2 | 3rd party outage | Any outages shown to be caused by a fault or other event on a 'third party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list). | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 2.3 | Outages to control fault levels | Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required) | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 2.4 | Force majeure events | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 2.5 | Transient interruptions less than one (1) minute | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 2.6 | Auxiliary transformers | | |
| 2.7 | Static VAR compensator transformers (which are counted as part of the SVC) | | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| 2.8 | The opening of one end of a transmission circuit | The opening of only one or both sides of a transformer for operational purposes, such as to control losses, fault levels, incompatibility of tap changes etc but where the transformer remains available to carry power on immediate manual or automatic return to service | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| 2.9 | The period where a transformer is made available for service, but not switched in, at the end of each day of a multi-day planned outage | | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| Parameter 3- Reactive Plant Availability | | | |
| No. | Defined exclusions | Further description of exclusion | Reference |
| 3.1 | Outages on assets that are not providing prescribed transmission services. | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 3.2 | 3rd party outage | Any outages shown to be caused by a fault or other event on a 'third party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list). | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 3.3 | Outages to control fault levels | Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required) | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 3.4 | Force majeure events | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 3.5 | Transient interruptions less than one (1) minute | | Service Target Performance Incentive Scheme (March 2008) p. 32 |
| 3.6 | Capacitor banks and reactors operating less than 66kV | | Service Target Performance Incentive Scheme (March 2008) p. 33 |
| 3.7 | reactive plant switched out by System Operations, or left out after repairs that make it available for service for operational purposes | | Service Target Performance Incentive Scheme (March 2008) p. 33 |

| Parameter 4- Loss of supply event frequency > 0.05 system minutes (No.) | | | |
|---|---|---|--|
| No. | Defined exclusions | Further description of exclusion | Reference |
| 4.1 | Outages on assets that are not providing prescribed transmission services (e.g. some connection assets) | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.2 | Successful reclose events (less than one minute duration) | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.3 | Any outages shown to be caused by a fault or other event on a 'third party system'-e.g. intertrip signal, generator outage, customer installation | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.4 | Planned outages | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.5 | Force majeure events | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.6 | Where TransGrid protection operates correctly due to a fault on a customer's or a third party system | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.7 | Pumping station supply interruption | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 4.8 | Outage caused by customer's own control system during a transient voltage fluctuation | | Service Target Performance Incentive Scheme (March 2008) p. 34 |

| Parameter 5 - Loss of supply event frequency > 0.25 system minutes (No.) | | | |
|--|---|---|--|
| No. | Defined exclusions | Further description of exclusion | Reference |
| 5.1 | Outages on assets that are not providing prescribed transmission services (e.g. some connection assets) | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.2 | Successful reclose events (less than one minute duration) | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.3 | Any outages shown to be caused by a fault or other event on a 'third party system'-e.g. intertrip signal, generator outage, customer installation | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.4 | Planned outages | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.5 | Force majeure events | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.6 | Where TransGrid protection operates correctly due to a fault on a customer's or a third party system | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.7 | Pumping station supply interruption | | Service Target Performance Incentive Scheme (March 2008) p. 34 |
| 5.8 | Outage caused by customer's own control system during a transient voltage fluctuation | | Service Target Performance Incentive Scheme (March 2008) p. 34 |

| Parameter 6 - Average Outage Duration | | | |
|--|---|---|--|
| No. | Defined exclusions | Further description of exclusion | Reference |
| 6.1 | Planned outages | | Service Target Performance Incentive Scheme (March 2008) p. 35 |
| 6.2 | Momentary interruptions (less than one minute) | | Service Target Performance Incentive Scheme (March 2008) p. 35 |
| 6.3 | Force majeure | As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51 | Service Target Performance Incentive Scheme (March 2008) p. 35 |
| 6.4 | Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation, customer request or AEMO direction | | Service Target Performance Incentive Scheme (March 2008) p. 35 |
| 6.5 | Outages for capacitor banks and reactors operating at less than 66kV | | Service Target Performance Incentive Scheme (March 2008) p. 35 |

Service Target Performance Incentive Scheme - Definition of Force Majeure

| Definition of Force Majeure | Reference |
|---|--|
| <p>For the purpose of applying the <i>service target performance incentive scheme</i>, force majeure events means any event, act or circumstance or combination of events, acts and circumstances which (despite the observance of good electricity industry practice) is beyond the reasonable control of the part affected by any such event, which may include, without limitation, the following:</p> <ul style="list-style-type: none">- fire, lightning, explosion, flood, earthquake, storm, cyclone, action of the elements, riots, civil commotion, malicious damage, natural disaster, sabotage, act of a public enemy, act of God, war (declared or undeclared), blockage, revolution, radioactive contamination, toxic or dangerous chemical contamination or force of nature.- action or inaction by a court, government agency (including denial, refusal or failure to grant any authorisation, despite timely best endeavour to obtain same)- strikes, lockouts, industrial and/or labour disputes and/or difficulties, work bans, blockades, picketing- acts or omissions (other than failure to pay money) of a party other than the TNSP, which party either is connected to or uses the high voltage grid or is directly connected to or uses a system for the supply of electricity that in turn is connected to the high voltage grid <p>- where those acts or omissions affect the ability of the TNSP to perform its obligation under the service standard by virtue of that direct or indirect connection to or use of the high voltage grid</p> <p>In determining what force majeure events should be excluded the AER will consider the following:</p> <ul style="list-style-type: none">- was the event unforeseeable and its impact extraordinary, uncontrollable and not manageable?- does the event occur frequently? If so, how did the impact of the particular event differ?- could the TNSP, in practice, have prevented the impact (not necessarily the event itself)?- could the TNSP have effectively reduced the impact of the event by adopting better practices? | Service Target Performance Incentive Scheme (January 2007) p. 31 |