

SPI PowerNet Pty Ltd

**Electricity Transmission
Revenue Proposal
2014/15 – 2016/17**

**Appendix 6A:
PB STIPS Report**

**Fitting probability distributions
for SP AusNet reliability data
for STPIS Submission
(Parsons Brinkerhoff)**

Submitted: 28 February 2013

SP AusNet

**Fitting probability distributions for SP AusNet
reliability data for STPIS Submission**


15 February 2013

Document information

Client: SP AusNet
Title: Fitting probability distributions for SP AusNet reliability data for STPIS Submission
Document No: 2193220A- Rev2
Date: 15 February 2013

Rev	Date	Details
0	07/02/2013	Draft
1	14/02/2013	Final
2	15/02/2013	Final, corrections to introduction section 1

Author, Reviewer and Approver details

Prepared by:	J Zhang, P Walshe	Date: 06/02/2013	
Reviewed by:	S Pottachira	Date: 08/02/2013	
Approved by:	P Walshe	Date: 15/02/2013	

Distribution

SP AusNet

©Parsons Brinckerhoff Australia Pty Limited 2013

Copyright in the drawings, information and data recorded in this document (the information) is the property of Parsons Brinckerhoff. This document and the information are solely for the use of the authorised recipient and this document may not be used, copied or reproduced in whole or part for any purpose other than that for which it was supplied by Parsons Brinckerhoff. Parsons Brinckerhoff makes no representation, undertakes no duty and accepts no responsibility to any third party who may use or rely upon this document or the information.

Document owner

Parsons Brinckerhoff Australia Pty Limited

ABN 80 078 004 798

Level 15 28 Freshwater Place

Southbank VIC 3006

Tel: +61 3 9861 1111

Fax: +61 3 9861 1144

Email: melbourne@pb.com.au

www.pbworld.com

Certified to ISO 9001, ISO 14001, AS/NZS 4801

A GRI Rating: Sustainability Report 2011

Contents

	Page number
1. Introduction	1
1.1 Approach	1
2. Results of distribution fitting	2
2.1 Average outage duration	2
2.2 Loss of supply event frequency	4
2.3 Average circuit outage rate	7
3. Summary of findings	20

1. Introduction

Parsons Brinckerhoff has been engaged by SP AusNet to assist with the determination of suitable targets and other attributes for the parameters of its service target performance incentive scheme (STIPS).

The service component of SP AusNet's STIPS will measure performance against the following parameters:

- Average outage duration (1 sub-parameter)
- Loss of supply event frequency (2 sub-parameters)
- Average circuit outage rates (6 sub-parameters).

Parsons Brinckerhoff determined a curve of best fit to SP AusNet's reliability data from the past five years 2008-2012 for each of the sub-parameters and calculated the standard deviation on which proposed caps and collars for this scheme are based.

1.1 Approach

Parsons Brinckerhoff used the @RISK product, a risk analysis and simulation add-in tool for Microsoft Excel, to determine the types of probability distribution that best fit the reliability data.

Recognising the need to present the best fit distribution curve based on the nature of the reliability data, the following distribution parameters were chosen for this exercise.

- Average outage duration data are fitted using continuous probability distributions bounded at a lower limit of zero
- Loss of supply event frequency are fitted with discrete probability distributions
- Availability rates are fitted with continuous probability distributions bounded at a lower limit of zero.

Three key fit statistics were used to measure how well the probability distribution functions fit the input data. For discrete probability distributions, the Chi Squared (ChiSq) fit statistic was used. For non-discrete distributions, the Kolmogorov-Smirnov (K-S) and the Anderson-Darling (A-D) fit statistics were used.

The K-S fit statistic focuses on the differences between the middle of the fitted distribution and the input data. The A-D fit statistic focuses on the difference between the tails of fitted distribution and input data. Where the input data was concentrated around the middle of a distribution curve the K-S fit statistic was used and where the data was near the tails the A-D fit statistic was used. The results from both were compared in each case. Where the input data was both in the middle and the tails of a distribution, the result from the A-D fit statistic was favoured, because the best fit of the data and the distribution curve at the tails improves the calculation of the scheme measures (caps and collars at one or two standard deviations).

Once the probability distribution function of best fit was determined for each sub-parameter the standard deviation of the probability distribution functions were calculated.

Because a probability distribution is being fitted to a dataset of five values only for each sub-parameter, the fit statistics are typically low in value and the curve of best fit is sensitive to small changes in any of the five values. The curve of second best fit was examined to test for any large variations in the calculated standard deviation that might indicate that the curve of best fit should not be used.

2. Results of distribution fitting

2.1 Average outage duration

The average outage duration is a measure of the response time to outages. The optimal performance limit is close to zero, which represents an immediate response; as such a lower limit of zero is set for fitting curves to the data.

The best fit using the A-D fit statistic is the Exponential distribution curve (figure 1), where the duration data is spread across the middle and tails of the distribution. Table 1 shows the statistical results using other distributions to fit the duration data using the A-D fit statistic, where it can be seen the Erlang distribution curve exhibits the second best fit.

Figure 1 Average outage duration – continuous distribution fit comparison using A-D




Table 1 Average outage duration – statistics table for A-D

Fit	A-D	Input	Expon	Erlang	Pareto2	Gamma	Weibull
Distribution Statistics							
Expon	0.4745	Minimum	4.0000	0.0000	0.0000	0.0000	0.0000
Erlang	0.4745	Maximum	230.0000	+Infinity	+Infinity	+Infinity	+Infinity
Pareto2	0.4745	Mean	97.9556	97.9556	97.9556	97.9556	97.3162
Gamma	0.4785	Mode	88.7500 [e...]	0.0000	0.0000	0.0000	3.1732
Weibull	0.4899	Median	91.7780	67.8976	67.8976	67.8976	12.8495
LogLogistic	0.5952	Std. Deviation	82.2058	97.9556	97.9556	97.9556	72.7936
Triang	0.6068	Skewness	1.0905	2.0000	2.0000	2.0000	87.6454
Lognorm	0.6640	Kurtosis	5.4675	9.0000	9.0000	9.0000	1.7059
Lognorm2	0.6640	Percentiles					
Uniform	1.1859	5%	4.0000	5.0245	5.0245	5.0245	7.0024
Rayleigh	1.2669	10%	4.0000	10.3207	10.3207	10.3207	13.3774
InvGauss	1.3007	15%	4.0000	15.9196	15.9196	15.9196	19.7531
ChiSq	---	20%	4.0000	21.8582	21.8582	21.8582	26.2690
BetaGeneral	---	25%	71.5000	28.1801	28.1801	28.1801	33.0109
Pareto3	N/A	30%	71.5000	34.9383	34.9383	34.9383	40.0500
Pearson3	N/A	35%	71.5000	42.1976	42.1976	42.1976	47.4610
Pearson5	N/A	40%	71.5000	50.0382	50.0382	50.0382	55.3216
Pearson6	N/A	45%	91.7780	58.5615	58.5615	58.5615	63.7269
		50%	91.7780	67.8976	67.8976	67.8976	72.7936
		55%	91.7780	78.2183	78.2183	78.2183	82.6715
		60%	92.5000	89.7558	89.7558	89.7558	93.5559
		65%	92.5000	102.8360	102.8360	102.8360	105.7352
		70%	92.5000	117.9359	117.9359	117.9359	119.5986
		75%	92.5000	135.7953	135.7953	135.7953	135.7674
		80%	92.5000	157.6535	157.6535	157.6535	155.2687
		85%	230.0000	185.8335	185.8335	185.8335	180.0151
		90%	230.0000	225.5511	225.5511	225.5511	214.2668
		95%	230.0000	293.4488	293.4488	293.4488	271.4739

The best fit using the K-S fit statistic is the Triangle distribution curve (figure 2). Table 2 illustrates other distribution curves fitting the outage duration data using the K-S statistics, the LogLogistic distribution curve exhibits the second best fit for the outage duration data.

Figure 2 Average outage duration – continuous distribution fit comparison using K-S




Table 2 Average outage duration – statistics table for K-S

Fit Ranking	Input	Triang	LogLogistic	Weibull	Gamma	Expon			
Fit	K-S	Distribution Statistics							
Triang	0.2711	4.0000	0.0000	0.0000	0.0000	0.0000			
LogLogistic	0.2931	230.0000	290.5189	+Infinity	+Infinity	+Infinity			
Weibull	0.2931	97.9556	98.1730	219.4410	97.3162	97.9556			
Gamma	0.3138	Mean	98.7500 [e..]	-4.0000	19.1694	12.8495	3.1732		
Expon	0.3181	Mode	91.7780	86.5101	72.9474	72.7936	68.7736		
Erlang	0.3181	Median	82.2058	68.0095	+Infinity	87.6454	96.3559		
Pareto2	0.3181	Std. Deviation	1.0905	0.5653	+Infinity	1.7059	1.9673		
Rayleigh	0.3653	Skewness	5.4675	2.4000	+Infinity	7.2023	6.8056		
Lognorm	0.3695	Kurtosis	Percentiles						
Lognorm2	0.3695		5%	4.0000	9.3122	6.6013	7.0024	5.4470	5.0245
BetaGeneral	0.3963		10%	4.0000	16.8124	14.7971	13.3774	10.9567	10.3207
Uniform	0.4783		15%	4.0000	24.5240	20.7039	19.7531	16.6993	15.9196
InvGauss	0.5097		20%	4.0000	32.4660	26.6613	26.2690	22.7372	21.8582
ChiSq	0.7064		25%	71.5000	40.6602	32.8544	33.0109	29.1247	28.1801
			30%	71.5000	49.1325	39.4311	40.0508	35.9202	34.9383
			35%	71.5000	57.9131	46.5386	47.4610	43.1910	42.1976
			40%	71.5000	67.0385	54.3448	55.3216	51.0182	50.0382
			45%	91.7780	76.5527	63.0571	63.7269	59.5028	58.5615
			50%	91.7780	86.5101	72.9474	72.7936	68.7736	67.8976
			55%	91.7780	96.9792	84.3890	82.6715	78.9992	78.2183
			60%	92.5000	106.0479	97.9179	93.5599	90.4073	89.7558
			65%	92.5000	119.8329	114.3422	105.7352	103.3166	102.8360
			70%	92.5000	132.4944	134.9527	119.9986	118.1933	117.9359
			75%	92.5000	146.2629	161.9670	135.7674	135.7595	135.7953
			80%	92.5000	161.4925	199.5900	155.2687	157.2240	157.6353
			85%	230.0000	178.7787	257.0204	180.0151	184.8521	185.8335
			90%	230.0000	199.2834	359.6192	214.2668	223.7269	225.5511
			95%	230.0000	226.0057	618.6654	271.4739	290.0582	293.4488

As the data concentrates about both the middle and tails of the distribution, the A-D fit has been selected and the curve of best fit determined as Exponential. The curve of second best fit is the Erlang curve. The standard deviations of the two curves are the same (97.96).

In comparison, the standard deviation of the best K-S fit curve (Triangle) is significantly less at 68.01. The upper limit of the Triangle curve, however, is bounded at 290.5, which is counter intuitive to the possible performance outcomes. Hence the adoption of this curve to represent the data is inappropriate.

2.2 Loss of supply event frequency

Losses of supply events represent discrete occurrences of failure. In order to best fit the loss of supply events data, discrete distribution curves are used with equal interval binning.

Number of events > 0.05 system minutes

Figure 3 shows the NegBin discrete distribution curve is the best fit for the loss of supply events greater than 0.05 systems. Table 3 is provided to show the variation in statistics for other discrete distribution curves.

Noting that the Chi Squared fit statistics are similar for the top three curves of best fit, and that the standard deviations vary widely, the curve of second best fit (Geometric) and the curve of third best fit (Poisson) were also examined. The standard deviations are 2.45, 2.00 and 1.41 respectively. The relatively high variation in standard deviations indicates some uncertainty in the curve fitting.

The average of the three values (2.45, 2.00, 1.41) is 1.95, close to the standard deviation for the curve of best fit. This indicates that the standard deviation of 2.000 for the curve of best fit (NegBin) is an appropriate value to use in setting caps and collars.

Figure 3 No. of events > 0.05 system minutes – best discrete distribution fit - NegBin




Table 3 No. of events > 0.05 system minutes – discrete distributions statistics table

Fit Ranking		Function	Input	NegBin	Geomet	Poisson	HyperGeo	IntUnifo..
Fit	Chi-Sq			=RiskNegBi..	=RiskGeom..	=RiskPoisso..	=RiskHyper..	=RiskInt..
NegBin	0.0755	- Distribution Statistics						
Geomet	0.1339	Minimum	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Poisson	0.1564	Maximum	6.0000	+Infinity	+Infinity	+Infinity	63.0000	6.0000
HyperGeo	0.1947	Mean	2.0000	2.0000	2.0000	2.0000	1.9801	3.0000
IntUniform	1.0667	Mode	1.0000	0.0000	0.0000	1.0000	2.0000	0.0000
Binomial	N/A	Median	1.0000	1.0000	1.0000	2.0000	2.0000	3.0000
		Std. Deviation	2.3452	2.0000	2.4495	1.4142	1.3836	2.0000
		Skewness	1.7444	1.5000	2.0412	0.7071	0.6748	0.0000
		Kurtosis	6.3223	6.2500	9.1667	3.5000	3.4219	1.7500
		- Percentiles						
		5%	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		10%	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		15%	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000
		20%	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000
		25%	1.0000	0.0000	0.0000	1.0000	1.0000	1.0000
		30%	1.0000	1.0000	0.0000	1.0000	1.0000	2.0000
		35%	1.0000	1.0000	1.0000	1.0000	1.0000	2.0000
		40%	1.0000	1.0000	1.0000	1.0000	1.0000	2.0000
		45%	1.0000	1.0000	1.0000	2.0000	2.0000	3.0000
		50%	1.0000	1.0000	1.0000	2.0000	2.0000	3.0000
		55%	1.0000	2.0000	1.0000	2.0000	2.0000	3.0000
		60%	1.0000	2.0000	2.0000	2.0000	2.0000	4.0000
		65%	2.0000	2.0000	2.0000	2.0000	2.0000	4.0000
		70%	2.0000	3.0000	2.0000	3.0000	3.0000	4.0000
		75%	2.0000	3.0000	3.0000	3.0000	3.0000	5.0000
		80%	2.0000	3.0000	3.0000	3.0000	3.0000	5.0000
		85%	6.0000	4.0000	4.0000	3.0000	3.0000	5.0000
		90%	6.0000	5.0000	5.0000	4.0000	4.0000	6.0000
		95%	6.0000	6.0000	7.0000	5.0000	4.0000	6.0000

Number of events > 0.30 system minutes

The discrete distribution of best fit for the loss of supply events greater than 0.30 system minutes is the IntUniform curve, giving a standard deviation of 0.816. Table 4 is provided to show the statistics for other discrete distribution curves.

The curve of second best fit (Binomial) has a significantly worse fit statistic – 7.2 compared to 1.6 for the curve of best fit – hence it has not been considered.

Figure 4 No. of event > 0.30 system minutes – best discrete distribution fit – IntUniform




Table 4 No. of events > 0.30 system minutes – discrete distributions statistics table

Fit	Chi-Sq	Input	IntUniform	Binomial	HyperGeo	Poisson	Geomet
IntUniform	1.6000						
Binomial	7.2024						
HyperGeo	7.2029						
Poisson	8.2707						
Geomet	11.9605						
NegBin	N/A						

Function	=RiskIntUni..	=RiskBinomi..	=RiskHyper..	=RiskPoisso..	=RiskGeomet(0.55556)	
Minimum	0.0000	0.0000	0.0000	0.0000	0.0000	
Maximum	2.0000	2.0000	2.0000	2.0000	+Infinity	
Mean	0.8000	1.0000	0.8000	0.8000	0.8000	
Mode	0.0000	0.0000	1.0000	1.0000	0.0000	
Median	1.0000	1.0000	1.0000	1.0000	1.0000	
Std. Deviation	0.8367	0.8165	0.6928	0.6928	0.8944	
Skewness	0.5122	0.0000	0.2887	0.2887	1.1180	
Kurtosis	2.3878	1.5000	2.0833	2.0834	4.2500	
Percentiles						
5%	0.0000	0.0000	0.0000	0.0000	0.0000	
10%	0.0000	0.0000	0.0000	0.0000	0.0000	
15%	0.0000	0.0000	0.0000	0.0000	0.0000	
20%	0.0000	0.0000	0.0000	0.0000	0.0000	
25%	0.0000	0.0000	0.0000	0.0000	0.0000	
30%	0.0000	0.0000	0.0000	0.0000	0.0000	
35%	0.0000	1.0000	0.0000	0.0000	0.0000	
40%	0.0000	1.0000	1.0000	1.0000	0.0000	
45%	1.0000	1.0000	1.0000	1.0000	1.0000	
50%	1.0000	1.0000	1.0000	1.0000	1.0000	
55%	1.0000	1.0000	1.0000	1.0000	1.0000	
60%	1.0000	1.0000	1.0000	1.0000	1.0000	
65%	1.0000	1.0000	1.0000	1.0000	1.0000	
70%	1.0000	2.0000	1.0000	1.0000	1.0000	
75%	1.0000	2.0000	1.0000	1.0000	1.0000	
80%	1.0000	2.0000	1.0000	1.0000	1.0000	
85%	2.0000	2.0000	2.0000	2.0000	2.0000	
90%	2.0000	2.0000	2.0000	2.0000	2.0000	
95%	2.0000	2.0000	2.0000	2.0000	3.0000	

2.3 Average circuit outage rate

Average circuit outage rates represent measures of availability for components of transmission circuits. The optimal performance limit is 0%, which represents total availability for the component for the year; as such a lower limit of zero is set for fitting non-continuous curves to the data.

The availability rate measures are presented based on the components and nature of availability in the following categories.

Lines outage rate – fault performance

The K-S fit statistic has the Weibull distribution curve delivering the best fit (figure 5), while using the A-D fit statistic, the LogLogistic curve is best fitting (figure 6). As most of the data congregate near the two tails, the A-D fit statistic is preferred (LogLogistic), giving a standard deviation of 0.090.

Tables 5 and 6 present the variation in statistical fit by other distribution curves for K-S and A-D respectively. The standard deviations for the curve of second best fit (Pearson5) and the Weibull are 0.080 and 0.072, being slightly lower than for the preferred curve.

Figure 5 Lines - fault non-continuous distribution comparison using K-S




Table 5 Lines – fault non-continuous distribution statistics table for K-S

Fit	K-S	Function	Webul	LogLogistic	Triang	Gamma	InvGauss	Lognorm
LogLogistic	0.2182							
Triang	0.2226							
Gamma	0.2239							
InvGauss	0.2253							
Lognorm	0.2255							
Lognorm2	0.2255							
Pearson5	0.2263							
Pearson6	0.2263							
Erlang	0.2267							
Rayleigh	0.3233							
Uniform	0.3752							
Expon	0.4774							
Pareto2	0.4774							
ChiSq	0.5494							
BetaGeneral	N/A							
Pareto	N/A							

Function	Webul	LogLogistic	Triang	Gamma	InvGauss	Lognorm
Minimum	0.1681	0.0000	0.0000	0.0000	0.0000	0.0000
Maximum	0.3583	+Infinity	+Infinity	0.3583	+Infinity	+Infinity
Mean	0.2590	0.2599	0.2622	0.2389	0.2590	0.2592
Mode	0.1728 [est]	0.2671	0.2335	0.3583	0.2385	0.2285
Median	0.2437	0.2617	0.2488	0.2534	0.2522	0.2487
Std. Deviation	0.0809	0.0722	0.0902	0.0845	0.0729	0.0790
Skewness	0.2398	-0.0957	2.0116	-0.5657	0.5629	0.8684
Kurtosis	0.7325	2.7522	17.9225	2.4000	3.4752	4.4663

Percentiles	Webul	LogLogistic	Triang	Gamma	InvGauss	Lognorm
5%	0.1681	0.1374	0.1475	0.0801	0.1519	0.1557
10%	0.1681	0.1642	0.1685	0.1133	0.1711	0.1727
15%	0.1681	0.1828	0.1829	0.1388	0.1850	0.1852
20%	0.1681	0.1977	0.1946	0.1603	0.1965	0.1957
25%	0.2000	0.2106	0.2048	0.1792	0.2069	0.2053
30%	0.2000	0.2221	0.2141	0.1963	0.2164	0.2140
35%	0.2000	0.2327	0.2229	0.2120	0.2256	0.2227
40%	0.2000	0.2427	0.2316	0.2266	0.2345	0.2313
45%	0.2437	0.2523	0.2401	0.2404	0.2433	0.2399
50%	0.2437	0.2617	0.2488	0.2534	0.2522	0.2487
55%	0.2437	0.2711	0.2579	0.2657	0.2613	0.2578
60%	0.3250	0.2804	0.2674	0.2776	0.2708	0.2674
65%	0.3250	0.2900	0.2777	0.2889	0.2809	0.2777
70%	0.3250	0.3000	0.2892	0.2998	0.2917	0.2890
75%	0.3250	0.3107	0.3024	0.3103	0.3038	0.3016
80%	0.3250	0.3224	0.3183	0.3205	0.3175	0.3164
85%	0.3583	0.3358	0.3386	0.3304	0.3341	0.3344
90%	0.3583	0.3522	0.3675	0.3399	0.3557	0.3586
95%	0.3583	0.3759	0.4197	0.3493	0.3894	0.3977

Figure 6 Lines - fault non-continuous distribution comparison using A-D




Table 6 Lines – fault non-continuous distribution statistics table for A-D

Fit Ranking	Fit	A-D	Function	=RiskLogLo..	=RiskPears..	=RiskPears..	=RiskInvGa..	=RiskLogno..	=RiskLogno..
Fit Ranking									
1	Pearson5	0.2597							
2	Pearson6	0.2609							
3	InvGauss	0.2624							
4	Lognorm	0.2637							
5	Lognorm2	0.2637							
6	Gamma	0.2702							
7	Erlang	0.2815							
8	Weibull	0.2873							
9	Rayleigh	0.5528							
10	Uniform	0.6972							
11	Expon	1.2235							
12	Pareto2	1.2235							
13	ChiSq	1.6672							
14	Triang	+Infinity							
15	BetaGeneral	N/A							
16	Pareto	N/A							
Fit									
Distribution Statistics									
	Minimum	0.1681	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
	Maximum	0.3583	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
	Mean	0.2590	0.2622	0.2597	0.2595	0.2590	0.2592	0.2592	0.2592
	Mode	0.1728 [est]	0.2335	0.2214	0.2237	0.2285	0.2294	0.2294	0.2294
	Median	0.2437	0.2488	0.2455	0.2464	0.2487	0.2488	0.2488	0.2488
	Std. Deviation	0.0809	0.0902	0.0799	0.0786	0.0750	0.0754	0.0754	0.0754
	Skewness	0.2398	2.0116	1.3598	1.2273	0.8684	0.8977	0.8977	0.8977
	Kurtosis	0.7325	17.9225	6.7989	6.0387	4.2569	4.4663	4.4663	4.4663
Percentiles									
	5%	0.1681	0.1475	0.1588	0.1579	0.1561	0.1557	0.1557	0.1557
	10%	0.1681	0.1685	0.1739	0.1736	0.1727	0.1727	0.1727	0.1727
	15%	0.1681	0.1829	0.1852	0.1852	0.1851	0.1852	0.1852	0.1852
	20%	0.1681	0.1946	0.1949	0.1951	0.1956	0.1957	0.1957	0.1957
	25%	0.2000	0.2048	0.2037	0.2042	0.2051	0.2053	0.2053	0.2053
	30%	0.2000	0.2141	0.2121	0.2128	0.2140	0.2143	0.2143	0.2143
	35%	0.2000	0.2229	0.2204	0.2211	0.2227	0.2229	0.2229	0.2229
	40%	0.2000	0.2316	0.2286	0.2294	0.2313	0.2315	0.2315	0.2315
	45%	0.2437	0.2401	0.2369	0.2378	0.2399	0.2401	0.2401	0.2401
	50%	0.2437	0.2488	0.2455	0.2464	0.2487	0.2488	0.2488	0.2488
	55%	0.2437	0.2579	0.2545	0.2554	0.2578	0.2579	0.2579	0.2579
	60%	0.3250	0.2674	0.2641	0.2650	0.2674	0.2675	0.2675	0.2675
	65%	0.3250	0.2777	0.2746	0.2754	0.2777	0.2777	0.2777	0.2777
	70%	0.3250	0.2892	0.2862	0.2869	0.2890	0.2890	0.2890	0.2890
	75%	0.3250	0.3024	0.2995	0.3000	0.3017	0.3016	0.3016	0.3016
	80%	0.3250	0.3183	0.3152	0.3155	0.3164	0.3163	0.3163	0.3163
	85%	0.3583	0.3386	0.3350	0.3348	0.3345	0.3344	0.3344	0.3344
	90%	0.3583	0.3675	0.3623	0.3612	0.3586	0.3586	0.3586	0.3586
	95%	0.3583	0.4197	0.4083	0.4053	0.3973	0.3977	0.3977	0.3977

Lines outage rate – forced outage performance

The data for lines forced to be unavailable is spread across the middle and the tails of the distribution curve. The best fit distribution for the lines forced outage performance for both the K-S and A-D fit statistics is the Pearson5 distribution curve (figure 7 and 8) giving a standard deviation of 0.017.

Tables 7 and 8 illustrate the other distribution fit statistics for the lines forced outage performance. The standard deviation for the curve of second best fit (InvGauss) is the same as for the curve of best fit.

Figure 7 Lines - forced non-continuous distribution comparison using K-S




Table 7 Lines – forced non-continuous distribution statistics table for K-S

Fit	K-S	Function	=RiskPears..	=RiskLogno..	=RiskLogno..	=RiskInvGa..	=RiskErlang..	=RiskGamm..
Lognorm	0.2578	Minimum	0.1250	0.0000	0.0000	0.0000	0.0000	0.0000
Lognorm2	0.2578	Maximum	0.1681	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
InvGauss	0.2579	Mean	0.1489	0.1489	0.1489	0.1489	0.1489	0.1489
Erlang	0.2585	Mode	0.1670 [est]	0.1452	0.1461	0.1461	0.1470	0.1470
Gamma	0.2591	Median	0.1429	0.1476	0.1479	0.1479	0.1482	0.1482
Weibull	0.2794	Std. Deviation	0.0183	0.0168	0.0166	0.0166	0.0165	0.0165
Rayleigh	0.5018	Skewness	-0.0952	0.4574	0.3364	0.3364	0.2222	0.2216
Triang	0.5532	Kurtosis	1.2607	3.3963	3.2019	3.2019	3.1868	3.0741
Expon	0.5682							
Uniform	0.5950							
ChiSq	0.6818							
BetaGeneral	N/A							
LogLogistic	N/A							
Pareto	N/A							
Pareto2	N/A							
Pearson5	N/A							

Figure 8 Lines - forced non-continuous distribution comparison using A-D




Table 8 Lines – forced non-continuous distribution statistics table for A-D

Fit Ranking	Fit	Function	Input	Pearson5	InvGauss	Lognorm	Lognorm2	Erlang	Gamma
1	A-D	=RiskPears..							
2	Pearson5	=RiskInvGa..							
3	InvGauss	=RiskLogno..							
4	Lognorm	=RiskLogno..							
5	Lognorm2	=RiskErlang..							
6	Erlang	=RiskGamm..							
7	Gamma								
8	Weibull								
9	Rayleigh								
10	Expon								
11	Uniform								
12	ChiSq								
13	Triang								
14	BetaGeneral								
15	LogLogistic								
16	Pareto								
17	Pareto2								
18	Pearson5								

Distribution Statistics	Input	Pearson5	InvGauss	Lognorm	Lognorm2	Erlang	Gamma
Minimum	0.1250	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Maximum	0.1681	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
Mean	0.1489	0.1489	0.1489	0.1489	0.1489	0.1489	0.1489
Mode	0.1670 [est]	0.1452	0.1461	0.1461	0.1470	0.1470	0.1470
Median	0.1429	0.1476	0.1479	0.1479	0.1479	0.1482	0.1482
Std. Deviation	0.0183	0.0168	0.0166	0.0166	0.0166	0.0165	0.0165
Skewness	-0.0952	0.4574	0.3348	0.3364	0.3364	0.2222	0.2216
Kurtosis	1.2607	3.3963	3.1868	3.2019	3.2019	3.0741	3.0737

Percentiles	Input	Pearson5	InvGauss	Lognorm	Lognorm2	Erlang	Gamma
5%	0.1250	0.1235	0.1232	0.1232	0.1232	0.1227	0.1228
10%	0.1250	0.1284	0.1283	0.1283	0.1283	0.1281	0.1281
15%	0.1250	0.1318	0.1318	0.1318	0.1318	0.1318	0.1318
20%	0.1250	0.1346	0.1347	0.1347	0.1347	0.1348	0.1348
25%	0.1417	0.1370	0.1372	0.1372	0.1372	0.1374	0.1374
30%	0.1417	0.1393	0.1395	0.1395	0.1395	0.1398	0.1398
35%	0.1417	0.1415	0.1417	0.1417	0.1417	0.1420	0.1420
40%	0.1417	0.1435	0.1438	0.1438	0.1438	0.1441	0.1441
45%	0.1429	0.1456	0.1459	0.1459	0.1459	0.1462	0.1462
50%	0.1429	0.1476	0.1479	0.1479	0.1479	0.1482	0.1482
55%	0.1429	0.1497	0.1500	0.1500	0.1500	0.1503	0.1503
60%	0.1667	0.1519	0.1522	0.1522	0.1522	0.1525	0.1525
65%	0.1667	0.1542	0.1544	0.1544	0.1544	0.1547	0.1547
70%	0.1667	0.1566	0.1568	0.1568	0.1568	0.1571	0.1570
75%	0.1667	0.1593	0.1595	0.1595	0.1595	0.1596	0.1596
80%	0.1667	0.1624	0.1625	0.1625	0.1625	0.1626	0.1625
85%	0.1681	0.1661	0.1660	0.1660	0.1660	0.1660	0.1660
90%	0.1681	0.1709	0.1706	0.1706	0.1706	0.1704	0.1703
95%	0.1681	0.1784	0.1776	0.1777	0.1777	0.1771	0.1770

Reactive plant outage rate – fault performance

Using the K-S fit statistic, the best fit distribution for reactive plant unavailability due to fault is the InvGauss (figure 9), while the A-D fit statistic has the Loglogistic curve as the best fit (figure 10). As the data is spread evenly across the middle and the tails of the distribution curve the A-D fit is preferred (LogLogistic), giving a standard deviation of 0.064.

Tables 9 and 10 are provided to show the variation in fit statistics of other distribution curves. The standard deviation for the curve of second best fit (InvGauss) at 0.058 is not materially different.

Figure 9 Reactive plant – fault non-continuous distribution comparison using K-S




Table 9 Reactive plant – fault non-continuous distribution statistics table for K-S

Fit Ranking	Fit	K-S	Function	Input	InvGauss	Lognorm	Lognorm2	Pearson6	Erlang	Gamma
	Lognorm	0.1364								
	Lognorm2	0.1364								
	Pearson6	0.1373								
	Erlang	0.1417								
	Gamma	0.1418								
	LogLogistic	0.1423								
	Pearson5	0.1468								
	Weibull	0.1583								
	BetaGeneral	0.2246								
	Triang	0.3525								
	Rayleigh	0.4288								
	Uniform	0.4750								
	ChiSq	0.5191								
	Expon	0.5323								
	Pareto2	0.5323								
	Pareto	N/A								
			Minimum	0.2468	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
			Maximum	0.4156	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
			Mean	0.3247	0.3247	0.3247	0.3247	0.3247	0.3247	0.3247
			Mode	0.2510 [est]	0.3095	0.3097	0.3097	0.3090	0.3145	0.3145
			Median	0.3247	0.3196	0.3196	0.3196	0.3193	0.3213	0.3213
			Std. Deviation	0.0643	0.0580	0.0580	0.0580	0.0583	0.0574	0.0574
			Skewness	0.3711	0.5355	0.5420	0.5420	0.5822	0.3536	0.3534
			Kurtosis	2.9009	3.4780	3.5268	3.5268	3.6374	3.1875	3.1873
			5%	0.2468	0.2389	0.2387	0.2387	0.2391	0.2364	0.2364
			10%	0.2468	0.2546	0.2546	0.2546	0.2548	0.2536	0.2537
			15%	0.2468	0.2659	0.2660	0.2660	0.2660	0.2657	0.2658
			20%	0.2468	0.2752	0.2753	0.2753	0.2753	0.2757	0.2757
			25%	0.2857	0.2835	0.2836	0.2836	0.2835	0.2843	0.2844
			30%	0.2857	0.2912	0.2912	0.2912	0.2911	0.2923	0.2923
			35%	0.2857	0.2984	0.2985	0.2985	0.2983	0.2998	0.2998
			40%	0.2857	0.3055	0.3056	0.3056	0.3053	0.3071	0.3071
			45%	0.3247	0.3125	0.3126	0.3126	0.3123	0.3142	0.3142
			50%	0.3247	0.3196	0.3196	0.3196	0.3193	0.3213	0.3213
			55%	0.3247	0.3268	0.3268	0.3268	0.3265	0.3285	0.3285
			60%	0.3506	0.3343	0.3343	0.3343	0.3340	0.3360	0.3360
			65%	0.3506	0.3423	0.3422	0.3422	0.3419	0.3438	0.3438
			70%	0.3506	0.3508	0.3508	0.3508	0.3505	0.3522	0.3521
			75%	0.3506	0.3603	0.3602	0.3602	0.3600	0.3613	0.3613
			80%	0.3506	0.3712	0.3711	0.3711	0.3709	0.3717	0.3717
			85%	0.4156	0.3842	0.3841	0.3841	0.3841	0.3841	0.3841
			90%	0.4156	0.4012	0.4012	0.4012	0.4014	0.4000	0.4000
			95%	0.4156	0.4278	0.4279	0.4279	0.4286	0.4245	0.4244

Figure 10 Reactive plant – fault non-continuous distribution comparison using A-D




Table 10 Reactive plant – fault non-continuous distribution statistics table for A-D

Fit Ranking	Fit	Function	Input	LogLogistic	InvGauss	Lognorm	Lognorm2	Pearson6	Erlang	
	A-D									
		Function	=RiskLogLo..	=RiskInvGa..	=RiskLogno..	=RiskLogno..	=RiskPears..	=RiskErlang..		
		- Distribution Statistics								
		Minimum	0.2468	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
		Maximum	0.4156	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	
		Mean	0.3247	0.3258	0.3247	0.3247	0.3247	0.3247	0.3247	
		Mode	0.2510 [est]	0.3126	0.3095	0.3097	0.3097	0.3090	0.3145	
		Median	0.3247	0.3197	0.3196	0.3196	0.3196	0.3193	0.3213	
		Std. Deviation	0.0643	0.0643	0.0580	0.0580	0.0580	0.0583	0.0574	
		Skewness	0.3711	1.0065	0.5355	0.5420	0.5420	0.5822	0.3536	
		Kurtosis	2.9009	6.8954	3.4780	3.5268	3.5268	3.6374	3.1875	
		- Percentiles								
		5%	0.2468	0.2338	0.2389	0.2387	0.2387	0.2391	0.2364	
		10%	0.2468	0.2531	0.2546	0.2546	0.2546	0.2548	0.2536	
		15%	0.2468	0.2659	0.2659	0.2660	0.2660	0.2660	0.2657	
		20%	0.2468	0.2759	0.2752	0.2753	0.2753	0.2753	0.2757	
		25%	0.2857	0.2845	0.2835	0.2836	0.2836	0.2835	0.2843	
		30%	0.2857	0.2922	0.2912	0.2912	0.2912	0.2911	0.2923	
		35%	0.2857	0.2994	0.2984	0.2985	0.2985	0.2983	0.2998	
		40%	0.2857	0.3062	0.3055	0.3056	0.3056	0.3053	0.3071	
		45%	0.3247	0.3130	0.3125	0.3126	0.3126	0.3123	0.3142	
		50%	0.3247	0.3197	0.3196	0.3196	0.3196	0.3193	0.3213	
		55%	0.3247	0.3266	0.3268	0.3268	0.3268	0.3265	0.3285	
		60%	0.3506	0.3338	0.3343	0.3343	0.3343	0.3340	0.3360	
		65%	0.3506	0.3415	0.3423	0.3422	0.3422	0.3419	0.3438	
		70%	0.3506	0.3499	0.3508	0.3508	0.3508	0.3505	0.3522	
		75%	0.3506	0.3594	0.3603	0.3602	0.3602	0.3600	0.3613	
		80%	0.3506	0.3705	0.3712	0.3711	0.3711	0.3709	0.3717	
		85%	0.4156	0.3845	0.3842	0.3841	0.3841	0.3841	0.3841	
		90%	0.4156	0.4039	0.4012	0.4012	0.4012	0.4014	0.4001	
		95%	0.4156	0.4373	0.4278	0.4279	0.4279	0.4286	0.4245	

Reactive plant outage rate – forced outage performance

Reactive plant forced unavailability data has a high representation in the middle and right tail of the distribution. The best fit distribution curve for both the K-S and A-D fit statistics is the Rayleigh distribution curve (figures 11 and 12), giving a standard deviation of 0.076.

Tables 11 and 12 are provided to show the variation in fit statistics of other distribution curves. The standard deviation for the curve of second best fit (Erlang) at 0.074 is not materially different.

Figure 11 Reactive plant – forced non-continuous distribution comparison using K-S




Table 11 Reactive plant – forced non-continuous distribution statistics table for K-S

Fit Ranking	Fit	K-S	Input	Rayleigh	Weibull	Uniform	Erlang	LogLogistic	Gamma	
	Function		=RiskRaylei...	=RiskWeibu...	=RiskUnifor...	=RiskErlang...	=RiskLogLo...	=RiskGamm...		
	Distribution Statistics									
	Minimum		0.0649	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	Maximum		0.2468	+Infinity	+Infinity	0.3084	+Infinity	+Infinity	+Infinity	
	Mean		0.1481	0.1448	0.1489	0.1542	0.1481	0.1556	0.1481	
	Mode		0.0695 [est]	0.1155	0.1325	0.0000	0.1110	0.1086	0.1142	
	Median		0.1299	0.1360	0.1437	0.1542	0.1359	0.1323	0.1369	
	Std. Deviation		0.0772	0.0757	0.0675	0.0890	0.0740	0.1106	0.0708	
	Skewness		0.3700	0.6311	0.4323	0.0000	1.0000	14.8754	0.9562	
	Kurtosis		0.6587	3.2451	2.9378	1.8000	4.5000	+Infinity	4.3715	
	Percentiles									
	5%		0.0649	0.0370	0.0473	0.0154	0.0506	0.0532	0.0537	
	10%		0.0649	0.0530	0.0643	0.0308	0.0646	0.0671	0.0676	
	15%		0.0649	0.0659	0.0774	0.0463	0.0755	0.0774	0.0783	
	20%		0.0649	0.0772	0.0886	0.0617	0.0850	0.0862	0.0877	
	25%		0.0909	0.0876	0.0987	0.0771	0.0938	0.0942	0.0963	
	30%		0.0909	0.0976	0.1082	0.0925	0.1023	0.1018	0.1045	
	35%		0.0909	0.1072	0.1173	0.1080	0.1106	0.1092	0.1125	
	40%		0.0909	0.1167	0.1261	0.1234	0.1189	0.1167	0.1205	
	45%		0.1299	0.1263	0.1349	0.1388	0.1273	0.1243	0.1286	
	50%		0.1299	0.1360	0.1437	0.1542	0.1359	0.1323	0.1369	
	55%		0.1299	0.1460	0.1526	0.1696	0.1450	0.1407	0.1456	
	60%		0.2078	0.1564	0.1619	0.1851	0.1545	0.1499	0.1548	
	65%		0.2078	0.1674	0.1715	0.2005	0.1649	0.1601	0.1647	
	70%		0.2078	0.1792	0.1818	0.2159	0.1763	0.1718	0.1755	
	75%		0.2078	0.1923	0.1931	0.2313	0.1891	0.1857	0.1878	
	80%		0.2078	0.2072	0.2058	0.2468	0.2041	0.2030	0.2020	
	85%		0.2468	0.2250	0.2208	0.2622	0.2226	0.2260	0.2195	
	90%		0.2468	0.2479	0.2398	0.2776	0.2473	0.2608	0.2429	
	95%		0.2468	0.2827	0.2683	0.2930	0.2870	0.3285	0.2803	

Figure 12 Reactive plant – forced non-continuous distribution comparison using A-D




Table 12 Reactive plant – forced non-continuous distribution statistics table for A-D

Fit	Fit Ranking	Function	Input	Rayleigh	Erlang	LogLogistic	Invgauss	Lognorm	Lognorm2
Erlang	0.2296								
LogLogistic	0.2341								
Invgauss	0.2477								
Lognorm	0.2497								
Lognorm2	0.2497								
Pearson5	0.2510								
Gamma	0.2568								
Weibull	0.2672								
Uniform	0.3190								
Expon	0.6857								
Pareto2	0.6857								
ChiSq	2.1240								
Triang	+Infinity								
BetaGeneral	N/A								
Pareto	N/A								
Pearson6	N/A								

Transformers outage rate – fault performance

The best fitting curve for Transformers unavailability caused by fault using the K-S fit statistic is the Pearson5 distribution (figure 13) curve while the A-D fit statistic has the LogLogistic distribution curve as the best fit (figure 14). As the data for Transformers unavailability caused by fault data is concentrated in the middle of the distribution, the K-S fit statistic (Pearson5) is preferred giving a standard deviation of 0.085.

Tables 13 and 14 show the difference in how the K-S and A-D fit statistics rated the distribution curves according their goodness of fit to the data range. The standard deviation for the curve of second best fit (Triang) is lower at 0.069, and for LogLogistic is similar at 0.089.

Figure 13 Transformers – fault non-continuous distribution comparison using K-S




Table 13 Transformers – fault non-continuous distribution statistics table for K-S

Fit Ranking	Fit	K-S	Function	Input	Pearson5	Triang	InvGauss	Lognorm	Lognorm2	Pearson6
			- Distribution Statistics							
			Minimum	0.0769	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
			Maximum	0.2759	+Infinity	0.3334	+Infinity	+Infinity	+Infinity	+Infinity
			Mean	0.1607	0.1628	0.1532	0.1607	0.1610	0.1610	0.1611
			Mode	0.0819 [est]	0.1138	0.1261	0.1196	0.1219	0.1219	0.1229
			Median	0.1316	0.1422	0.1475	0.1463	0.1467	0.1467	0.1468
			Std. Deviation	0.0765	0.0854	0.0687	0.0719	0.0726	0.0726	0.0733
			Skewness	0.8432	2.8918	0.2305	1.3421	1.4454	1.4454	1.5405
			Kurtosis	3.3453	26.8605	2.4000	6.0022	6.9311	6.9311	7.8496
			- Percentiles							
			5%	0.0769	0.0753	0.0458	0.0728	0.0723	0.0723	0.0721
			10%	0.0769	0.0857	0.0648	0.0845	0.0845	0.0845	0.0845
			15%	0.0769	0.0938	0.0794	0.0937	0.0939	0.0939	0.0941
			20%	0.0769	0.1010	0.0917	0.1017	0.1021	0.1021	0.1023
			25%	0.1261	0.1077	0.1025	0.1092	0.1098	0.1098	0.1100
			30%	0.1261	0.1144	0.1123	0.1165	0.1171	0.1171	0.1173
			35%	0.1261	0.1210	0.1213	0.1237	0.1243	0.1243	0.1245
			40%	0.1261	0.1278	0.1297	0.1310	0.1316	0.1316	0.1317
			45%	0.1316	0.1348	0.1384	0.1385	0.1390	0.1390	0.1391
			50%	0.1316	0.1422	0.1475	0.1463	0.1467	0.1467	0.1468
			55%	0.1316	0.1503	0.1570	0.1545	0.1549	0.1549	0.1549
			60%	0.1933	0.1590	0.1671	0.1634	0.1636	0.1636	0.1636
			65%	0.1933	0.1688	0.1779	0.1731	0.1732	0.1732	0.1731
			70%	0.1933	0.1800	0.1894	0.1840	0.1839	0.1839	0.1837
			75%	0.1933	0.1931	0.2019	0.1964	0.1962	0.1962	0.1959
			80%	0.1933	0.2093	0.2158	0.2112	0.2108	0.2108	0.2105
			85%	0.2759	0.2306	0.2316	0.2298	0.2292	0.2292	0.2289
			90%	0.2759	0.2614	0.2503	0.2553	0.2547	0.2547	0.2545
			95%	0.2759	0.3177	0.2746	0.2979	0.2979	0.2979	0.2982

Figure 14 Transformers – fault non-continuous distribution comparison using A-D




Table 14 Transformers – fault non-continuous distribution statistics table for A-D

Fit	A-D	Function	=RiskLogLo..	=RiskInvGa..	=RiskLogno..	=RiskLogno..	=RiskPears..	=RiskPears..
InvGauss	0.2222	Minimum	0.0769	0.0000	0.0000	0.0000	0.0000	0.0000
Lognorm	0.2224	Maximum	0.2759	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
Lognorm2	0.2224	Mean	0.1607	0.1635	0.1607	0.1610	0.1610	0.1628
Pearson6	0.2226	Mode	0.0819 [est]	0.1279	0.1196	0.1219	0.1229	0.1138
Pearson5	0.2305	Median	0.1316	0.1464	0.1463	0.1467	0.1468	0.1422
Gamma	0.2317	Std. Deviation	0.0765	0.0885	0.0719	0.0726	0.0726	0.0733
Rayleigh	0.2464	Skewness	0.8432	-4.6772	1.3421	1.4454	1.4454	1.5405
Erlang	0.2498	Kurtosis	3.3453	+Infinity	6.0022	6.9311	6.9311	7.8496
Triang	0.2514	Percentiles						
Weibull	0.2521	5%	0.0769	0.0688	0.0728	0.0723	0.0723	0.0721
BetaGeneral	0.3390	10%	0.0769	0.0833	0.0845	0.0845	0.0845	0.0857
Uniform	0.4665	15%	0.0769	0.0938	0.0937	0.0939	0.0939	0.0938
Expon	0.8404	20%	0.0769	0.1026	0.1017	0.1021	0.1021	0.1010
ChiSq	2.0761	25%	0.1261	0.1104	0.1092	0.1098	0.1098	0.1100
Pareto	N/A	30%	0.1261	0.1178	0.1165	0.1171	0.1171	0.1173
Pareto2	N/A	35%	0.1261	0.1249	0.1237	0.1243	0.1243	0.1245
		40%	0.1261	0.1319	0.1310	0.1316	0.1316	0.1317
		45%	0.1316	0.1390	0.1385	0.1390	0.1390	0.1391
		50%	0.1316	0.1464	0.1463	0.1467	0.1467	0.1468
		55%	0.1316	0.1541	0.1545	0.1549	0.1549	0.1503
		60%	0.1933	0.1624	0.1634	0.1636	0.1636	0.1590
		65%	0.1933	0.1716	0.1731	0.1732	0.1732	0.1731
		70%	0.1933	0.1819	0.1840	0.1839	0.1839	0.1837
		75%	0.1933	0.1941	0.1964	0.1962	0.1962	0.1959
		80%	0.1933	0.2089	0.2112	0.2108	0.2108	0.2105
		85%	0.2759	0.2285	0.2298	0.2292	0.2292	0.2289
		90%	0.2759	0.2573	0.2553	0.2547	0.2547	0.2545
		95%	0.2759	0.3116	0.2979	0.2979	0.2979	0.2982

Transformers outage rate – forced outage performance

The data for forced unavailability of transformers is best fitted with a BetaGeneral distribution curve (figure 15) according to the K-S fit statistic. The A-D fit statistic has the Weibull distribution curve as the best fit (figure 16). As the data is distributed across both the middle and tails of the distribution, the A-D fit statistic is preferred (Weibull), giving a standard deviation of 0.034.

Tables 15 and 16 presents the variation in the distribution curve statistics between K-S and A-D fit statistics. The standard deviation for the curve of second best fit (Gama) is higher at 0.045 and for BetaGeneral is similar at 0.038.

Figure 15 Transformers – forced non-continuous distribution comparison using K-S




Table 15 Transformers – forced non-continuous distribution statistics table for K-S

Fit Ranking	Fit	K-S	Input	BetaGeneral	Rayleigh	Lognorm	Lognorm2	Pearson5	Gamma
	Rayleigh	0.3242							
	Lognorm	0.3246							
	Lognorm2	0.3246							
	Pearson5	0.3251							
	Gamma	0.3269							
	Erlang	0.3272							
	InvGauss	0.3335							
	Weibull	0.3345							
	Uniform	0.3427							
	Expon	0.3847							
	Triang	0.4476							
	ChiSq	0.6936							
	LogLogistic	N/A							
	Pareto	N/A							
	Pareto2	N/A							
	Pearson6	N/A							

Function	=RiskBetaG..	=RiskRaylei..	=RiskLogno..	=RiskLogno..	=RiskPears..	=RiskGamm..
Minimum	0.0504	0.0000	0.0000	0.0000	0.0000	0.0000
Maximum	0.1552	0.1552	+Infinity	+Infinity	+Infinity	+Infinity
Mean	0.1198	0.1221	0.1116	0.1215	0.1215	0.1198
Mode	0.0530 [est]	0.1552	0.0890	0.0935	0.0935	0.1026
Median	0.1429	0.1386	0.1046	0.1113	0.1113	0.1076
Std. Deviation	0.0432	0.0383	0.0583	0.0531	0.0531	0.0705
Skewness	-1.3663	-1.2404	0.6311	1.3945	1.3945	3.3120
Kurtosis	-4.1651	3.5586	3.2451	6.6461	6.6461	39.1476

Percentiles	Input	BetaGeneral	Rayleigh	Lognorm	Lognorm2	Pearson5	Gamma
5%	0.0504	0.0380	0.0285	0.0560	0.0560	0.0554	0.0561
10%	0.0504	0.0598	0.0409	0.0651	0.0651	0.0633	0.0666
15%	0.0504	0.0767	0.0507	0.0722	0.0722	0.0696	0.0743
20%	0.0504	0.0906	0.0595	0.0783	0.0783	0.0751	0.0809
25%	0.1053	0.1022	0.0675	0.0840	0.0840	0.0804	0.0869
30%	0.1053	0.1121	0.0752	0.0894	0.0894	0.0856	0.0925
35%	0.1053	0.1204	0.0826	0.0948	0.0948	0.0908	0.0980
40%	0.1053	0.1275	0.0900	0.1001	0.1001	0.0961	0.1033
45%	0.1429	0.1335	0.0973	0.1056	0.1056	0.1017	0.1087
50%	0.1429	0.1386	0.1046	0.1113	0.1113	0.1076	0.1141
55%	0.1429	0.1428	0.1125	0.1173	0.1173	0.1139	0.1198
60%	0.1453	0.1462	0.1205	0.1238	0.1238	0.1209	0.1257
65%	0.1453	0.1489	0.1290	0.1308	0.1308	0.1288	0.1320
70%	0.1453	0.1511	0.1381	0.1386	0.1386	0.1378	0.1388
75%	0.1453	0.1527	0.1482	0.1476	0.1476	0.1484	0.1465
80%	0.1453	0.1538	0.1597	0.1583	0.1583	0.1616	0.1554
85%	0.1552	0.1545	0.1734	0.1717	0.1717	0.1790	0.1662
90%	0.1552	0.1550	0.1910	0.1902	0.1902	0.2044	0.1804
95%	0.1552	0.1551	0.2179	0.2214	0.2214	0.2515	0.2029

Figure 16 Transformers – forced non-continuous distribution comparison using A-D




Table 16 Transformers – forced non-continuous distribution statistics table for A-D

Fit Ranking		Fit	Input	Weibull	Gamma	Erlang	Rayleigh	Lognorm	Lognorm2
Fit	A-D	Function	=RiskWeibu..	=RiskGamm..	=RiskErlang..	=RiskRaylei..	=RiskLogno..	=RiskLogno..	
- Distribution Statistics									
		Minimum	0.0504	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
		Maximum	0.1552	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity	+Infinity
		Mean	0.1198	0.1203	0.1198	0.1198	0.1116	0.1215	0.1215
		Mode	0.0530 [est]	0.1233	0.1026	0.1027	0.0890	0.0935	0.0935
		Median	0.1429	0.1210	0.1141	0.1141	0.1048	0.1113	0.1113
		Std. Deviation	0.0432	0.0344	0.0454	0.0453	0.0583	0.0531	0.0531
		Skewness	-1.3663	-0.0700	0.7575	0.7559	0.6311	1.3945	1.3945
		Kurtosis	4.1651	2.7396	3.8607	3.8571	3.2451	6.6461	6.6461
- Percentiles									
		5%	0.0504	0.0623	0.0561	0.0562	0.0285	0.0560	0.0560
		10%	0.0504	0.0748	0.0666	0.0667	0.0409	0.0651	0.0651
		15%	0.0504	0.0836	0.0743	0.0744	0.0507	0.0722	0.0722
		20%	0.0504	0.0906	0.0809	0.0810	0.0595	0.0783	0.0783
		25%	0.1053	0.0967	0.0869	0.0870	0.0675	0.0840	0.0840
		30%	0.1053	0.1022	0.0925	0.0926	0.0752	0.0894	0.0894
		35%	0.1053	0.1072	0.0980	0.0980	0.0826	0.0948	0.0948
		40%	0.1053	0.1120	0.1033	0.1034	0.0900	0.1001	0.1001
		45%	0.1429	0.1166	0.1087	0.1087	0.0973	0.1056	0.1056
		50%	0.1429	0.1210	0.1141	0.1141	0.1048	0.1113	0.1113
		55%	0.1429	0.1255	0.1198	0.1198	0.1125	0.1173	0.1173
		60%	0.1453	0.1300	0.1257	0.1257	0.1205	0.1238	0.1238
		65%	0.1453	0.1346	0.1320	0.1320	0.1290	0.1308	0.1308
		70%	0.1453	0.1394	0.1388	0.1388	0.1381	0.1386	0.1386
		75%	0.1453	0.1445	0.1465	0.1465	0.1482	0.1476	0.1476
		80%	0.1453	0.1501	0.1554	0.1553	0.1597	0.1583	0.1583
		85%	0.1552	0.1565	0.1662	0.1661	0.1734	0.1717	0.1717
		90%	0.1552	0.1645	0.1804	0.1803	0.1910	0.1902	0.1902
		95%	0.1552	0.1759	0.2029	0.2027	0.2179	0.2214	0.2214

3. Summary of findings

Table 17 summarises the probability distribution functions that have been chosen to best fit the parameter data (table 18). In Parsons Brinckerhoff’s view this approach is robust and does not seem to be sensitive to the choice of distribution function, because the results were close for the next best fit distributions. The approach is also consistent with the Australian Energy Regulator’s previous regulatory decisions to use a curve of best fit approach.

Table 17 Summary of best fit distributions

Parameter	Best fit distribution	Standard Deviation
Average outage duration	Exponential	97.96
No. of events >0.05 system minutes	NegBin	2.000
No. of events >0.30 system minutes	IntUniform	0.816
Lines outage rate - fault	LogLogistic	0.090
Lines outage rate - forced outage	Pearson5	0.017
Reactive plant outage rate - fault	LogLogistic	0.064
Reactive plant outage rate - forced outage	Rayleigh	0.076
Transformers outage rate - fault	Pearson5	0.085
Transformers outage rate - forced outage	Weibull	0.034

Table 18 Reliability Data 2008-2012

Parameter	2008	2009	2010	2011	2012
Average outage duration	71.5	91.8	92.5	4.0	230.0
No. of events >0.05 system minutes	1	6	1	0	2
No. of events >0.30 system minutes	1	2	0	0	1
Lines outage rate - fault	20.0%	35.8%	16.8%	24.4%	32.5%
Lines outage rate - forced outage	16.7%	12.5%	14.3%	16.8%	14.2%
Reactive plant outage rate - fault	28.6%	35.1%	24.7%	32.5%	41.6%
Reactive plant outage rate - forced outage	6.5%	9.1%	13.0%	24.7%	20.8%
Transformers outage rate - fault	13.2%	27.6%	7.7%	12.6%	19.3%
Transformers outage rate - forced outage	10.5%	15.5%	14.5%	5.0%	14.3%