



Network Development Management Plan

Version Number: 2.0

Date: October 2017

Authorisations

| Action | Name and title | Date |
|---------------|------------------------------|----------|
| Prepared by | Network Planning | 5/10/15 |
| Authorised by | Network Planning Team Leader | 27/10/17 |
| Review cycle | 2.5 Years | |

Responsibilities

This document is the responsibility of the Network Planning Team, Tasmanian Networks Pty Ltd, ABN 24 167 357 299 (hereafter referred to as "TasNetworks").

Please contact the Network Planning Leader with any queries or suggestions.

- Implementation All TasNetworks staff and contractors.
- Compliance All group managers.

© Tasmanian Networks Pty Ltd 2017

Disclaimer

This document is protected by copyright vested in Tasmanian Networks Pty Ltd (TasNetworks). No part of the document may be reproduced or transmitted in any form by any means including, without limitation, electronic, photocopying, recording or otherwise, without the prior written permission of TasNetworks. No information embodied in the document that is not already in the public domain shall be communicated in any manner whatsoever to any third party without the prior written consent of TasNetworks. Any breach of the above obligations may be restrained by legal proceedings seeking remedies including injunctions, damages and costs.

Record of revisions

| Section number | Details |
|----------------|---------------------------|
| 1.0 | For issue |
| 2.0 | Re-issued for Reset 19-24 |

Table of Contents

| | |
|--|----|
| Authorisations..... | 2 |
| 1 Purpose..... | 7 |
| 2 Scope | 7 |
| 3 Regulatory and Legislative Obligations | 7 |
| 4 Strategic Alignment and Objectives | 8 |
| 4.1 Asset Management Plans | 10 |
| 4.2 Area planning Strategies (Area Development plans) | 10 |
| 5 Support Systems and Applications..... | 11 |
| 5.1 Asset Management Information Systems | 11 |
| 5.2 Asset Information | 11 |
| 5.3 Asset Loading Information (Historian) Systems | 11 |
| 5.4 Tools and applications | 11 |
| 6 Demand forecasts | 12 |
| 7 Network Performance..... | 12 |
| 7.1 Service Target Performance Incentive Scheme | 12 |
| 7.2 Network performance management..... | 13 |
| 7.2.1 Prevent outages from occurring | 13 |
| 7.2.2 Minimise the number of customers affected | 13 |
| 7.2.3 Restoring supply as quickly as possible | 13 |
| 8 Reinforcement Drivers | 14 |
| 8.1 Security planning standards | 14 |
| 8.2 High Voltage feeder and reliability community performance..... | 14 |
| 8.3 Suboptimal sizing of transformers, cables and conductors | 15 |
| 8.4 Circuit(s) not rated for load distribution | 16 |
| 8.5 Switchgear not appropriate for task..... | 16 |
| 8.6 Changing the nominal system voltage..... | 16 |
| 8.7 Quality of supply issues | 16 |
| 9 Risk Based Management | 16 |
| 9.1 Risk Level Evaluation..... | 17 |
| 9.2 Risk Assessment & Treatment | 19 |
| 9.2.1 Identification | 19 |
| 9.2.2 Risk assessment..... | 19 |
| 9.2.3 Options and solutions..... | 19 |
| 9.2.4 Prioritisation and budget..... | 20 |
| 9.2.5 Business approvals | 20 |

| | |
|--|----|
| 9.2.6 Implementation..... | 20 |
| 9.2.7 Evaluation | 20 |
| 10 Management Plan | 20 |
| 10.1 Network Planning Levels..... | 20 |
| 10.1.1 Major System..... | 21 |
| 10.1.2 High Voltage System | 21 |
| 10.1.3 Low Voltage System..... | 23 |
| 10.2 Reinforcement Strategy | 23 |
| 10.3 Guiding principles | 23 |
| 11 CAPEX Programs 2019-24..... | 25 |
| 11.1 Major System | 25 |
| 11.1.1 Zone Substations (CAZNC) | 25 |
| 11.1.2 Strategic Acquisition of Land (LANDZ) | 25 |
| 11.1.3 Sub-transmission Circuits (CAZNC) | 26 |
| 11.2 High Voltage System | 26 |
| 11.2.1 Derwent Bridge 22 kV supply development (CAHVF) | 26 |
| 11.2.2 East Coast South supply Development (CAHVF) | 27 |
| 11.2.3 Meadowbank 22 kV supply development (CAHVF)..... | 27 |
| 11.2.4 Hobart CBD 11 kV supply development (CAHVF) | 28 |
| 11.2.5 Sheffield 22 kV supply development (PRHVF) | 29 |
| 11.2.6 Westbury Urban community reliability improvement (PRHVR) | 29 |
| 11.2.7 Install/Augment Voltage Regulator for Capacity (CAHVF) | 29 |
| 11.2.8 Augment HV GI Feeder - Capacity (CAHVF)..... | 30 |
| 11.2.9 Augment HV Feeder and Control Stations - Fault Level (CAHVF)..... | 30 |
| 11.2.10 Augment HV Feeder - Network access development (CAHVF) | 31 |
| 11.2.11 Augment HV Feeder - Trip P (PRHVR)..... | 31 |
| 11.2.12 Augment HV Feeder for Reliability - Trip S (PRHVR) | 31 |
| 11.2.13 Installation of HV and LV conduit with other underground works | 31 |
| 11.3 Low Voltage System..... | 32 |
| 11.3.1 Distribution substations (CATXU) | 32 |
| 11.3.2 Augment Low Voltage Feeders for Capacity (CALVF) | 32 |
| 11.3.3 Local Reliability (PRTXI, PRHOS, PRSPT) | 32 |
| 11.4 OPEX Programs 2019/20-2023/24..... | 33 |
| 12 Financial Summary | 33 |
| 12.1 Proposed CAPEX Expenditure | 33 |
| 12.2 System Development..... | 33 |

12.3 Reliability..... 33

Appendix A: TasNetworks demand forecast methodology 34

12.4 Linear regression methodology 34

12.5 Temperature correction 34

12.6 Embedded generation 34

1 Purpose

The purpose of this document is to define the management strategy for distribution network development. The plan provides:

- TasNetworks' approach to demand, performance, and network operability driven reinforcement strategies, as reflected through its legislative and regulatory obligations and strategic plans;
- The key projects and programs underpinning its activities; and

2 Scope

This management plan includes reinforcement programs and expenditure profiles associated with distribution assets and elements operating at 44 kV, 33 kV, 22 kV, 11 kV, SWER voltages, and 400/230 V; namely, the Distribution Network.

This management plan has been developed in conjunction with TasNetworks' suite of asset management plans and area strategy reports, with the objective of managing network capacity and performance levels through the planning period to 2028/29 in accordance with TasNetworks asset management objectives.

This management plan identifies the issues and strategies relating to distribution assets and supply arrangements, and details the specific activities, and associated reinforcement expenditure profiles that need to be undertaken to address the identified issues, whilst ensuring the network evolves in an economically optimal way to sustainably meet our customer's needs.

This document excludes:

- Customer development works e.g. new or modified connections to the distribution network;
- Non-demand related customer activity e.g. asset removal and relocations as requested by customers or third parties (local councils, planning authorities, etc.);
- Renewal and preventative maintenance programs;
- Demand management development e.g. network support trials or development; and
- Power Quality rectification works.

3 Regulatory and Legislative Obligations

The Tasmanian electricity supply industry operates under both state and national regulatory regimes. TasNetworks, being a participant in the NEM, is required to develop, operate and maintain the transmission and distribution system in accordance with the National Electricity Rules (NER) and other local requirements under the terms of our licences issued by the Tasmanian Economic Regulator in accordance with the Tasmanian Electricity Supply Industry Act 1995.

Network development (reinforcement) expenditure is associated with the construction (extension and augmentation) of network assets in accordance with our asset management plans, area strategy reports, network performance targets and obligations, and planning principles, to ensure that the distribution network delivers:

- Compliance with regulatory obligations; and
- Safety, operational efficiency, reliability and security of supply outcomes that meet customers' needs, by maintaining asset utilisation rates at appropriate levels at the lowest whole of life cost.

If inadequate reinforcement work is undertaken then, as demand, generation, and adverse weather events increase, customers may face increased risk of load shedding, asset failure or service performance and quality of supply issues.

As a joint transmission and distribution network service provider, network development strategies in the distribution network also consider TasNetworks' regulatory obligations for transmission network planning. The regulations which are relevant to transmission and distribution network planning and development are:


- the National Electricity Rules (NER). These rules stipulate the requirements surrounding the electrical performance of the network. Of particular relevance to the distribution network is the Service Target Performance Incentive Scheme (STPIS);
- The NER (specifically Chapter 5 and 5.1) also stipulates our obligations for encouraging and managing new and modified customer connection services to the transmission and distribution networks;
- the *Electricity Supply Industry (Network Planning Requirements) Regulations 2007* (ESI) – (Note: not applicable to the distribution network). The ESI regulations define the minimum criteria for network performance following contingency events on the transmission network; and
- guidelines and standards applicable to the electricity industry as per the Tasmanian Electricity Code (TEC). The TEC contains arrangements for the regulation of the Tasmanian electricity supply industry which are not covered by the NER and are largely related to the distribution network. Of particular interest to network planning are the reliability requirements which outline the acceptable levels of reliability for various classifications of Tasmanian communities. Any excursions outside these requirements result in Guaranteed Service Level (GSL) payments to the impacted customers.

4 Strategic Alignment and Objectives

The business plan is the annual roadmap to support our corporate plan. It identifies responsibilities for the completion of initiatives identified in TasNetworks' corporate plan. The intent is to bring focus on priority initiatives that must be delivered to transform our business and achieve our strategic goals, whilst continuing to operate our business and achieve our targets.

Table 1 represents TasNetworks' documents that support the asset management framework. The diagram highlights the links to from the business and corporate plans, and the existence of, and interdependence between, the Plan, Do, Check, Act components of good asset management practice.

Figure 1 – TasNetworks asset management documentation framework



* The Annual Planning Report (APR) is a requirement of sections 5.12.2 and 5.13.2 of the National Electricity Rules (NER) and also satisfies a licence obligation to publish a Tasmanian Annual Planning Statement (TAPS). The APR is a compilation of information from the Area Development Plans and the Asset Management Plans.

The Network Development management plan has been developed to align with both TasNetworks' Asset Management Policy and Strategic Objectives. This management plan describes the network management strategies and programs developed to manage the distribution protection, control and related assets with the aim of achieving these objectives.

For these assets the management strategy focuses on the following objectives:

- Safety will continue to be our top priority and we will continue to ensure that our safety performance continues to improve
- Service performance will be maintained at current overall network service levels, whilst service to poorly performing reliability communities will be improved to meet regulatory requirements
- Cost performance will be improved through prioritisation and efficiency improvements that enable us provide predictable and lowest sustainable pricing to our customers
- Customer engagement will be improved to ensure that we understand customer needs, and incorporate these into our decision making to maximise value to them
- Our program of work will be developed and delivered on time and within budget

4.1 Asset Management Plans

The suite of asset management plans have been developed to align with both TasNetworks' Asset Management Policy and Strategic Objectives.

The asset management policy, contained within the Strategic Asset Management Plan, states 'Consistent with our vision and purpose, we strive for excellence in asset management and are committed to providing a safe working environment, value for our customers, sustainable shareholder outcomes, care for our assets and the environment, safe and reliable network services, whilst effectively and efficiently managing our assets throughout their life-cycle'.

It is part of a suite of documentation that supports the achievement of TasNetworks strategic performance objectives and, in turn, its mission. The asset management plans identifies the issues and strategies relating to network system assets and detail the specific activities that need to be undertaken to address the identified issues.

4.2 Area planning Strategies (Area Development plans)

For planning purpose, the transmission and distribution networks are managed as eight planning areas. An Area planning strategy exists for each planning area, which are used to capture and summarise location specific network information, demand forecasts, and emerging issues. These reports are used to develop our combined transmission and distribution Annual Planning Report.

The Area planning strategies contribute to the asset management objectives by building understanding, capabilities and strategies to realise early opportunities, whilst delivering safe and reliable network services. We do this to meet our customers' needs and the Rules requirements. The Area Strategy reports form a part of the end to end works program process, which identify the need, timing and opportunity, in early parts of planning and network development.

5 Support Systems and Applications

5.1 Asset Management Information Systems

TasNetworks utilises Asset Management Information Systems, which are maintained to contain up to date, detailed information with regard to assist network development planning and works.

The network asset information is managed using a spatial data warehouse (G/Tech). This data base stores critical attributes for each asset and element, including the location, construction, rating, and its interconnection to the network.

A works management system (WASP) is used to manage network development activities and for the recording of asset performance.

These systems are in the process of migration to SAP (Systems, Applications, and Products) as part of our business wide Ajilis project.

5.2 Asset Information

Asset related information is stored and accessed through the asset management systems. Where asset information is insufficient audits are undertaken to gather the information.

5.3 Asset Loading Information (Historian) Systems

TasNetworks utilises Asset Loading Information Systems, which are maintained to store historical system loading data at different network levels. This data is used for a range of network analysis and network development planning activities.

The network asset loading information is managed by the NOCS team, and made available through PI historian.

5.4 Tools and applications

TasNetworks utilises a range of applications for analysis of the distribution network to identify and evaluate network development related risk. The primary applications for distribution network analysis used by TasNetworks are:

- Siemens PSS SINCAL 10.5.
- GeoMedia;
- Cymcap – cable loading assessment software
- TasNetworks Economic Evaluation Tool

6 Demand forecasts

The demand forecasts are an essential input to identify emerging demand related issues (capacity constraints) or opportunities (asset rationalisation/retirement) and develop early strategies to address them.

TasNetworks in its role as the jurisdictional network planner for the Tasmanian transmission and distribution networks has compiled its own maximum demand forecasts at different network levels (transmission and distribution) based on a regional demand forecast for Tasmania produced by the National Institute of Economic and Industry Research (NIEIR). These forecasts are used for planning studies and project development. An overview of the forecasting methodology is provided in Appendix B.

Similarly the Australian Energy Market Operator (AEMO) in its role as an independent energy markets and power systems operator produce a regional forecast for Tasmania, and connection point maximum demand forecasts for Tasmanian transmission network. AEMO's forecasts are used by the Australian Energy Regulator (AER) in their evaluation of TasNetworks revenue determination.

Both forecasts by TasNetworks and AEMO show flat or small growth or decline across the Tasmanian connection points. The differences are marginal, and have a negligible impact on capacity constraints being brought forward or deferred within the planning horizon.

Our program was initially developed using TasNetworks connection point forecast. Subsequently we have adopted to use AEMOs 2017 Connection Point forecast to:

- finalise our 2019-29 augmentation programs, and to
- develop our latest suite of long term transmission development plans detailed in our eight Area planning strategy reports.

AEMO will be developing their 2018 Connection Point forecast in December 2017 prior to TasNetworks revenue reset submission. Although we will review any changes in the forecasts, we expect minimal impacts on our proposed demand driven expenditure forecasts.

7 Network Performance

7.1 Service Target Performance Incentive Scheme

TasNetworks' Service Target Performance Incentive Scheme (STPIS), which meets the requirements of the Australian Energy Regulator's (AER's) Service Standards Guideline, imposes service performance measures and targets onto TasNetworks with a focus on outage duration and frequency. Good asset performance will have a significant impact on TasNetworks' ability to meet the STPIS targets.

STPIS parameters include:

- System Average Interruption Duration Index (SAIDI); and
- System Average Interruption Frequency Index (SAIFI).

Details of the STPIS scheme and performance targets can be found in the *"Electricity distribution network service providers - Service target performance incentive scheme - November 2009"*.

7.2 Network performance management

A fundamental requirement of the operation of the distribution network is to ensure that a reasonable level of supply reliability is delivered to its customers. The expectation of a reasonable level of supply reliability has been defined in the Tasmanian Electricity Code (TEC) in two parts:

- System level expectations of service measured by SAIDI and SAIFI; and
- Localised or community based expectations of SAIDI and SAIFI.

While TasNetworks operates an extensive program of maintenance and renewal activities across the network; reliability cannot be managed solely at an asset management level, but requires a holistic approach to ensure activities are collectively targeted towards system performance levels as stated in our key asset management objectives:

- Service performance will be maintained at current overall service levels, whilst service to poorly performing communities will be improved to meet regulatory requirements.

At a system level, TasNetworks strategy is based on three principles:

1. Prevent outages from occurring;
2. Minimise the number of customers affected; and
3. Restore supply as quickly as possible.

The follow sections provide more details on these principles.

7.2.1 Prevent outages from occurring

The most effective method of maintaining reliability is to address the root cause of network faults that can result in customer outages. By preventing the outages occurring in the first place, other mitigation measures are avoided. Maintenance and renewal activities are aligned to this objective

7.2.2 Minimise the number of customers affected

Despite measures to reduce the number of faults, outages will occur and impact customers. The next measure to achieving reliability performance targets is to use network configuration (feeders and interconnections) and protection design to minimise the number of customers affected when outages occur. This is achieved through reinforcement programs targeting the poor performing communities and worst performing feeders, by:

- Reducing feeder network area, and increasing/reinforcing network interconnections;
- Using appropriate electrical protection devices;
- Ensuring accurate protection co-ordination,

7.2.3 Restoring supply as quickly as possible

The third strategy to achieving reliability performance targets is to restore customers that have been affected by an outage as quickly as possible.

This requires Distribution Operations to have sufficient monitoring devices in the network to respond quickly and to target accurately field crews to the correct sites to expedite restoration.

It is also acknowledged that at a local level, parts of the network can be subject to varying levels of outages that are driven by a number of issues. To ensure local clusters of customers are not subjected to sustained substandard network performance, localised or targeted, activities are required to address these customer groups.

8 Reinforcement Drivers

TasNetworks' requirements for developing the distribution network are principally driven by six elements:

- Asset capability;
- New load and generation connection requests;
- Network access requirements;
- Demand forecasts (refer Section 0);
- Network performance requirements (refer TEC); and
- National electricity rules (NER) compliance.

These elements are used to guide network development strategies and ultimately reinforcement programs. The following sections provide details on more general considerations that drive network development programs.

8.1 Security planning standards

TasNetworks has well established security planning standards based on an n-1 philosophy for Major System infrastructure (refer Section 20), including zone substation assets and their sub-transmission feeders. This includes full firm and 'switched' firm arrangements where economical.

TasNetworks' zone substations are established where significant bulk load points exist and there is a need to further distribute the capacity requirements of customer loads at high voltage (HV). Zone substations are radially supplied by one to three, 33 kV (or 44 kV on the west coast) dedicated power-transformer-ended sub-transmission circuits. These sites are located in the Greater Hobart and Kingston South planning areas and supply large numbers of customers within reliability communities such as Critical Infrastructure – Hobart CBD, Hobart High Density Commercial, and Hobart and Kingston urban.

At the HV System planning level (refer Section 20), we develop our feeder networks with respect to interconnectivity, capacity and operability to meet jurisdictional reliability performance obligations, and provide adequate capability to manage network access maintaining adequate service outcomes to customers.

Whilst the majority of our HV System is rural, comprising of long feeder networks with minimal interconnection with neighbouring feeders, we have a number of highly interconnected networks such as the Hobart CBD, where higher levels of feeder security, redundancy and control is required to meet service performance outcomes.

Some HV customer connections in the distribution network have a similar n-1 supply arrangement i.e. a duplicate feeder supply. At the HV System planning level, this is considered a higher level of reliability that is generally required to meet community reliability service performance targets, and therefore generally the arrangement would be at the request of, and funded by those customers directly.

8.2 High Voltage feeder and reliability community performance

Distribution network reliability performance can be influenced by focusing on the controllable aspects of reliability:

- prevention;
- minimising customer impact; and

- reducing outage duration through effective planning and restoration.

The most effective method of managing reliability performance is to address the root cause of network faults that can result in customer outages, and to ensure planned outages are undertaken in an efficient manner. Despite our best endeavours, outages will occur on the distribution network due to forces largely outside of TasNetworks control such as storms, fauna and flora.

In this regard, network development reliability programs are associated with improving outage prevention and minimising outage durations through targeted augmentation projects; with the objective of meeting the service performance management strategy.

Network development strategies and associated augmentation programs aim to manage feeder and community performance issues through:

- effective network and asset designs;
- analysis of feeder and reliability area performance;
- implementation of innovative technology and other solutions for the improvement of network reliability;
- effective protection designs and coordination;
- effective isolation of faulted sections via network reconfiguration; and
- flexible and effective SCADA, remote control monitoring and distribution automation.

8.3 Suboptimal sizing of transformers, cables and conductors

HV and LV (including sub-transmission) cable and conductor assets are sized to manage:

- the network peak demand;
- the transfer capability between neighbouring network during planned and unplanned network reconfigurations;
- the system fault level;
- the voltage level (bandwidth) supplied to customers for variations in load due to daily and seasonal demand/generation changes, and load growth;
- the rapid changes in voltage level (transient) as a result of disturbing loads or transient load changes;
- Minimise network losses; and
- Cater for future growth.

These assets will have a set of thermal ratings or 'rated capacity' in terms of current (amps) that are determined based on various operating conditions, construction and manufacturers specification. The capacity ratings that are used in investigating risks and identifying and evaluating treatment options of the capability of assets is given in the following terms:

| | |
|------------------|---|
| Planning rating | A nominal rating based upon design ambient temperature, wind speed, insulation or nameplate rating. |
| Cyclic rating | Based upon core hot spot temperature not exceeding design criteria and thermal loading over a 24 hour period. |
| Nameplate rating | The rating identified upon the equipment nameplate for normal operation |

Generally:

- transformers will have a nameplate rating (manufacturers specification), and a normal cyclic rating;
- cables will have a nameplate rating (manufacturers specification), and a short term (1 hour) cyclic rating. Often the nameplate rating and planning rating are similar; and
- conductors will have seasonal planning ratings that are typical for standard pole top construction, taking standard height and clearances into account.
- These assets will also have a fault withstand rating, based on a range of operating conditions.

8.4 Circuit(s) not rated for load distribution

TasNetworks operates the HV and Low Voltage (LV) networks as three-phase networks, which also supply small two-phase and Single Wire Earth Return (SWER) systems. These systems are transitioned to three-phase networks in response to:

- load growth;
- excessive phase unbalance;
- power quality issues; and
- To meet community expectations (to facilitate economic development) where significant asset renewal programs are implemented

8.5 Switchgear not appropriate for task

As feeder configurations change over time, often switchgear requires upgrading to meet operational requirements, coordinate effectively, and maintain network performance. This can include:

- upgrading single phase operation to three-phase (ganged) operation;
- upgrading manually operated equipment to remote controlled devices; and
- upgrading protection devices to cater for load and growth.

8.6 Changing the nominal system voltage

Manage isolated, non-standard or suboptimal network voltages by migrating to more appropriate voltage levels i.e. migrating from 11 kV to 22 kV in regional areas.

8.7 Quality of supply issues

Quality of supply issues including voltage flicker and waveform distortion associated with electrical loading of the network are dealt with in the Power Quality Management Plan¹.

9 Risk Based Management

For network development related work there is a high correlation between creation and augmentation of network assets and the treatment of network risks. The following sections describe the main processes that are used to identify network development risks, methodologies that are used to address the higher risks and options that are undertaken to apply treatment.

¹ Refer R/299031

As each of the processes is targeted to each of the three levels of network management (refer Section 10.1) the risks may be similar but treatment is varied according to the elements addressed.

9.1 Risk Level Evaluation

Network risks associated with this management plan have been assessed, for the system as a whole, according to the TasNetworks Risk Management Framework Risk Rating Matrix².

The risk ratings used in the framework are:

- Low;
- Moderate;
- High; and
- Very High.

The application of TasNetworks Risk Management Framework portrays the level of risk associated with each of the three levels of network management should the risks go untreated.

Table 9-1: Network development risk assessment³

| Consequence category | Description | Evaluated risk at network planning level | | |
|--|---|--|-----------|-----------|
| | | Major System | HV System | LV System |
| Safety & People Human safety both public & internal: | Decreased operating clearances Increasing risk of third party contact Electric shock or electrocution Explosion, Physical damage or harm. | Medium | High | Medium |
| Environment & Community Environmental incidents: | Increased risk of conductor clashing or failure leading to interruptions and fire ignition Explosion and expulsion of oil | Medium | Medium | Medium |
| Regulatory Compliance Business or legislative standards: | Non-compliance with obligations fine, breach of code and standard or licence for TEC, NER, connection agreements, legislation and regulation; Failure of asset. | High | High | Low |
| Customer Customer outcomes: | substandard reliability (SAIFI and SAIDI) unavailability of network services | Medium | Medium | Low |

² TasNetworks Risk Management Framework v1.0 March 2015 (R0000209871)

³ Highest level of risk at each planning level as determined and described within the Network Development Risk Evaluation tables (refer Network Planning)


Network Development Management Plan

| | | | | |
|---|---|--------|--------|--------|
| | <p>inability to meet obligations to connect</p> <p>Community values and expectations</p> <p>Increased customer complaints</p> <p>reputation damage</p> | | | |
| Financial | Higher cost associated with repairing equipment under fault, compensation payments, under regulatory regime - STPIS outcomes; | Medium | Medium | Low |
| Network Performance Loss of equipment life | <p>decreased life expectancy of assets due to operating above design criteria</p> <p>overheating of transformers and switchgear leading to:</p> <p>flashover</p> <p>explosion</p> <p>oil spill</p> <p>reduced current ratings</p> | Medium | Medium | Medium |
| Network Performance System stability / security | <p>running the system in an insecure state or above its capability that may lead to consequential failures</p> <p>protection operation initiated interruptions to supply</p> <p>rotational interruptions to supply to manage equipment loadings</p> | Medium | Medium | Low |
| Network Performance Quality of supply | <p>electromagnetic interference</p> <p>damage to network and customer equipment</p> <p>increased customer complaints</p> <p>protection operation initiated interruptions to supply</p> <p>Operability of reticulation and system components</p> <p>Reduced capability to minimise impacts of planned outages</p> <p>contingency events</p> <p>sub optimal system design and / or equipment that cannot be operated.</p> | Medium | Medium | Low |

9.2 Risk Assessment & Treatment

The network development approach for assessment of risks and the identification, evaluation and implementation of treatment options can be illustrated by the process shown in Figure 2.

Figure 2 – Risk assessment process



9.2.1 Identification

Network development related risks are identified through a range of business processes. Forecast or emerging issues are identified through our annual demand forecasting processes, quarterly reliability performance reporting, and our resulting system investigation and analysis. Current issues are generally identified through customer engagement, field staff, and real time operations.

9.2.2 Risk assessment

The following are assessed in accordance with the risk evaluation tables (refer Section 9.1) to gain an understanding of the risks and to enable the evaluation of treatment options:

- Causative issues;
- Identification of magnitude and breadth of the issue; and
- Implication of not addressing the issue.

9.2.3 Options and solutions

A suite of options (generally 2-4 depending on the planning level and risk) is developed that will address the identified issue(s). Each option is assessed for treatment of the issue with consideration to its implementation, probability of success, business fit and financial requirements. Some projects are jointly attended with the transmission network.

Larger projects are subjected to the NER Regulatory Test process or Regulatory Investment Test for Transmission (RIT-T) where undertaken jointly with the transmission network.

9.2.4 Prioritisation and budget

An economic cost effectiveness analysis of possible options is carried out to identify options that meet the regulatory test. Budgets are refined and year of implementation identified.

Prioritisation takes account of:

1. Severity of the untreated risk;
2. Impact upon the business if left untreated;
3. Time of requirement;
4. Capital finance constraints; and
5. Business appetite.

9.2.5 Business approvals

The identified treatment option is approved according to the level of required expenditure conforming to the business delegation approval process.

9.2.6 Implementation

The project(s) are planned, designed and commissioned.

9.2.7 Evaluation

Following implementation of the solution to treat the risk, the project(s) is evaluated to confirm that the treatment has reduced the level of risk to an acceptable level.

Should the treatment option be unsuccessful the issue is reviewed and the planning process entered again.

10 Management Plan


10.1 Network Planning Levels

Network development works are managed at three planning levels within the distribution network that reflect various levels of assessment, which include:

1. Major System;
2. High Voltage System; and
3. Low Voltage System.

Within each of these levels there are a number of assessment considerations that enable prioritisation for treatment. These are shown in Figure 3.

Figure 3– Network Planning Levels



10.1.1 Major System

The Major System primarily includes zone substations (urban and rural) and sub-transmission circuits operating at 33 kV and 44 kV. Feeder connection sites (to the transmission network) are also considered at this planning level.

Work within this level incorporates strategic planning outcomes associated with the transmission network. Additionally, incurs substantial project capital expenditure and as such regulatory tests are applicable in the majority of cases.

Common projects and programs within this planning level include:

- Upgrade or establishment of urban and rural zone substations including associated distribution feeder integration;
- Strategic acquisition of land associated with zone substation infrastructure corridors;
- Reinforcement or establishment of sub-transmission circuits including protection and communications;
- Establishment of HV feeders from terminal substations;

10.1.2 High Voltage System

The High Voltage (HV)⁴ System planning level includes development of existing and new HV distribution feeders and associated elements operating at 6.6 kV, 11 kV, SWER voltages, 22 kV or 44 kV (assets that are not sub-transmission). This planning level represents the majority of the distribution network, and is the largest component of the Network Development expenditure forecast.

⁴TasNetworks HV feeders operate between 6.6 kV and 22 kV. Although these voltages are commonly referred as medium voltages by other Australian utilities, TasNetworks reference to HV reflects the legacy nomenclature used by Aurora Energy.

The main components of HV system includes:

- Overhead conductor
- Underground cable
- Voltage regulators
- Overhead switchgear (Reclosers, Gas Switches, ABS, Fuses, Links)
- Ground mounted switchgear (generally components of Distribution Substations)

Planning at this level also includes network development works associated with addressing and maintaining reliability performance. This includes:

- Addressing the worst performing HV feeders;
- Addressing the poorest performing Reliability Communities.
- Maintaining Reliability Category performance at a system level (refer TEC).

Generally the HV System is a radially operated system with varied levels of network interconnection depending on population density and topography.

Work within this level incorporates strategic planning outcomes associated with the transmission network..

Common projects and programs within this planning level include:

- Reinforcement or establishment of overhead and underground conductors and cables to manage thermal loading of HV feeder elements;
- Reinforcement or establishment of underground conductors and cables to manage higher than rated fault level of HV feeder elements;
- Reinforcement or establishment of overhead and underground conductors and cables to manage low fault level or voltages along HV feeder;
- Reinforcement or establishment of voltage regulators, cap banks, Statcoms, or mobile generator connection sites to manage thermal loading or low voltage levels on HV feeder elements;
- Reinforcement or establishment of HV feeder interconnections to manage feeder network size, coverage, transfer capability and operational flexibility (planned and unplanned network access and restoration);
- Reinforcing the feeder trunk to manage exposure of the main HV feeder elements (Feeder Trunk Strategy);
- Upgrade, relocation, or establishment of protection devices and switchgear to manage coordination and network reconfiguration (planned and unplanned access and restoration);
- Upgrading distribution substations, where the HV switchgear is integrated, to manage HV feeder network access and reconfiguration.
- Transitioning single-phase or SWER systems to three-phase systems to manage load, voltage, or power quality regulations;
- Migrating 11 kV networks to 22 kV networks to manage load, and voltage.

Additionally, Network Development programs at this level can include:

- Rationalising HV network elements associated with customer development or asset renewal activities – using other TasNetworks or third party activities to increase the efficiency of the network by removing and improving network configurations with those works, reflecting changes in the needs of customers supplied in an area and the economics of opportunity and resource management.

10.1.3 Low Voltage System

This covers Low Voltage (LV) feeders, switches, distribution substations and interconnections operating at < 1 kV i.e. 400/230 V.

This system planning level predominantly consists of upgrading distribution transformers (ground, or pole mounted) and augmenting LV circuits to manage asset loading and voltage. It should be noted that many of the voltage issues at this level of the distribution network are localised and generally managed through the Power Quality thread.

Common projects and programs within this planning level include:

- Upgrading, relocating or establishing distribution transformers, substations, and LV circuits to manage localised thermal loading, voltage, and service performance;
- Installation of HV and LV duct (conduit) with other TasNetworks or third party (local council, developments, etc) works for future network development. Typically for road crossings.
- Reinforcing localised supply feeds to manage exposure of the HV and LV feeder elements (bird strike mitigation, protection relocation, Local Reliability Program);

10.2 Reinforcement Strategy

The management of risk may require treatment by any of the following options:

- | | | |
|----|---|---|
| 1. | Do nothing | No action to be undertaken. |
| 2. | Reduction in loading | Involves redirection of circuit loading to other circuits or units. Non-network solutions such as Demand Side Management and Embedded Generation are considered in this context. |
| 3. | Increase utilisation | Involves re-rating, reducing clearances, improving control settings/limits, adding SCADA control/protection schemes, to operate assets close to operating/physical limits without comprising acceptable levels of performance and risk. |
| 4. | Augmentation | Involves making the device stronger, bigger or replicated. |
| 5. | Removal from service | Involves removal of the asset in its entirety. Normally does not extend to conductors or transformers, given that if the component is heavily loaded it is needed, but can be associated with switches or other control devices. |
| 6. | Network extensions/ interconnections | Establishing additional network to interconnect neighbouring systems – allowing transfer capability and operational flexibility. |

10.3 Guiding principles

In addition to specific considerations applicable to each of the three Network Planning Levels (refer Section 10.1.2) and development strategies described in the Area planning strategy reports, the following principles are common to all levels and aid the assessment of the level of untreated risk and action undertaken to treat any identified risk:

| | |
|---|--|
| Safety | People must not be endangered by the operation of TasNetworks equipment or as a consequence of operating the system. |
| Sub-transmission, High Voltage & Low Voltage circuits | Sub-transmission circuits should be operated with due regard to the cyclic rating of the asset or suite of assets. This enables clearances to ground or other electrical structures to be safely maintained and components not to be unduly stressed e.g. connectors and fittings. |
| Switchgear | Switchgear should be operated with due regard to the rating of the asset or suite of assets. This enables components not to be unduly stressed causing mal-operation. |
| Transformers | Transformers should be operated with due regard to the cyclic rating of the asset or suite of assets. This enables components not to be unduly stressed and the transformer life expectancy not to be unduly shortened by its operation. |
| Customer outcomes | Interruptions and quality of supply are maintained so to not adversely affect the level of contracted supply. |
| Environmental | <p>Relevant environmental standards are to be employed including Electro Magnetic Radiation (EMR) and noise.</p> <p>One of the higher risks is the expulsion of oil due to transformer failure. Management of load mitigates the likelihood.</p> |
| Standards | <p>Relevant standards are to be complied with. Common standards used are:</p> <ul style="list-style-type: none">• Environmental Protection and Biodiversity Conservation Act 1999;• Environmental Management and Pollution Control Act 1994;• Electricity Wayleaves and Easements Act 2000;• Land Acquisition Act 1993;• AS/NZS 61000 Electromagnetic Compatibility (EMC) parts 3.6 & 3.7;• AS 2374.7 Power transformer loading -1997• AS/NZS 3000 Electrical installations (known as the Australian/New Zealand Wiring Rules)• ENA CB(1) 2006;• AS 2067 Substations and High Voltage installations exceeding 1 kV ac;• TEC Chapter 8 sections 3, 6, 7 & 8; and• NER Sections 4.2, 4.6, 5.3, 5.5, 5.6, Schedules 5.1, 5.2, 5.3, 5.4, 5.5, 5.7. |

| | |
|-----------------------------------|---|
| Community values and expectations | The visibility and amenity of any infrastructure installed. Community reaction and appropriate consultation where necessary and the installation of equipment being undertaken with due regard to community values. |
| Loss of equipment life | Larger and more expensive infrastructure is to take into account loss of equipment life due to loading beyond nameplate ratings. This should mainly focus on power transformers and underground cables. |
| System stability | Loading beyond nameplate ratings and system design requirements will introduce elements of system instability and possible consequential supply loss and equipment failure. |
| Operability of components | Loading beyond nameplate ratings will cause reduction of operation capability e.g. switch contacts either welding shut or not being able to be closed. This has consequences of the component and the system being unable to be operated in its optimal state to ensure a reliable and quality outcome. |
| Fault rating | The designated fault rating for the component should not to be exceeded. Conditions to be assessed are steady state and transient modes of operation. |
| System voltage | System voltage output should be contained within its permitted range. |

11 CAPEX Programs 2019-24

11.1 Major System

11.1.1 Zone Substations (CAZNC)

With the exception of Richmond Rural Zone, which is being addressed as part of asset refurbishment project (Asset Strategy) there are no transformation capacity issues at Zone Substations under normal and contingency (N-1) conditions.

In previous regulatory submissions and strategies a number of forecast additional zone substation developments fell within the upcoming two year determination, including Austins Ferry Zone (including Bridgewater 110/33 kV development), Brighton Zone, Blackmans Bay Zone, Sandford Zone, Margate Zone; and Richmond Rural Zone conversion and upgrade.

Based on AEMOs Connection Point forecast, it was determined that the proposed zone substation developments will not be required within the regulatory period to 2029. As such, no additional zone substation projects have been proposed within our regulatory reset.

11.1.2 Strategic Acquisition of Land (LANDZ)

Although it is likely that no zone substations will need to be established within the planning period, strategic acquisition of land may be required to secure appropriate sites that will ensure future costs are known and economical. It is proposed to allow for the purchase of land for these future zone sites at a rate of one land purchase every two years. Two sites falls within the 2019-24 period.

11.1.3 Sub-transmission Circuits (CAZNC)⁵

There are no capacity issues (excluding fault level) associated with the sub-transmission feeders under normal configuration. However, with consideration of TasNetworks planning standards at this network level, under contingency analysis a large number of capacity issues were identified, particularly associated with the summer rated 33 kV overhead networks.

Generally the overhead sub-transmission feeders already utilise the largest conductor size (19/3.25 AAC equivalent) available in the distribution network. To manage these issues, we have proposed to re-rate relevant sub-transmission overhead feeder sections at a higher operating temperature (increase from 50°C to 75°C). This has involved firstly undertaking extensive line audits (thermal, aerial and LiDAR), and is expected to require minor augmentation (re-tensioning, reduced clearances, taller poles etc) in the current period. As these constraints are existing, augmentations are progressing in the current period. We however forecast a proportion of augmentations will continue into the early stages of the 2019-24 reset period.

There are two sections of 33 kV underground cables that will be overloaded during the period to 2029. It is proposed to monitor and/or re-rate these sections using modelling software (CYMCAP) rather than address the constraints through augmentation.

Some 33 kV overhead sections will not be able to operate at a higher temperature due to pole top construction, conductor condition, and location/route limitations. These sections may need to be relocated (including undergrounding), or renewed as required.

expenditure is required largely address the relocation and renewal 33 kV overhead elements that surround the 33 kV connection points at Creek Rd and Risdon.

11.2 High Voltage System

The HV System planning level includes a number of individual projects to address specific area issues, as well as a number of programs that are proposed to manage issues state-wide, including:

- 11.2.1 Derwent Bridge 22 kV supply development (CAHVF);
- 11.2.2 East Coast South supply development (CAHVF);
- 11.2.3 Meadowbank 22 kV supply development (CAHVF);
- 11.2.4 Hobart CBD 11 kV supply development (CAHVF);
- 11.2.5 Sheffield 22 kV supply development (PRHVR);
- 11.2.6 Westbury Urban community reliability improvement (PRHVR);
- 11.2.7 Install/Augment Voltage Regulator – Capacity (CAHVF);
- 11.2.8 Augment HV GI Feeder – Capacity (CAHVF);
- 11.2.9 Augment HV Feeder and Control Station – Fault level (CAHVF);
- 11.2.10 Augment HV Feeder – Network access development (CAHVF);
- 11.2.11 Augment HV Feeder – Trip P, Trip S (PRHVF);

11.2.1 Derwent Bridge 22 kV supply development (CAHVF)⁶

This project is proposed as part of a joint planning network development plan to replace a number of 110/22 kV supply transformers at Waddamana and possibly St Marys that require replacement within the 2019-24 period. The existing Derwent Bridge 110/22 kV substation has a relatively new

⁵ Area Strategy – Greater Hobart

⁶ Area Strategy - Central

110/22 kV 25 MVA capable transformer, and supplies an isolated community with a peak load of only 280 kW.

To enable the supply transformer at Derwent Bridge to be used elsewhere in the network, the forecast need being the Waddamana and St Marys supply transformer condition, this project proposes to extend the 22 kV network supplied from Tungatinah Substation 13 km along the 110 kV corridor to the Derwent Bridge-Butlers Gorge Tee. The existing 110 kV line that supplies Derwent Bridge from this tee will then be energised at 22 kV, and reconfigured at Derwent Bridge to supply the local network.

In previous years TasNetworks (then Transend Networks and Aurora Energy) explored alternative solutions to supply the local Derwent Bridge network by converting the network into a micro-grid. Although the deferral value is much less than previous years, TasNetworks will again be looking to the market for alternative micro-grid solutions for the Derwent Bridge supply. Previous assessments suggest that the proposed network solution is the most economical.

For the distribution augmentation component the project is forecast to be completed before 2022.

11.2.2 East Coast South supply Development (CAHVF)⁷

The Swansea, Bicheno and Coles Bay area is supplied from two distribution feeders – one each from Triabunna (feeder 43507) and St Marys (feeder 57004) substations. The connection of Swan irrigation scheme, although having an intermittent operation, has exhausted any remaining network capacity to supply this area. This project is proposed to address the limited supply capacity and configuration of the East Coast south area that will allow future growth and improve TasNetworks ability to manage this network.

The project proposes the reestablishment of the ‘Royal George’ line, by extending Avoca 56001 16 km along Royal George Rd and Old Coach Rd, north of Swansea.

The project is forecast to be completed within the 2020-24 period.

11.2.3 Meadowbank 22 kV supply development (CAHVF)⁸

This project is proposed as part of a joint planning network development plan to address the transmission security of Meadowbank Substation with regard to the Electricity Supply Industry (Network Planning Requirements) Regulations 2007, that following a supply transformer failure at Meadowbank Substation, the amount of unserved energy would exceed 300 MWh.

Additionally, the proposed solution would improve the reliability performance (SAIDI and SAIFI) in the Central Area, which has been non-compliant in recent years. The project is managed under development augmentation rather than reliability reinforcement as the primary driver is a transmission planning requirement.

The proposal is to energise a section of 110 kV transmission line between Waddamana and the township of Bothwell (ex TL400) at 22 kV, supplied from Waddamana Substation. This will enable larger transfers away from Meadowbank through the distribution network in the event of a

⁷ Area Strategy - Eastern

⁸ Area Strategy - Central

transformer contingency, thereby reducing the amount of possible unserved energy below the 300 MWh deterministic criteria.

The project is forecast to be completed prior to 2023.

11.2.4 Hobart CBD 11 kV supply development (CAHVF)⁹

Hobart CBD is the main central business district in Tasmania and as a defined Critical Infrastructure reliability community, affords the highest service performance targets of any other community in the distribution network.

Hobart CBD is experiencing a period of high growth and declining service performance. At a category level, our reliability performance in SAIFI (over the past 5 years) and SAIDI (past 2 years) for Hobart CBD has been below the standard required under the Tasmanian Electricity Code.

Planned economic developments in the area includes a major commercial and residential development at Macquarie Point, a significantly refurbished public hospital, new accommodation and education facilities to cope with increased tourism and expanding higher education.

Hobart CBD is largely supplied from East Hobart 33/11 kV Zone substation (Risdon 33 kV) as well as from North Hobart 110/11 kV Terminal and West Hobart 33/11 kV Zone substations (Creek Rd 33 kV). The 11 kV feeder networks in the area are radial and relatively interconnected.

Additionally some feeder segments operate with a differential protection schemes. Historically these networks were operated as a number of meshed 11 kV networks. Overtime the meshed operation was removed and segments of differential protection schemes have been reduced or removed due to asset failures, and feeder and customer load developments.

Currently there is no visibility or remote control of these feeder networks downstream of the 11 kV injection points, where a large proportion of distribution substations and switching stations are located within buildings and vaults (and within a traffic congested area) making network access and transfer capability for planned and unplanned responses challenging and timely.

This localised program proposes to develop existing key distribution substation sites that form part of the CBD feeder network. The extent of the development includes:

- Where there is large amounts of space, sites may be developed to include additional switchgear, remote control, visibility over SCADA, and increase feeder interconnectivity and capacity.
- Where site have limited space or are difficult to access (vault type), sites may be developed into having a lower impact on network configuration (remove from main feeder trunk), or develop switchgear to having remote control and visibility over SCADA to limit field operator access needs.
- Teed cable sections may be removed, by developing nearby distribution sites with additional switchgear.
- Direct high capacity 11 kV feeders from the supply substations may be developed to key distribution nodes within the CBD for localised HV distribution.
- Develop feeder networks towards a meshed or ringed operation, requiring development and renewal of the aged copper differential protection infrastructure with newer technology.

⁹ Area Strategy – Greater Hobart

The program has been developed based on a site specific and scoped development plan, staged over the current period through to 2029, that aim to develop approximately one site per year, including the associated underground cable and communications works.

The development program, including multiple locations is forecast to continue through to 2029, driven predominantly by customer development and asset renewal activity.

11.2.5 Sheffield 22 kV supply development (PRHVF)¹⁰

This project is proposed as part of a joint planning network development plan to address the reliability performance of the Railton Rural community, including Railton feeders 85001 and 85003.

There is a spare 110/22 kV supply transformer stored at Sheffield Substation. This project proposes to energise this unit as a semi-permanent 22 kV connection point as part of a related transmission development project.

This project proposed to reinforce the surrounding 22 kV network to integrate the hot spare as a semi-permanent supply substation for the Railton Rural community. Under normal network configuration, parts of the Railton network will be transferred to Sheffield, which will reduce the lengths of those feeder, create transfer capacity, and thereby improve the distribution reliability performance of these networks.

For the distribution augmentation component the project is forecast to be completed before 2024.

11.2.6 Westbury Urban community reliability improvement (PRHVR)¹¹

The Westbury Urban community is an isolated community 35km west of Hadspen that includes the township of Westbury and part of the Westbury industrial estate. This community is supplied by two distribution feeders from Hadspen Substation. The long feeders lead to increased exposure to faults and extended time to repair compared to many other urban communities.

This project proposed to improve reliability of the Westbury Urban community by reducing the exposure of one of the feeders and reinforcing the main feeder trunk from Hadspen Substation. This project is expected to improve the performance of this community to within targets specified in the TEC.

The project is forecast to be completed prior to 2023.

11.2.7 Install/Augment Voltage Regulator for Capacity (CAHVF)

These programs includes the installation of new, or the relocation and/or upgrade of existing regulators to manage asset loading, and/or feeder steady state voltage control under normal or contingent network configurations.

These assets can be pole mounted in an Open-Delta configuration (two single phase tanks to regulate a three phase system), or ground mounted in a Closed-Delta configuration (three single phase tanks to regulator a three phase system).

Closed Delta configurations have the benefit of an additional 5% of voltage regulation, can be paralleled though off neutral tap, and minimise neutral voltage shift. Consequently with the

¹⁰ Area Strategy – North West

¹¹ Area Strategy - Northern

additional tank, this configuration must be ground mounted with appropriate oil containment, which has a substantial cost increase compared to pole mounted arrangements. For these reasons, a Closed-Delta configuration is only installed where a pole mounted unit is not suitable. This is generally required in normal or contingent network configurations where more than two voltage regulators will be configured in series.

This program has been developed through power system analysis of the HV feeder networks using PSS Sincal, and based on existing and forecast loading to 2025. Consideration is given to historical programs as an indicator of the number of installations that can be delivered. Consideration is also given to related programs, such as asset renewals and demand management development, that may also address the identified constraints over this period.

Within the 2019-24 period a total of four units have been proposed.

11.2.8 Augment HV GI Feeder - Capacity (CAHVF)

This program includes the augmentation of existing large GI (3/12 Galvanised Iron conductor) spur feeders where the connected load on these feeder sections has significantly exceeded the capability of conductor type, resulting in unacceptable voltages and related power quality issues.

GI is a low capacity, strong, though highly resistive conductor. It is used to supply small irrigation loads close to the main feeder, or clusters of remote small loads through difficult terrain where large spans are required. Its use is limited to > 500m from a water source, outside of high fault level network areas, and to supply < 300 kVA and 600 kVA at 11 kV and 22 kV respectively. Overtime these spurs have been extended, and the loading on these spurs has increased such that maintaining appropriate voltage levels to customer along these lines is challenging.

This program has been developed through an asset information assessment, identifying those GI spur sections that have > 900 kVA of connected load that represent the GI spurs most likely to be exposing customer to unacceptable voltages. The proposed expenditure is based on reinforcing these sites such that the remaining load supplied from GI conductor is < 300 kVA and < 600 kVA in the 11 kV and 22 kV networks respectively.

Within the 2019-24 period a program totalling 50 km of overhead conductor is proposed (10km/year).

11.2.9 Augment HV Feeder and Control Stations - Fault Level (CAHVF)

This program includes the proposed augmentation of overhead conductors and control stations (such as EDO fuses) to fault rated equivalents where those conductor elements are operating at system fault levels that are in excess of asset fault withstand ratings.

The bulk of the program consists of the augmentation of small conductor (GI, Cu, and Al) installed in close proximity to terminal substations.

This program has been developed through power system fault analysis of the HV feeder networks using PSS Sincal, based on 2017 maximum system fault levels. The program aims to address all conductor sections and control stations operating well in excess of their asset ratings.

Consideration has been given to other asset renewal programs that address small GI, Cu, and Al conductor based on condition, and that address control stations such as EDO fuses based on High Bushfire Consequence Areas, where fault level is an input into site prioritisation under those programs.

Within the 2019-24 period a program totalling 25 km of overhead conductor and 50 control stations sites are proposed (5km and 10 sites per year).

11.2.10 Augment HV Feeder - Network access development (CAHVF)

This program proposes to address areas of the distribution network, identified by Distribution Operations (during switching preparations, and after extreme weather events), that have resulted in:

- inefficient and prolonged outages for planned and unplanned network access,
- excessive use of mobile generators,
- limited outage windows that adversely impact customer and field resources.

Distribution Operations have the responsibility to manage the HV distribution network for system management, system access and fault restoration management. Proposed works under this program aim to improve the efficiency of field staff, reduce outage duration, increase Distribution Operations visibility and remote control capability in the HV network, and increase the flexibility of network access planning.

Within the 2019-24 period a program to address network access constraints is proposed.

11.2.11 Augment HV Feeder - Trip P (PRHVR)

These reliability reinforcement programs include targeted augmentation projects to restore the performance of the poorest performing reliability communities and worst performing feeders towards the performance thresholds as described in the TEC.

The program is a bottom up build of reliability reinforcement projects, and allocated across the current regulatory period, and the subsequent 2019-24 period. This approach concludes that:

- all existing non-compliant communities (that are being addressed by large augmentation development (Refer Sheffield and Westbury projects in Sections 11.2.5 11.2.6 respectively) will be addressed under this program within the 19/20 & 20/21 programs of work.
- any additional non-compliant communities will be addressed in subsequent determinations from 21/22 (Refer 11.2.12 Trip S).

The majority of augmentation projects under this program are associated with Feeder Trunk Strategies (reinforcement of the feeder trunk section between the substation circuit breaker and first or second protection device i.e. Protection Zones 1 & 2), which include:

- Visual audit of vegetation and asset condition of the feeder trunk section
- Targeted vegetation management;
- Targeted asset replacement/relocation;
- Protection coordination review;
- Protection Zone 2 device upgrades as required.

11.2.12 Augment HV Feeder for Reliability - Trip S (PRHVR)

This program is proposed to undertake minor reinforcement to maintain communities that trend below performance targets throughout the period to 2029. This program will begin from 21/22, as the Trip-P reliability reinforcement programs finish, which addresses existing poor performing communities and feeders.

11.2.13 Installation of HV and LV conduit with other underground works

This program incorporates the installation of underground conduit with other works (generally third party works by councils, planning authorities), allowing for:

- Savings in future expenditure associated with excavation and reinstatement civil works (including traffic management);
- Prevention of community inconvenience associated with repeat civil works along public roads and footpaths.
- Meeting the expectations of customers in regards to joint planning activities.

The approach to developing the forecast expenditure for this program is to continue historical volumes and historical expenditure throughout the period to 2024.

11.3 Low Voltage System

11.3.1 Distribution substations (CATXU)

This program consists of upgrading distribution transformers (ground, or pole mounted) for capacity. The approach to prioritising distribution substations for overloading assessment has been undertaken through a comparison of three estimation methods, including:

- Application of an average After Diversity Maximum Demand (ADMD) (4 kVA/customer)
- Application of an estimated ADMD, based on customer numbers and historical logging of +200 sites state-wide.
- Application of a calculated ADMD using Virtual Network Monitoring (Network Innovation)

The three methods provide a reasonable overview of the transformer fleet in terms of the likelihood that some sites may be overloaded. Further, a consequence assessment has been used for the fleet based on safety, environmental, and performance (customer) impact. The resultant prioritised list of distribution transformers forms the basis of targeted site logging assessment, and proposed investigations and augmentations for overloaded transformers.

The approach to developing the forecast expenditure for this program is to continue historical volumes and historical expenditure throughout the period to 2024.

This equates to the following annual volumes and forecast expenditure:

- | | |
|-------------------------------------|---------|
| • Upgrade Ground Substation | 3 sites |
| • Upgrade Pole transformer > 50 kVA | 5 sites |
| • Upgrade Pole transformer < 50 kVA | 5 sites |

11.3.2 Augment Low Voltage Feeders for Capacity (CALVF)

This program consists of augmenting LV circuits to manage asset loading and voltage.

The approach to developing the forecast expenditure for this program is to continue historical volumes and historical expenditure throughout the period to 2029.

11.3.3 Local Reliability (PRTXI, PRHOS, PRSPT)

These programs address localised reliability issues that result in poor levels of service as experienced by customers, but may not be captured effectively at the HV system level (feeder and community performance). Still, these specific issues do contribute to poor community performance, GSL payments and represent the 'worst' customer service performance.

The main programs include:

- Rectification of multi-visit transformers;
- Install/upgrade control station;
- Install bird diverters and pole top reconfigurations;

11.4 OPEX Programs 2019/20-2023/24

There are no OPEX programs included in the network development management plan.

12 Financial Summary

12.1 Proposed CAPEX Expenditure

The capital programs and expenditure identified in this management plan are necessary to manage operational and safety risks and maintain network capacity and performance at acceptable levels. All capital expenditure is prioritised expenditure based on the AEMO 2017 connection point demand forecast, reliability performance reporting at the time of report publication, and TasNetworks existing risk management framework.

Expenditure details are provided in the Network Development Management Plan summary (R883346)

12.2 System Development

The forecast expenditure for capacity (System Development) and reliability reinforcement is steady over the forecast period to 2024, declining towards the end of the period. The higher expenditure in the initial years is influenced by a number of large development projects associated with the HV System.

Demand driven expenditure over the forecast period is low resulting from low demand growth at the majority of connection points. The bulk of our proposed expenditure is required to:

- reinforce regional areas to meet our service performance obligations, improve network access issues, and to support localised growth from agriculture developments; and
- reinforce our Hobart CBD feeder network to support localised growth from development activity, service performance obligations, and provide adequate network visibility and control in this area.

12.3 Reliability

The forecast expenditure for reliability reinforcement is lower than the current (two year) period (on par with historical regulatory period) with minimal forecast reliability driven augmentation projects towards the end of the forecast period to 2029.

Within the 2019-24 period, reinforcement is driven by TasNetworks jurisdictional obligations to manage community performance. There are a small number of proposed projects that influence expenditure within this period.

Appendix A: TasNetworks demand forecast methodology

A ten year connection site forecast is compiled annually by TasNetworks to meet distribution and transmission network demand planning needs, and support the Office of the Tasmanian Economic Regulator's (OTTER) annual reporting requirements in accordance with NER schedule 5.7.

The TasNetworks approach is to project load growth (or decline) at each connection site at a rate consistent with recent history, using weather corrected data and temperature-based 10%, 50%, and 90% Probability Of Exceedance (POE). Distribution planning is based on a 50% POE. The sources of input for this approach are as follows:

- State (TAS) maximum demand forecast produced by the National Institute of Economic Industry Research (NIEIR);
- Temperature data retrieved from the Bureau of Meteorology (BOM) web site;
- Terminal (distribution connection sites) and zone substation active and reactive power data obtained from asset loading information systems; and
- Load adjustment information received from internal process associated with new or augmented customer connections. Only committed connections over 0.5 MW are used as required.

These site or spatial forecasts, in maximum demand MWs, are based on the nature of customers in the region and their demand profiles taking into account subdivision and commercial development opportunities and economic indicators and relationships with energy demands.

The spatial forecasts at connection sites are aggregated together, using diversity factors, to a system level forecast (bottom-up). This bottom-up forecast is compared with and reconciled to a Tasmanian system level forecast that is prepared separately by NIEIR, a top-down approach. There is a review of the data to ensure that it is consistent with the expectations of the Network Planning experts.

The daily load profiles by season, working day and non-working days that are used to develop the forecasts are based on historic profiles.

To produce the connection site forecasts used for system augmentation planning, where appropriate the base-line demand forecasts are adjusted for demand side management initiatives and impacts of larger embedded generating units.

12.4 Linear regression methodology

The individual connection site forecasts are based upon linear regression methodology.

12.5 Temperature correction

Historic data is weather temperature corrected based upon Bureau Of Meteorology (BOM) temperature information across weather sites closest to each connection site.

12.6 Embedded generation

The impact of individual larger embedded generating units on connection site forecasts is only subtracted from the base-line load demand forecasts when the generator would be normally operating at the time of maximum demand on the relevant distribution zone substation or the transmission connection site. As such, for a single embedded generator within a geographical area its unavailability is not allowed for if outside its normal operation.

Should the situation arise where multiple embedded generators operate normally at time of local geographical area maximum demand, a probability based allowance will be made for generating unit unavailability.

The impact of multiple small-scale embedded generation, such as photo-voltaic systems, is included in that the contribution is an inherent part of historic connection point demands.