

16 December 2022

Level 2 20 Bond Street Sydney NSW 2000

T 02 9239 9199

F 02 9233 1965

To: Ms. Chantal Hopwood Head of Regulation **TasNetworks** 1 – 7 Maria Street, Lenah Valley 7008 Tasmania

Via email: Chantal.Hopwood@tasnetworks.com.au

Dear Ms. Hopwood

AEMO review of TasNetworks Network Capability Incentive Parameter Action Plan (NCIPAP) for 1 July 2024 to 30 June 2029

I am writing to provide AEMO's review of your proposed project in the TasNetworks NCIPAP for the regulatory period from 1 July 2024 to 30 June 2029. This review is provided in compliance with clause 5.2 of the Service Target Performance Incentive Scheme (STPIS)¹.

TasNetworks proposed a NCIPAP project "Palmerston substation terminal equipment upgrade".

AEMO agrees with TasNetworks' assessment of the project need, improvement targets and likely material benefits of the proposed NCIPAP. AEMO's assessment is provided in the attachment to this letter.

If you have any questions or would like to seek any clarification, please contact Nadesan Pushparaj at nadesan.pushparaj@aemo.com.au.

Yours sincerely

Samantha Christie

Manager Network Planning

cc: Mr Warwick Anderson, General Manager, AER

¹ AER. Service target performance incentive scheme. https://www.aer.gov.au/networkspipelines/guidelines-schemes-models-reviews/service-target-performance-incentive-scheme-version-5-september-2015-amendment.

TasNetworks - NCIPAP Priority projects for the regulatory period 1 July 2024 - 30 June 2029 AEMO Review - December 2022

Sourced from TasNetworks									AEMO Review			
Project name	Transmission circuit/Injection point	Scope of works	Current limit and reason for the limit	Target limit	Completion date	Capital cost estimate (\$ million)	Operating cost estimate per annum (\$)	Market benefit per annum (\$ million)	Pay back period	Ranking	Review of material benefit	Benefit category
Palmerston Substation terminal equipment upgrade	Palmerston Substation (Waddamana–Palmerston 220 kV transmission lines)	Upgrade terminal equipment at Palmerston Substation for two Waddamana–Palmerston 220 kV transmission lines	The existing thermal ratings of terminal equipment at Palmerston of Waddamana - Palmerston No.1 and No.2 220 kV lines are 453 MVA and 569 MVA respectively. The ratings of these terminal equipment limit northward power flow capability of Waddamana-Palmerston corridor is approximately 1,000 MVA. The 2022 ISP forecasts additional new wind generation of 400 MW in 2025-26 and 1,170 MW in 2030-31 in the Central Highlands REZ. This forecast is credible, given current connection activity in the Central Highlands REZ (and broader southern transmission network) of approximately 480 MW of new wind, with a further 300+ MW in pre-enquiry discussions. With forecast of increased renewable generation in South and Central Tasmania, northward power flow though the Waddamana—Palmerston transmission corridor would exceed its existing thermal capability.	Palmerston 220 kV lines to 762 MVA. This is to allow up to 530 MW of forecast	2025-26	3.77	0	1.63	2.31 years		additional wind generation from South/Central Tasmania to North Tasmania and NEM mainland.	Improve transfer capability. Market benefits due to improved access to low-cost renewable generation

AEMO RESPONSE TO TASNETWORKS NCIPAP PROPOSAL DEC2022.DOCX